

SJENICA, Serbia

WMO: 133690

Lat: 43.283N

Lon: 20.000E

Elev: 3409

StdP: 12.97

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.5	5.0	-4.7	4.8	-1.4	1.7	6.8	5.3	19.0	37.1	17.6	35.4	0.7	160	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	84.1	62.1	81.0	61.9	77.9	61.1	65.1	77.6	63.6	76.3	62.3	74.6	6.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.1	91.2	69.7	59.3	85.4	67.7	57.8	81.1	66.5	31.9	77.5	30.7	76.5	29.7	74.8	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.5	13.9	11.8	DB	-10.9	89.0	9.0	2.9	-17.3	91.1	-22.6	92.8	-27.6	94.4	-34.1	96.6	(4)
(5)			WB	-10.7	68.6	8.4	1.7	-16.7	69.8	-21.7	70.8	-26.4	71.7	-32.5	73.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.3	26.4	29.1	36.2	45.1	52.8	59.3	62.6	62.8	55.1	46.9	38.2	28.7
	DBStd	14.98	10.29	10.00	8.23	6.63	6.00	6.05	5.14	5.05	6.16	7.32	8.86	9.83
	HDD50	3161	731	587	429	170	42	6	1	1	25	145	363	661
	HDD65	7257	1196	1006	892	598	379	186	107	101	300	561	805	1126
	CDD50	1462	0	0	2	22	129	286	392	397	177	49	8	0
	CDD65	83	0	0	0	0	1	15	33	32	2	0	0	0
	CDH74	1676	0	0	0	2	35	314	609	620	94	2	0	0
	CDH80	377	0	0	0	0	3	45	149	167	13	0	0	0
Wind	WSAvg	4.1	4.1	4.5	5.1	5.1	4.6	3.9	3.8	3.4	3.5	3.5	4.0	4.2
Precipitation	PrecAvg	32.2	1.9	2.1	2.4	2.6	3.4	3.2	2.9	2.4	3.3	2.8	2.8	2.5
	PrecMax	44.6	4.5	4.0	5.9	6.6	6.4	6.7	5.4	5.6	8.2	5.4	5.4	5.2
	PrecMin	22.8	0.4	0.5	0.3	0.9	1.3	0.7	0.8	0.0	0.7	0.1	0.2	0.2
	PrecStd	5.5	1.2	0.9	1.3	1.3	1.3	1.5	1.2	1.4	1.8	1.5	1.2	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	55.9	63.0	72.0	78.3	84.6	87.9	88.9	81.6	71.9	63.2	53.6
		MCWB	43.3	44.2	46.6	52.8	58.0	63.3	62.5	63.1	59.4	57.1	50.7	46.6
	2%	DB	46.5	50.3	57.5	66.2	73.8	80.7	83.8	84.5	76.4	67.1	57.6	49.6
		MCWB	41.2	41.8	45.1	50.5	56.9	62.6	62.3	62.0	58.6	54.3	48.4	44.2
	5%	DB	43.2	46.6	53.7	61.8	70.3	77.9	80.6	80.8	72.0	63.4	54.4	46.0
		MCWB	39.0	40.3	43.6	48.5	55.6	61.4	62.4	61.6	57.7	53.0	47.2	41.6
	10%	DB	40.1	43.0	49.9	57.9	66.8	74.2	76.9	77.0	68.1	59.8	51.3	42.7
		MCWB	36.9	38.3	42.2	46.8	54.4	60.3	61.6	60.8	56.5	51.7	45.6	39.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.0	45.4	48.9	54.2	60.2	66.6	66.6	67.4	62.1	58.6	53.1	48.2
		MCDB	48.9	53.5	58.4	67.8	72.3	78.3	78.6	79.9	74.4	68.9	60.0	52.8
	2%	WB	41.7	42.8	46.2	51.5	58.4	64.4	64.9	64.8	60.2	56.0	50.3	44.9
		MCDB	45.8	49.4	55.5	63.1	70.2	76.5	77.8	77.6	71.3	64.2	55.7	48.7
	5%	WB	39.4	40.5	44.3	49.8	56.8	62.7	63.5	63.1	58.8	54.0	48.0	42.1
		MCDB	42.8	45.7	52.4	59.1	68.1	74.9	76.4	75.9	69.4	61.1	53.3	45.6
	10%	WB	37.1	38.4	42.3	47.9	55.0	61.0	62.2	61.8	57.3	52.3	45.9	39.5
		MCDB	39.8	42.6	49.4	56.0	65.2	72.4	74.4	74.2	66.5	58.6	50.5	42.3
Mean Daily Temperature Range	5% DB	MDBR	15.2	16.8	17.5	18.9	20.7	21.8	23.3	24.5	21.2	20.7	17.5	14.8
		MCDBR	18.1	21.7	25.9	28.8	29.2	29.7	31.4	33.1	30.2	27.7	23.8	19.0
		MCWBR	13.1	13.7	14.7	14.4	14.3	13.5	12.9	13.3	14.1	15.4	14.8	13.8
	5% WB	MCDBR	16.2	18.3	22.0	23.6	25.4	26.9	27.2	27.0	25.1	23.7	19.2	15.6
		MCWBR	11.9	11.9	13.0	12.5	13.3	13.1	12.6	12.6	12.4	13.8	12.6	11.6
Clear-Sky Solar Irradiance	taub	0.284	0.307	0.346	0.392	0.391	0.381	0.383	0.389	0.369	0.336	0.306	0.284	
	taud	2.428	2.348	2.317	2.227	2.280	2.337	2.328	2.307	2.358	2.452	2.483	2.460	
	Ebn at Noon	272	282	283	277	280	282	280	274	272	268	261	261	
	Edh at Noon	23	30	36	43	41	39	39	39	34	27	23	21	
All-Sky Solar Radiation	RadAvg	474	724	1076	1356	1660	1898	1964	1786	1249	882	560	406	
	RadStd	67	84	133	171	156	178	151	157	128	108	66	68	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)		+1.03	N/A	N/A	N/A	N/A	N/A	N/A	-209	+162	N/A

Nomenclature: See separate page