

SJENICA, Serbia

WMO: 133690

Lat: 43.283N

Lon: 20.000E

Elev: 1039

StdP: 89.45

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.6	-15.0	-20.4	0.7	-18.5	-16.8	1.0	-14.8	8.5	2.8	7.8	1.9	0.3	160	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	28.9	16.7	27.2	16.6	25.5	16.2	18.4	25.3	17.6	24.6	16.8	23.7	2.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.1	13.0	20.9	15.1	12.2	19.8	14.4	11.6	19.2	56.4	25.3	53.6	24.7	51.3	23.8	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.2	5.3	DB	-23.8	31.7	5.0	1.6	-27.4	32.8	-30.3	33.8	-33.1	34.7	-36.7	35.9	(4)
(5)			WB	-23.7	20.3	4.7	0.9	-27.1	21.0	-29.8	21.6	-32.4	22.1	-35.8	22.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	-3.1	-1.6	2.3	7.3	11.6	15.2	17.0	17.1	12.8	8.3	3.4	-1.8		
	DBStd	8.32	5.72	5.55	4.57	3.68	3.34	3.36	2.85	2.81	3.42	4.07	4.92	5.46		
	HDD10.0	1756	406	326	238	94	23	3	1	1	14	81	202	367		
	HDD18.3	4032	664	559	496	332	211	103	59	56	167	312	447	626		
	CDD10.0	812	0	0	1	12	72	159	218	221	98	27	4	0		
	CDD18.3	46	0	0	0	0	1	8	18	18	1	0	0	0		
	CDH23.3	931	0	0	0	1	19	174	338	344	52	1	0	0		
	CDH26.7	209	0	0	0	0	2	25	83	93	7	0	0	0		
(14) Wind	WSAvg	1.8	1.8	2.0	2.3	2.3	2.0	1.8	1.7	1.5	1.6	1.6	1.8	1.9		
(15) Precipitation	PrecAvg	818	49	53	60	65	86	81	73	61	84	71	71	64		
	PrecMax	1133	115	101	149	167	163	169	137	143	209	137	136	133		
	PrecMin	578	11	13	8	23	34	19	21	1	19	2	6	6		
	PrecStd	140	31	24	33	32	32	37	30	36	45	37	31	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.1	13.3	17.2	22.2	25.7	29.2	31.1	31.6	27.6	22.2	17.3	12.0		
		MCWB	6.3	6.8	8.1	11.5	14.5	17.4	17.0	17.3	15.2	13.9	10.4	8.1		
	2%	DB	8.1	10.2	14.2	19.0	23.2	27.0	28.8	29.2	24.7	19.5	14.2	9.8		
		MCWB	5.1	5.4	7.3	10.3	13.8	17.0	16.9	16.7	14.8	12.4	9.1	6.8		
	5%	DB	6.2	8.1	12.0	16.5	21.3	25.5	27.0	27.1	22.2	17.4	12.5	7.8		
		MCWB	3.9	4.6	6.5	9.2	13.1	16.3	16.9	16.5	14.3	11.6	8.5	5.3		
	10%	DB	4.5	6.1	9.9	14.4	19.4	23.4	24.9	25.0	20.0	15.5	10.7	5.9		
		MCWB	2.7	3.5	5.6	8.2	12.4	15.7	16.5	16.0	13.6	10.9	7.6	4.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	7.4	9.4	12.3	15.7	19.2	19.2	19.7	16.7	14.8	11.7	9.0		
		MCDB	9.4	11.9	14.7	19.9	22.4	25.7	25.9	26.6	23.5	20.5	15.5	11.6		
	2%	WB	5.4	6.0	7.9	10.8	14.7	18.0	18.3	18.2	15.7	13.3	10.2	7.1		
		MCDB	7.7	9.7	13.0	17.3	21.2	24.7	25.4	25.3	21.8	17.9	13.2	9.3		
	5%	WB	4.1	4.7	6.8	9.9	13.8	17.0	17.5	17.3	14.9	12.2	8.9	5.6		
		MCDB	6.0	7.6	11.3	15.1	20.1	23.8	24.7	24.4	20.8	16.2	11.8	7.6		
	10%	WB	2.8	3.6	5.7	8.8	12.8	16.1	16.8	16.6	14.1	11.3	7.7	4.2		
		MCDB	4.3	5.9	9.7	13.3	18.4	22.4	23.6	23.4	19.2	14.8	10.3	5.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	9.3	9.7	10.5	11.5	12.1	12.9	13.6	11.8	11.5	9.7	8.2		
		MCDBR	10.0	12.0	14.4	16.0	16.2	16.5	17.4	18.4	16.8	15.4	13.2	10.5		
	5% WB	MCWBR	7.3	7.6	8.1	8.0	7.9	7.5	7.2	7.4	7.8	8.6	8.2	7.7		
		MCWBR	9.0	10.2	12.2	13.1	14.1	15.0	15.1	15.0	13.9	13.1	10.7	8.6		
(40) Clear-Sky Solar Irradiance	taub		0.284	0.307	0.346	0.392	0.391	0.381	0.383	0.389	0.369	0.336	0.306	0.284		
	taud		2.428	2.348	2.317	2.227	2.280	2.337	2.328	2.307	2.358	2.452	2.483	2.460		
	Ebn at Noon		857	888	892	872	882	889	883	865	857	846	824	823		
	Edh at Noon		74	96	113	134	130	124	124	122	107	86	71	66		
(44) All-Sky Solar Radiation	RadAvg		1.50	2.28	3.39	4.28	5.23	5.98	6.19	5.63	3.94	2.78	1.77	1.28		
	RadStd		0.21	0.26	0.42	0.54	0.49	0.56	0.47	0.50	0.40	0.34	0.21	0.21		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	+0.57	N/A	N/A	N/A	N/A	N/A	N/A	-116	+90	N/A

Nomenclature: See separate page