

POZEGA UZICKA, Serbia

WMO: 133700

Lat: 43.833N

Lon: 20.033E

Elev: 1024

StdP: 14.16

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.8	13.7	4.4	7.2	9.2	10.8	9.9	15.1	12.2	39.3	10.0	39.7	0.6	260	0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	91.3	69.6	88.2	69.0	85.0	68.2	73.0	84.7	71.4	82.9	69.8	81.1	4.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.6	113.1	77.8	67.8	106.0	75.9	66.3	100.6	74.1	37.3	85.1	35.8	82.9	34.4	80.9	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.6	7.6	6.4	-2.1	95.9	7.4	3.1	-7.5	98.1	-11.8	99.9	-16.0	101.7	-21.4	103.9
			-1.3	76.9	8.2	1.8	-7.2	78.2	-12.1	79.2	-16.7	80.2	-22.7	81.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	30.3	35.3	43.7	52.6	60.2	67.2	70.0	62.3	52.3	42.7	32.9		
		DBStd	15.50	8.56	8.82	7.41	5.85	6.05	6.05	4.83	4.76	6.35	6.97	7.29		
		HDD50	2117	612	413	218	38	4	0	0	2	60	239	531		
		HDD65	5363	1076	832	660	374	168	46	13	123	394	670	994		
		CDD50	2745	0	2	23	115	322	517	621	624	370	131	19		
		CDD65	517	0	0	0	1	20	113	169	172	41	1	0		
		CDH74	5679	0	0	3	67	358	1257	1749	1737	484	24	0		
		CDH80	2056	0	0	0	10	68	434	666	720	157	1	0		
(14)	Wind	WSAvg	2.0	1.6	2.0	2.5	2.5	2.4	2.3	2.2	2.1	1.9	1.6	1.4	1.7	
(15)	Precipitation	PrecAvg	30.4	1.8	1.9	2.2	2.5	3.3	3.6	3.0	2.4	2.9	2.5	2.3	2.2	
(16)		PrecMax	47.2	4.0	3.9	6.4	7.0	8.3	7.8	8.8	6.3	6.5	6.0	4.4	4.8	
(17)		PrecMin	21.3	0.5	0.6	0.2	0.9	1.2	1.5	0.6	0.1	0.6	0.1	0.2	0.3	
(18)		PrecStd	6.0	1.0	0.8	1.4	1.3	1.5	1.5	1.7	1.6	1.6	1.5	1.1	1.1	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	57.4	64.6	72.6	81.5	86.2	91.6	94.1	97.0	90.5	77.2	70.7	60.1		
(20)		0.4% MCWB	48.0	51.3	54.2	60.2	64.1	71.0	70.3	69.4	66.0	61.9	57.3	51.1		
(21)		2% DB	49.0	58.2	67.4	74.6	81.8	88.5	90.7	91.9	84.6	73.3	64.5	53.0		
(22)		2% MCWB	43.9	48.2	51.7	57.1	63.8	70.2	70.3	69.0	65.2	60.7	54.5	47.3		
(23)		5% DB	43.8	52.3	63.2	70.5	78.4	85.3	87.3	87.7	79.4	68.4	58.5	45.2		
(24)		5% MCWB	41.3	45.3	50.4	55.1	62.5	69.2	69.6	68.5	64.1	58.3	52.0	42.5		
(25)		10% DB	39.8	46.9	58.3	66.4	74.6	81.9	83.5	83.7	74.9	63.8	53.5	42.1		
(26)		10% MCWB	38.1	43.1	48.2	53.3	61.4	67.8	68.7	68.1	62.9	56.7	49.4	40.5		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	48.4	52.1	55.7	62.1	67.8	74.6	75.2	74.9	69.2	64.5	59.2	51.1		
(28)		0.4% MCDB	56.1	62.6	67.6	75.0	79.2	85.1	86.0	84.4	79.2	73.6	68.0	58.9		
(29)		2% WB	44.6	48.9	53.2	59.1	65.7	72.3	73.0	72.6	67.3	61.8	55.5	47.1		
(30)		2% MCDB	48.6	56.1	64.3	71.9	76.2	84.0	84.5	84.2	78.3	69.3	63.0	51.8		
(31)		5% WB	41.4	45.9	50.9	56.7	64.4	70.5	71.3	70.7	65.5	59.4	52.5	43.1		
(32)		5% MCDB	43.9	51.4	61.1	66.6	75.0	81.9	82.8	82.4	75.4	66.3	57.7	45.0		
(33)		10% WB	38.4	43.1	48.8	54.8	62.6	68.8	69.6	69.2	64.0	57.4	49.8	40.6		
(34)		10% MCDB	39.8	46.9	57.6	63.9	72.5	79.7	80.8	80.2	72.9	63.4	53.2	41.8		
(35)	Mean Daily Temperature Range	MDBR	13.3	17.2	21.0	23.5	22.2	22.0	23.6	24.9	21.7	19.5	16.0	10.7		
(36)		5% DB MCDBR	19.2	28.6	32.4	34.0	30.5	29.2	31.6	34.4	31.0	28.6	25.3	18.2		
(37)		5% DB MCWBR	13.8	18.2	17.3	16.7	13.7	12.3	13.0	13.2	12.8	15.8	16.2	13.1		
(38)		5% WB MCDBR	18.2	25.7	28.6	27.5	25.8	26.8	27.0	26.9	25.3	25.2	23.0	16.4		
(39)		5% WB MCWBR	13.3	16.7	15.9	14.2	13.0	12.3	12.6	11.9	11.3	14.6	15.0	12.4		
(40)	Clear-Sky Solar Irradiance	taub	0.326	0.354	0.394	0.451	0.446	0.438	0.440	0.448	0.424	0.383	0.344	0.323		
(41)		taud	2.368	2.260	2.210	2.085	2.155	2.224	2.220	2.193	2.235	2.345	2.399	2.388		
(42)		Ebn at Noon	250	261	265	258	263	266	263	256	252	248	241	239		
(43)		Edh at Noon	25	33	40	49	47	44	43	43	38	30	24	23		
(44)	All-Sky Solar Radiation	RadAvg	444	698	1062	1366	1671	1886	1944	1756	1226	860	541	379		
(45)		RadStd	64	81	128	165	162	185	153	165	131	104	59	60		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (42 neighbors)	+1.15	N/A	N/A	N/A	+0.65	N/A	N/A	-243	+191	N/A

Nomenclature: See separate page