

UZICE-PONIKVE, Serbia

WMO: 133766

Lat: 43.900N

Lon: 19.700E

Elev: 904

StdP: 90.93

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.9	-10.8	-16.2	1.0	-12.6	-13.0	1.4	-8.4	8.8	0.1	7.9	-0.4	2.6	310	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	29.8	17.7	28.0	17.7	26.2	17.4	20.2	25.3	19.2	24.4	18.5	23.9	2.9	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	14.7	21.9	17.8	14.2	21.6	16.8	13.4	20.8	62.1	25.0	59.1	24.3	56.4	23.8	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.5	5.7	-16.4	31.6	2.6	2.2	-18.3	33.2	-19.8	34.4	-21.2	35.6	-23.1	37.2		
(5)			-16.8	21.7	2.6	0.7	-18.6	22.2	-20.2	22.6	-21.6	23.0	-23.5	23.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	-1.2	0.0	3.8	9.2	12.7	16.5	18.4	19.3	14.4	9.6	6.2	0.1		
	DBStd	8.44	5.61	6.08	4.91	4.32	3.94	3.83	3.52	3.44	4.59	4.59	4.85	5.19		
	HDD10.0	1430	348	282	197	62	19	1	0	0	14	66	131	309		
	HDD18.3	3508	606	514	451	274	177	78	42	29	132	273	366	566		
	CDD10.0	1113	0	2	5	39	103	197	261	290	147	52	16	1		
	CDD18.3	149	0	0	0	1	3	24	46	61	16	1	0	0		
	CDH23.3	1279	0	0	0	3	20	185	395	546	127	3	0	0		
	CDH26.7	309	0	0	0	0	2	26	98	156	27	1	0	0		
(14) Wind	WSAvg	2.5	2.6	2.7	2.9	2.8	2.6	2.4	2.2	2.1	2.2	2.2	2.4	2.7		
(15) Precipitation	PrecAvg	902	54	60	68	73	93	97	84	65	91	74	74	70		
	PrecMax	1336	122	119	182	199	195	198	198	154	196	154	135	167		
	PrecMin	630	16	17	10	21	44	28	18	2	22	3	7	7		
	PrecStd	163	29	25	40	38	34	39	40	41	47	41	32	33		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	15.8	18.1	23.8	25.9	29.0	31.0	32.9	29.9	23.1	18.2	13.9		
		MCWB	6.8	8.6	9.4	12.3	16.2	18.5	17.9	16.5	16.7	12.4	10.8	8.9		
	2%	DB	10.0	12.1	15.2	21.0	23.0	27.1	29.1	30.2	26.8	21.0	16.9	11.9		
		MCWB	6.3	6.7	7.9	11.8	15.3	18.0	18.1	17.3	15.8	12.6	10.4	7.4		
	5%	DB	8.1	10.0	13.1	18.2	21.1	25.8	27.8	28.2	24.1	18.9	14.9	10.0		
		MCWB	5.2	5.7	7.2	10.2	14.0	18.0	18.4	17.3	15.1	12.4	9.6	6.3		
	10%	DB	6.2	8.1	11.1	16.1	19.8	23.9	25.8	26.2	21.9	16.8	12.9	7.8		
		MCWB	3.9	4.6	6.1	9.3	13.7	17.2	18.1	17.0	14.8	11.7	8.6	5.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	8.7	9.9	14.0	17.8	21.2	21.2	20.7	18.2	14.9	12.4	9.2		
		MCDB	10.9	14.2	15.8	20.1	22.3	25.2	26.1	26.3	23.6	20.3	16.8	12.9		
	2%	WB	6.3	7.4	8.9	12.6	16.3	19.9	20.2	19.6	17.1	13.6	11.1	7.7		
		MCDB	9.3	11.7	14.0	18.6	21.1	24.3	25.4	25.4	23.5	18.2	15.2	11.4		
	5%	WB	5.3	6.0	7.9	11.4	15.2	18.9	19.2	18.7	16.1	12.8	9.9	6.3		
		MCDB	7.7	9.2	12.2	16.9	19.5	23.3	24.4	24.7	22.1	17.2	14.2	9.2		
	10%	WB	4.1	4.9	6.7	10.3	14.2	17.8	18.5	17.9	15.3	12.0	8.8	5.0		
		MCDB	5.9	7.3	10.6	15.1	18.0	22.7	23.9	24.1	20.9	16.3	12.1	7.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	6.4	7.5	8.6	8.7	9.1	10.1	10.7	9.4	8.4	7.3	6.1		
		MCDBR	7.6	9.8	10.9	11.8	10.9	11.4	12.7	13.0	12.5	11.7	9.7	8.6		
	5% WB	MCWBR	4.8	5.6	5.9	5.8	5.7	6.0	5.5	5.3	5.0	5.6	5.1	5.4		
		MCWBR	7.2	8.5	10.0	10.5	9.8	10.5	10.9	10.8	10.7	10.3	8.8	7.9		
(40) Clear-Sky Solar Irradiance	taub	taub	0.297	0.322	0.358	0.406	0.403	0.396	0.397	0.403	0.383	0.348	0.314	0.296		
		taud	2.423	2.333	2.301	2.195	2.251	2.304	2.296	2.278	2.321	2.424	2.466	2.444		
	Ebn at Noon	Ebn at Noon	831	865	876	857	869	875	868	850	838	826	804	797		
		Edh at Noon	74	97	114	137	134	128	127	125	111	88	71	67		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.40	2.19	3.35	4.29	5.26	5.92	6.11	5.52	3.85	2.70	1.69	1.18		
	RadStd	RadStd	0.20	0.25	0.40	0.52	0.50	0.57	0.48	0.52	0.42	0.32	0.18	0.19		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		+0.62	N/A	N/A	N/A	+0.37	N/A	N/A	-119	+100	N/A

Nomenclature: See separate page