

CUPRIJA, Serbia

WMO: 133840

Lat: 43.933N

Lon: 21.383E

Elev: 125

StdP: 99.83

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.9	-8.2	-14.0	1.1	-9.9	-11.2	1.5	-7.2	7.5	0.2	6.4	-0.1	0.9	320	0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	35.1	21.4	33.1	20.8	31.2	20.4	23.1	31.3	22.2	30.2	21.4	28.9	1.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.7	15.6	26.1	19.7	14.6	25.1	18.9	13.9	24.2	68.9	31.2	65.5	30.2	62.6	29.0	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.8	4.8	4.0	-15.8	38.1	4.2	2.2	-18.8	39.7	-21.3	41.0	-23.6	42.3	-26.7	43.9		
(5)			-16.1	24.6	4.1	1.0	-19.0	25.3	-21.5	25.9	-23.8	26.4	-26.8	27.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	0.7	2.6	7.0	12.2	16.8	20.4	22.3	17.5	12.1	7.2	2.0	(6)	
(7)		DBStd	8.70	4.77	5.11	4.65	4.04	3.57	3.51	3.09	3.21	3.84	4.39	4.61	4.58	(7)
(8)		HDD10.0	1027	290	209	116	23	1	0	0	0	31	107	250	(8)	
(9)		HDD18.3	2722	548	439	352	186	72	19	4	6	59	197	333	506	(9)
(10)		CDD10.0	1752	1	3	22	91	211	311	383	382	227	95	24	3	(10)
(11)		CDD18.3	403	0	0	0	3	24	81	128	129	36	3	0	0	(11)
(12)		CDH23.3	4850	0	0	4	60	336	953	1533	1501	418	45	1	0	(12)
(13)		CDH26.7	2054	0	0	0	12	85	378	712	718	142	6	0	0	(13)
(14)	Wind	WSAvg	1.5	1.6	1.7	1.8	1.7	1.4	1.3	1.3	1.3	1.4	1.7	1.6	(14)	
(15)	Precipitation	PrecAvg	679	47	45	48	64	72	75	61	59	56	51	55	(15)	
(16)		PrecMax	996	115	96	113	147	181	163	192	150	137	119	123	109	(16)
(17)		PrecMin	445	12	14	5	4	17	21	12	1	10	3	1	7	(17)
(18)		PrecStd	138	27	21	27	31	39	38	39	34	33	32	28	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.9	19.2	23.4	28.4	31.2	35.1	37.6	38.2	34.1	27.3	21.3	15.9	(19)
(20)			MCWB	9.3	11.1	13.0	16.0	19.1	22.1	22.0	21.7	19.8	17.7	14.4	11.1	(20)
(21)		2%	DB	11.2	15.6	20.6	24.8	28.9	32.7	35.0	35.4	30.2	24.4	18.9	13.0	(21)
(22)			MCWB	7.9	9.7	11.7	15.0	18.5	21.4	21.3	21.4	18.9	16.6	13.3	9.6	(22)
(23)		5%	DB	9.2	12.9	17.8	22.4	27.1	30.8	32.9	33.1	27.8	22.0	16.5	10.4	(23)
(24)			MCWB	6.7	8.2	10.5	13.7	17.8	20.8	21.0	20.7	18.1	15.6	12.2	7.9	(24)
(25)		10%	DB	7.2	10.4	15.2	20.2	25.0	28.8	30.8	30.8	25.5	19.7	14.1	8.2	(25)
(26)			MCWB	5.4	7.1	9.4	13.1	17.0	20.1	20.6	20.2	17.3	14.6	10.9	6.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	12.1	14.1	17.6	20.8	24.1	24.1	24.2	21.1	19.0	15.2	12.0	(27)
(28)			MCDWB	12.9	17.6	21.2	25.5	28.1	31.3	32.5	32.9	30.3	25.0	19.7	14.6	(28)
(29)		2%	WB	8.2	10.2	12.3	16.0	19.5	22.7	23.0	22.8	19.7	17.2	13.8	9.7	(29)
(30)			MCDWB	10.9	14.6	18.6	23.3	26.5	30.2	31.4	31.2	27.5	22.7	18.0	12.6	(30)
(31)		5%	WB	6.9	8.6	11.1	14.6	18.6	21.7	22.1	21.8	18.9	16.1	12.5	8.0	(31)
(32)			MCDWB	9.0	12.4	16.8	20.8	25.3	28.6	30.4	30.1	25.5	21.0	16.1	10.3	(32)
(33)		10%	WB	5.5	7.2	9.9	13.5	17.7	20.7	21.3	20.9	18.0	15.0	11.1	6.5	(33)
(34)			MCDWB	7.1	10.2	14.7	19.0	23.7	27.4	28.8	28.6	23.9	19.1	13.9	8.0	(34)
(35)	Mean Daily Temperature Range	MDBR		6.8	8.8	11.1	12.2	12.7	13.2	14.2	14.8	12.6	11.0	8.5	6.6	(35)
(36)		5% DB	MCDBR	10.6	14.4	16.7	17.1	16.9	17.2	18.7	19.3	17.0	15.1	12.2	10.0	(36)
(37)			MCWBR	7.4	8.8	8.8	8.3	7.4	6.9	6.7	6.6	6.8	7.8	7.1	6.9	(37)
(38)		5% WB	MCDWB	9.9	12.9	14.4	14.7	14.8	15.2	15.7	16.0	14.6	13.7	11.1	9.2	(38)
(39)			MCWBR	7.2	8.2	8.1	7.6	7.1	6.7	6.5	6.4	6.6	7.6	6.6	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.345	0.373	0.411	0.471	0.459	0.451	0.453	0.467	0.444	0.402	0.365	0.342	(40)
(41)		taud		2.301	2.205	2.174	2.030	2.126	2.194	2.190	2.148	2.178	2.284	2.335	2.330	(41)
(42)		Ebn at Noon		758	798	816	794	819	826	818	790	774	758	729	723	(42)
(43)		Edh at Noon		85	111	130	162	152	143	142	143	128	102	82	76	(43)
(44)	All-Sky Solar Radiation	RadAvg		1.31	2.14	3.32	4.48	5.42	6.12	6.26	5.61	3.93	2.68	1.66	1.14	(44)
(45)		RadStd		0.19	0.29	0.43	0.52	0.56	0.60	0.48	0.54	0.39	0.36	0.18	0.17	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.68	N/A	N/A	N/A	+0.62	+0.72	N/A	N/A	N/A	N/A
(47)	Regional (50 neighbors)	+0.66	N/A	N/A	N/A	+0.40	+0.42	N/A	-153	+101	N/A

Nomenclature: See separate page