

LESKOVAC, Serbia

WMO: 133890

Lat: 42.983N

Lon: 21.950E

Elev: 761

StdP: 14.30

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.7	16.8	5.8	7.6	12.6	11.5	10.2	19.9	14.2	35.3	12.5	33.3	2.2	180	0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.1	94.7	68.1	91.2	67.4	87.9	66.5	71.2	87.3	69.7	85.1	68.3	82.5	4.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.0	102.1	74.9	65.4	96.4	72.9	63.9	91.6	71.7	35.4	87.5	34.1	85.3	33.0	82.6	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.6	10.2	8.9	2.7	100.0	9.1	3.5	-3.9	102.6	-9.2	104.6	-14.3	106.6	-20.8	109.1
			1.9	73.9	8.8	2.3	-4.5	75.6	-9.7	76.9	-14.6	78.2	-21.1	79.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.4	32.6	37.0	44.7	53.7	61.9	68.5	72.0	72.1	63.6	53.5	44.4	35.1
	DBStd	15.61	8.88	9.24	7.88	6.95	6.13	5.81	5.17	5.26	6.40	7.57	8.08	8.17
	HDD50	1874	540	368	199	42	2	0	0	0	0	54	203	466
	HDD65	4946	1003	783	629	343	133	31	7	9	101	362	618	927
	CDD50	3098	2	5	35	152	371	556	683	684	409	161	36	4
	CDD65	693	0	0	0	3	36	137	225	229	59	4	0	0
	CDH74	8262	0	0	4	97	536	1580	2615	2606	740	82	2	0
	CDH80	3462	0	0	0	18	124	606	1199	1239	262	14	0	0
Wind	WSAvg	3.1	2.7	3.1	3.8	3.5	3.3	3.3	3.4	3.1	2.8	2.5	2.6	2.8
Precipitation	PrecAvg	25.0	1.8	1.7	1.8	2.4	2.6	2.2	1.9	1.7	2.2	2.4	2.2	2.2
	PrecMax	37.4	3.9	3.2	4.6	7.4	5.3	4.7	4.3	5.2	6.9	5.1	5.2	4.1
	PrecMin	15.5	0.4	0.2	0.2	0.8	0.9	0.2	0.2	0.1	0.7	0.2	0.0	0.1
	PrecStd	5.2	1.1	0.7	1.0	1.4	1.1	1.1	1.1	1.3	1.3	1.4	1.3	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.3	66.1	73.3	83.0	87.4	94.3	99.0	99.7	93.3	81.6	71.2	61.4
		MCWB	48.5	50.3	54.5	60.4	64.3	69.0	68.9	68.4	65.3	61.5	57.4	50.9
	2%	DB	53.3	59.9	68.3	76.2	83.3	90.3	94.5	95.1	86.8	75.8	65.9	55.0
		MCWB	45.7	47.8	51.8	57.4	62.8	68.1	68.2	68.1	63.6	59.5	54.2	47.9
	5%	DB	49.1	55.3	63.8	71.8	80.1	86.8	90.8	91.1	82.0	71.5	61.7	50.7
		MCWB	43.6	45.9	49.7	54.7	62.1	66.9	67.9	66.9	62.8	58.5	52.6	46.0
	10%	DB	45.3	50.9	59.4	67.7	76.2	83.2	87.1	87.3	77.6	67.4	57.4	47.0
		MCWB	41.4	44.2	48.0	53.4	60.7	65.8	66.7	65.9	61.4	56.6	50.4	43.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.0	51.9	55.7	61.8	67.7	73.5	72.9	72.7	68.1	64.0	58.0	51.8
		MCDB	56.7	62.7	69.3	77.7	80.6	86.8	88.0	89.0	84.4	74.5	67.5	58.1
	2%	WB	46.5	48.9	53.2	58.9	65.2	70.8	71.1	70.7	66.0	61.9	55.6	48.8
		MCDB	51.8	58.0	64.9	72.0	77.6	84.8	88.0	87.2	79.4	72.0	62.9	53.7
	5%	WB	44.1	46.9	51.0	56.7	63.5	69.0	69.7	69.1	64.5	59.8	53.5	46.3
		MCDB	48.5	54.0	61.5	68.0	75.9	82.2	85.3	84.8	76.8	68.5	60.4	50.5
	10%	WB	41.6	44.5	48.8	54.8	62.0	67.2	68.2	67.6	63.0	57.8	51.3	43.6
		MCDB	45.3	50.5	58.0	64.5	73.4	79.3	82.2	81.7	73.7	65.5	56.8	46.7
Mean Daily Temperature Range	5% DB	MDBR	13.3	16.5	19.8	22.1	23.0	23.9	26.1	27.2	23.6	20.9	17.3	12.0
		MCDBR	20.0	26.0	29.8	31.5	31.1	31.0	34.0	35.7	32.8	28.1	23.8	18.9
		MCWBR	13.0	14.6	14.5	13.5	12.1	10.9	10.5	10.9	11.7	13.2	13.0	12.1
	5% WB	MCDBR	18.6	22.9	26.6	26.6	26.5	27.4	28.6	29.7	26.6	24.5	20.9	16.8
MCWBR		12.5	13.3	13.3	12.1	11.4	11.2	10.5	10.5	10.4	12.3	11.8	11.1	
Clear-Sky Solar Irradiance	taub	0.343	0.372	0.418	0.481	0.469	0.454	0.456	0.473	0.447	0.403	0.368	0.341	
	taud	2.306	2.216	2.136	1.983	2.079	2.171	2.166	2.117	2.157	2.263	2.317	2.330	
	Ebn at Noon	245	256	258	250	257	262	259	250	246	242	233	234	
	Edh at Noon	27	35	43	54	51	46	46	47	42	33	27	25	
All-Sky Solar Radiation	RadAvg	469	742	1083	1412	1714	1962	2025	1821	1302	901	563	402	
	RadStd	72	101	138	173	157	174	149	158	111	122	64	63	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (41 neighbors)	+1.06	N/A	N/A	N/A	+0.72	+0.72	N/A	-297	N/A	N/A

Nomenclature: See separate page