

LESKOVAC, Serbia

WMO: 133890

Lat: 42.983N

Lon: 21.950E

Elev: 232

StdP: 98.57

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.8	-8.5	-14.5	1.1	-10.8	-11.4	1.5	-6.7	6.4	1.9	5.6	0.7	1.0	180	0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.5	34.8	20.0	32.9	19.6	31.0	19.1	21.8	30.7	21.0	29.5	20.2	28.1	1.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.4	14.6	23.8	18.5	13.8	22.7	17.7	13.1	22.0	64.5	30.8	61.5	29.6	58.8	28.1	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.6	4.6	4.0	DB	-16.3	37.8	5.0	1.9	-19.9	39.2	-22.9	40.3	-25.7	41.4	-29.4	42.8	(4)
(5)			WB	-16.7	23.3	4.9	1.3	-20.3	24.2	-23.1	24.9	-25.9	25.7	-29.5	26.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	0.4	2.8	7.1	12.0	16.6	20.3	22.2	22.3	17.6	11.9	6.9	1.7	(6)	
	DBStd	8.67	4.93	5.13	4.38	3.86	3.41	3.23	2.87	2.92	3.56	4.21	4.49	4.54	(7)	
	HDD10.0	1041	300	204	111	23	1	0	0	0	0	30	113	259	(8)	
	HDD18.3	2748	557	435	349	191	74	17	4	5	56	201	343	515	(9)	
	CDD10.0	1721	1	3	19	84	206	309	379	380	227	89	20	2	(10)	
	CDD18.3	385	0	0	0	2	20	76	125	127	33	2	0	0	(11)	
	CDH23.3	4590	0	0	2	54	298	878	1453	1448	411	46	1	0	(12)	
	CDH26.7	1923	0	0	0	10	69	337	666	688	146	8	0	0	(13)	
(14) Wind	WSAvg	1.4	1.2	1.4	1.7	1.6	1.5	1.5	1.5	1.4	1.3	1.1	1.2	1.3	(14)	
(15) Precipitation	PrecAvg	634	45	43	45	62	65	56	49	42	56	61	55	55	(15)	
	PrecMax	950	99	82	116	189	135	119	110	133	176	130	131	104	(16)	
	PrecMin	393	11	6	6	20	24	6	4	2	18	5	1	2	(17)	
	PrecStd	133	27	19	25	36	28	28	28	34	34	36	34	28	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.6	18.9	22.9	28.3	30.8	34.6	37.2	37.6	34.1	27.5	21.8	16.3	(19)	
		MCWB	9.2	10.2	12.5	15.8	17.9	20.6	20.5	20.2	18.5	16.4	14.1	10.5	(20)	
	2%	DB	11.8	15.5	20.1	24.6	28.5	32.4	34.7	35.1	30.4	24.3	18.8	12.8	(21)	
		MCWB	7.6	8.8	11.0	14.1	17.1	20.1	20.1	20.0	17.6	15.3	12.4	8.8	(22)	
	5%	DB	9.5	12.9	17.6	22.1	26.7	30.5	32.6	32.9	27.8	22.0	16.5	10.4	(23)	
		MCWB	6.4	7.7	9.8	12.6	16.7	19.4	19.9	19.4	17.1	14.7	11.4	7.8	(24)	
	10%	DB	7.4	10.5	15.2	19.8	24.6	28.4	30.6	30.7	25.4	19.6	14.1	8.3	(25)	
		MCWB	5.2	6.8	8.9	11.9	16.0	18.8	19.3	18.9	16.3	13.7	10.2	6.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	11.1	13.2	16.6	19.8	23.1	22.7	22.6	20.0	17.8	14.5	11.0	(27)	
		MCDB	13.7	17.0	20.7	25.4	27.0	30.5	31.1	31.7	29.1	23.6	19.7	14.5	(28)	
	2%	WB	8.1	9.4	11.8	14.9	18.4	21.5	21.7	21.5	18.9	16.6	13.1	9.3	(29)	
		MCDB	11.0	14.4	18.3	22.2	25.4	29.3	31.1	30.6	26.4	22.2	17.2	12.1	(30)	
	5%	WB	6.7	8.3	10.5	13.7	17.5	20.5	20.9	20.6	18.1	15.5	12.0	7.9	(31)	
		MCDB	9.1	12.2	16.4	20.0	24.4	27.9	29.6	29.3	24.9	20.3	15.8	10.3	(32)	
	10%	WB	5.3	7.0	9.3	12.7	16.7	19.6	20.1	19.8	17.2	14.3	10.7	6.5	(33)	
		MCDB	7.4	10.3	14.4	18.1	23.0	26.3	27.9	27.6	23.2	18.6	13.8	8.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	9.2	11.0	12.3	12.8	13.3	14.5	15.1	13.1	11.6	9.6	6.7	(35)	
		MCDBR	11.1	14.4	16.6	17.5	17.3	17.2	18.9	19.8	18.2	15.6	13.2	10.5	(36)	
	5% WB	MCWBR	7.2	8.1	8.0	7.5	6.7	6.1	5.8	6.1	6.5	7.4	7.2	6.7	(37)	
		MCWBR	10.3	12.7	14.8	14.8	14.7	15.2	15.9	16.5	14.8	13.6	11.6	9.4	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.343	0.372	0.418	0.481	0.469	0.454	0.456	0.473	0.447	0.403	0.368	0.341	(40)	
		taud	2.306	2.216	2.136	1.983	2.079	2.171	2.166	2.117	2.157	2.263	2.317	2.330	(41)	
	Ebn at Noon	Ebn at Noon	772	807	813	788	811	825	817	788	776	763	735	737	(42)	
		Edh at Noon	86	111	136	171	160	146	146	148	132	105	85	78	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.48	2.34	3.41	4.45	5.40	6.18	6.38	5.74	4.10	2.84	1.78	1.27	(44)	
	RadStd	RadStd	0.23	0.32	0.43	0.55	0.49	0.55	0.47	0.50	0.35	0.39	0.20	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (41 neighbors)	+0.59	N/A	N/A	N/A	+0.40	+0.40	N/A	-165	N/A	N/A

Nomenclature: See separate page