

NIKSIC, Montenegro

WMO: 134590

Lat: 42.767N

Lon: 18.950E

Elev: 2123

StdP: 13.60

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.9	22.6	2.8	6.9	23.5	7.7	8.8	27.2	23.1	36.0	20.4	36.7	8.0	20	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	23.0	91.3	69.1	88.4	68.5	85.4	67.6	72.4	85.7	70.7	84.1	69.0	81.7	8.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.7	114.2	77.5	66.5	105.4	76.1	64.6	98.7	74.7	37.4	85.7	36.0	85.0	34.4	82.4	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	16.9	15.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			12.2	74.5	3.6	3.6	9.6	77.1	7.5	79.2	5.5	81.3	2.9	83.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.4	36.2	37.9	43.1	51.4	58.4	66.5	71.8	72.5	62.9	55.0	45.8	38.6		
	DBStd	13.92	6.41	6.50	6.26	5.25	5.81	6.27	5.13	4.80	5.82	5.55	6.44	6.08		
	HDD50	1570	427	340	224	46	4	0	0	0	0	24	150	355		
	HDD65	4832	892	758	678	408	217	57	8	4	106	310	575	819		
	CDD50	2823	0	2	11	87	264	494	675	696	388	179	25	2		
	CDD65	611	0	0	0	0	12	101	218	236	44	0	0	0		
	CDH74	6108	0	0	0	7	117	973	2192	2394	419	6	0	0		
	CDH80	2252	0	0	0	0	8	265	865	994	120	0	0	0		
(14) Wind	WSAvg	6.3	5.7	6.8	7.5	7.0	6.6	6.4	6.4	6.0	5.6	5.7	6.0	6.1		
(15) Precipitation	PrecAvg	75.6	8.0	7.4	6.4	6.8	4.6	3.4	2.2	2.6	5.5	8.9	11.4	9.9		
	PrecMax	98.5	17.8	15.9	19.1	14.6	9.1	7.2	6.7	8.4	13.8	22.0	30.0	20.7		
	PrecMin	53.9	0.0	0.0	0.2	1.7	1.7	1.0	0.3	0.2	0.5	0.0	2.7	1.2		
	PrecStd	12.0	5.0	4.1	4.1	3.1	2.1	2.0	1.5	2.0	3.2	4.6	5.3	5.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	61.1	65.8	72.9	80.8	89.0	95.3	95.6	88.6	75.0	67.5	56.3		
		MCWB	46.6	47.5	50.4	54.4	64.8	69.2	70.6	69.6	66.6	61.2	54.7	47.8		
	2%	DB	50.8	53.9	61.1	68.4	77.2	86.1	91.4	92.1	83.3	72.0	61.8	52.6		
		MCWB	44.7	45.2	49.0	53.3	62.6	68.1	68.6	69.3	65.5	59.9	52.5	47.8		
	5%	DB	47.7	50.1	57.7	65.1	73.9	82.9	88.3	88.9	78.6	69.3	58.1	50.2		
		MCWB	44.1	44.3	47.0	52.4	60.6	66.9	68.4	68.7	63.6	58.7	52.1	46.7		
	10%	DB	45.1	47.0	54.0	62.0	70.7	79.7	85.1	85.7	74.4	65.9	55.4	47.6		
		MCWB	42.1	42.6	45.9	50.9	59.2	65.3	67.8	67.7	61.7	57.2	50.8	44.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.6	51.2	54.2	58.7	67.3	73.4	75.4	75.5	70.2	64.9	58.5	52.8		
		MCDB	51.4	54.3	58.6	65.8	76.5	84.2	85.6	88.0	84.0	69.6	61.2	53.1		
	2%	WB	47.4	48.2	51.4	56.1	64.7	70.5	72.5	72.3	67.2	62.2	56.0	50.2		
		MCDB	48.9	51.6	57.0	63.7	73.7	81.8	85.6	87.0	78.3	67.7	58.8	50.9		
	5%	WB	45.1	45.8	49.0	54.2	62.2	68.6	70.7	70.6	65.1	60.2	53.8	47.4		
		MCDB	46.7	48.5	54.0	61.7	71.1	79.8	83.9	85.0	74.7	66.2	56.6	49.0		
	10%	WB	42.7	43.9	47.3	52.5	60.1	66.8	68.9	68.8	63.1	58.5	51.7	44.9		
		MCDB	44.5	46.1	52.1	59.5	68.5	77.3	81.5	82.3	72.2	64.2	54.3	46.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	13.3	14.4	15.4	17.6	19.4	21.8	23.0	19.0	17.3	14.8	12.8		
		MCDBR	17.8	19.7	21.9	22.3	23.1	24.3	27.2	28.1	25.7	24.4	21.6	19.3		
		MCWBR	12.9	12.8	12.0	11.4	11.6	11.1	11.3	11.9	11.3	13.8	13.7	13.0		
	5% WB	MCDBR	14.3	15.0	17.2	18.8	21.8	22.7	24.4	25.9	22.0	19.9	15.7	12.5		
		MCWBR	11.8	11.2	11.1	11.4	12.4	12.3	13.1	13.3	11.8	13.2	11.7	9.6		
(40) Clear-Sky Solar Irradiance	taub		0.315	0.342	0.392	0.447	0.438	0.422	0.422	0.430	0.405	0.373	0.343	0.314		
	taud		2.381	2.285	2.179	2.067	2.154	2.252	2.250	2.222	2.276	2.349	2.383	2.405		
	Ebn at Noon		259	269	267	260	266	271	269	263	260	254	245	248		
	Edh at Noon		25	33	41	50	47	43	43	42	37	31	25	23		
(44) All-Sky Solar Radiation	RadAvg		504	734	1111	1444	1791	2071	2141	1915	1358	938	584	449		
	RadStd		62	106	154	169	150	151	134	137	113	100	65	82		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)	+0.95	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-191	+180	N/A

Nomenclature: See separate page