

PRIZREN, Kosovo

WMO: 134770

Lat: 42.217N

Lon: 20.733E

Elev: 1322

StdP: 14.01

Time Zone: 1.00 (EUC)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.9	18.7	10.1	9.7	17.8	13.3	11.3	21.1	18.8	39.1	15.8	46.5	1.4	0	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.0	92.4	67.8	89.1	67.0	86.2	66.1	69.8	87.2	68.5	85.2	67.3	83.3	4.6	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.9	93.4	76.4	62.7	89.4	75.1	61.4	85.3	74.2	34.5	87.4	33.5	85.6	32.5	83.5	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.3	12.1	9.9	10.1	97.3	5.9	2.8	5.9	99.3	2.5	101.0	-0.9	102.5	-5.1	104.6		
			9.9	71.8	5.5	1.7	6.0	73.0	2.7	74.0	-0.3	75.0	-4.3	76.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.5	33.7	37.7	46.0	53.2	62.3	70.2	74.1	73.8	65.5	55.2	45.2	35.5
	DBStd	16.05	7.80	8.52	8.09	7.09	6.68	6.09	5.91	5.84	6.11	7.84	9.03	9.46
	HDD50	1780	506	351	176	46	3	0	0	0	0	39	196	463
	HDD65	4728	969	765	589	355	131	18	4	8	67	314	594	914
	CDD50	3408	1	6	52	143	383	605	747	739	466	199	53	14
	CDD65	882	0	0	0	2	46	173	286	282	83	9	1	0
	CDH74	7609	0	0	0	24	324	1439	2717	2437	606	61	1	0
	CDH80	2763	0	0	0	0	66	470	1107	958	154	8	0	0
Wind	WSAvg	3.2	2.6	3.1	4.0	3.9	3.6	3.6	3.3	3.3	3.1	2.7	2.4	2.9
Precipitation	PrecAvg	30.3	2.0	2.2	2.5	2.5	2.2	2.2	2.3	1.4	3.0	3.1	3.7	3.1
	PrecMax	44.8	4.6	4.3	5.2	4.3	4.6	5.7	6.9	4.8	7.5	6.5	7.3	6.9
	PrecMin	20.8	0.2	0.2	0.2	0.5	0.4	0.3	0.2	0.0	0.4	0.2	1.3	0.4
	PrecStd	6.8	1.1	1.1	1.5	1.1	1.3	1.3	1.7	1.1	1.9	1.9	1.7	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.6	63.0	71.6	77.1	85.9	92.8	99.1	96.0	89.0	80.6	70.0	63.9
		MCWB	48.8	49.1	53.0	57.2	63.3	68.8	69.3	68.9	66.4	62.0	56.7	52.5
	2%	DB	52.3	58.3	67.4	72.2	81.6	88.6	93.5	91.8	84.2	74.4	64.6	58.8
		MCWB	45.5	47.5	51.8	55.0	62.5	67.2	68.1	67.6	64.6	60.4	54.3	51.2
	5%	DB	48.8	54.9	63.1	68.6	77.6	85.2	89.4	88.7	80.5	70.5	60.3	54.7
		MCWB	43.6	45.8	49.4	53.9	60.9	66.0	67.3	66.7	63.3	59.0	52.5	48.5
	10%	DB	45.8	51.0	58.7	64.7	73.7	82.0	86.0	85.7	76.9	67.0	57.2	49.8
		MCWB	41.8	43.4	47.7	52.2	58.9	64.7	66.5	65.9	61.9	57.5	51.1	45.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.5	50.2	54.3	58.4	65.3	70.3	71.7	71.6	67.7	63.8	57.7	54.1
		MCDB	56.8	60.7	69.1	71.6	80.5	88.4	91.5	90.5	82.0	76.2	66.5	61.5
	2%	WB	46.4	47.9	52.4	56.5	63.2	68.5	70.0	69.4	65.9	61.6	55.2	51.2
		MCDB	51.4	57.4	65.5	69.4	78.5	86.0	87.8	86.1	80.9	71.6	62.8	58.1
	5%	WB	43.9	45.9	50.4	54.9	61.7	66.9	68.8	68.0	64.6	59.9	53.2	48.5
		MCDB	48.6	54.0	61.5	66.4	75.8	83.3	85.7	84.7	77.8	68.9	59.5	54.9
	10%	WB	41.8	43.9	48.2	53.1	59.9	65.4	67.5	66.9	63.0	58.2	51.4	45.2
		MCDB	45.3	50.4	57.7	63.5	71.9	80.2	83.4	82.5	74.8	66.0	56.6	49.4
Mean Daily Temperature Range	5% DB	MDBR	11.0	14.3	15.6	15.6	17.1	19.2	21.0	20.5	18.9	16.2	11.9	9.2
		MCDBR	16.1	20.6	22.6	21.8	22.5	23.0	25.1	25.1	24.2	20.5	16.4	14.6
		MCWBR	10.6	12.1	11.1	10.1	10.1	9.5	9.4	9.3	9.8	10.1	9.3	8.8
	5% WB	MCDBR	14.7	19.1	19.7	19.3	20.9	22.1	22.4	22.3	21.2	18.6	15.1	14.5
MCWBR		9.9	11.5	9.9	9.6	9.6	9.8	9.9	9.2	9.2	9.9	8.7	8.9	
Clear-Sky Solar Irradiance	taub	0.316	0.342	0.385	0.436	0.433	0.412	0.416	0.432	0.410	0.374	0.344	0.317	
	taud	2.379	2.300	2.236	2.113	2.189	2.289	2.271	2.225	2.271	2.360	2.400	2.397	
	Ebn at Noon	260	270	271	264	268	273	271	263	259	255	247	249	
	Edh at Noon	26	33	39	48	46	41	42	42	38	30	25	23	
All-Sky Solar Radiation	RadAvg	513	769	1103	1430	1739	2003	2087	1876	1336	940	598	433	
	RadStd	75	99	142	174	142	162	141	143	121	115	66	74	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (34 neighbors)	+0.99	N/A	N/A	N/A	N/A	N/A	N/A	-203	N/A	N/A

Nomenclature: See separate page