

OHRID, North Macedonia

WMO: 135790

Lat: 41.100N

Lon: 20.817E

Elev: 2297

StdP: 13.52

Time Zone: 1.00 (EUC)

Period: 97-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.6	19.8	8.1	9.1	19.9	12.3	11.2	22.6	20.8	40.7	18.7	36.2	7.3	350	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.8	86.5	66.6	83.7	66.4	81.3	66.0	70.5	80.6	69.0	79.3	67.6	78.1	5.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.0	108.3	76.9	65.4	102.0	75.2	63.8	96.4	73.7	35.9	80.3	34.5	79.5	33.3	78.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	15.0	13.0	9.1	91.3	2.8	2.8	7.1	93.2	5.4	94.9	3.9	96.4	1.8	98.4
			8.4	73.1	2.8	1.9	6.3	74.4	4.7	75.6	3.1	76.7	1.1	78.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	34.1	35.6	42.2	49.5	57.7	64.1	68.8	69.3	61.6	53.3	44.0	37.3
	DBStd	13.55	6.58	6.59	6.06	5.17	4.62	5.21	4.08	4.04	4.91	5.72	6.26	7.41
	HDD50	1846	493	402	250	66	3	0	0	0	1	36	197	398
	HDD65	5262	958	822	708	466	228	78	15	9	124	364	630	860
	CDD50	2406	0	0	7	50	241	423	583	597	347	138	17	3
	CDD65	348	0	0	0	0	2	51	132	142	21	0	0	0
	CDH74	3443	0	0	0	1	44	529	1350	1322	195	2	0	0
	CDH80	774	0	0	0	0	1	90	324	339	20	0	0	0
Wind	WSAvg	5.0	5.3	5.8	5.7	5.0	4.3	4.5	4.8	4.6	4.7	4.8	4.8	6.1
Precipitation	PrecAvg	27.7	2.4	2.2	2.0	2.8	2.0	1.3	1.3	1.0	2.6	3.3	3.8	3.2
	PrecMax	33.8	5.5	5.7	3.7	4.4	4.3	2.9	3.7	3.0	5.6	6.7	7.1	6.4
	PrecMin	19.0	0.0	0.6	0.2	0.6	0.2	0.1	0.0	0.1	0.4	0.2	1.1	0.0
	PrecStd	4.7	1.6	1.3	1.0	0.9	1.1	0.7	1.0	0.7	1.5	1.7	1.4	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	53.8	64.0	69.9	78.0	86.5	89.3	89.8	82.9	72.9	64.3	57.8
		MCWB	47.1	45.7	52.4	55.0	63.5	67.4	66.2	66.5	63.2	61.2	57.3	52.2
	2%	DB	48.9	50.9	58.4	65.5	74.8	82.3	86.4	86.7	79.2	69.6	60.4	53.8
		MCWB	45.6	45.1	49.1	54.1	62.3	67.1	66.7	66.6	63.3	60.6	54.8	49.4
	5%	DB	46.4	48.4	55.7	62.7	72.0	79.7	83.8	83.9	76.0	66.6	57.4	51.2
		MCWB	43.6	43.9	47.8	52.8	61.0	66.5	66.6	66.3	62.8	59.0	52.8	48.0
	10%	DB	44.3	46.3	52.9	59.4	69.2	76.9	81.3	81.2	72.7	63.8	54.9	48.7
		MCWB	42.0	42.7	46.5	51.2	59.8	65.5	66.3	65.7	61.5	57.6	51.0	46.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.9	47.8	53.8	57.6	65.7	71.9	72.3	72.4	67.2	64.3	58.3	52.8
		MCDB	50.5	51.8	61.8	66.2	74.8	80.0	81.7	83.5	76.2	70.4	62.3	55.8
	2%	WB	46.1	45.7	50.9	55.5	63.5	69.6	70.5	70.1	65.2	61.8	55.6	50.1
		MCDB	48.6	49.1	56.6	62.9	72.2	78.4	80.8	80.8	74.6	67.4	59.2	53.2
	5%	WB	44.1	44.6	49.0	53.9	62.0	67.9	69.0	68.5	63.7	59.9	53.5	48.2
		MCDB	46.1	47.8	53.9	60.9	70.1	77.2	79.8	79.5	73.1	65.2	57.2	51.1
	10%	WB	42.1	43.0	47.3	52.3	60.5	66.3	67.6	67.1	62.3	58.3	51.3	46.2
		MCDB	44.1	46.2	51.8	58.2	68.0	75.7	78.3	78.2	71.3	63.2	54.6	48.5
Mean Daily Temperature Range	5% DB	MDBR	12.4	14.3	15.8	17.1	20.1	22.3	23.8	23.9	20.0	17.6	14.9	11.9
		MCDBR	14.4	17.7	21.5	23.0	25.6	26.2	28.2	27.2	25.2	21.3	17.5	13.8
		MCWBR	11.0	12.3	13.2	12.7	13.9	12.9	12.7	12.3	12.1	13.2	12.4	10.4
	5% WB	MCDBR	13.4	16.1	18.6	20.4	23.8	24.6	24.8	24.8	22.6	19.3	16.0	13.3
	MCWBR	10.6	11.8	12.0	12.3	13.9	13.4	13.1	12.9	12.1	12.9	11.6	10.4	
Clear-Sky Solar Irradiance	taub	0.309	0.334	0.379	0.431	0.427	0.404	0.409	0.422	0.406	0.370	0.336	0.310	
	taud	2.427	2.346	2.253	2.115	2.190	2.297	2.278	2.237	2.266	2.356	2.421	2.432	
	Ebn at Noon	268	276	274	267	271	277	274	266	262	259	254	257	
	Edh at Noon	25	32	39	48	46	41	42	42	38	31	25	23	
All-Sky Solar Radiation	RadAvg	561	811	1133	1463	1783	2080	2176	1930	1412	999	648	492	
	RadStd	79	108	149	166	138	155	122	126	121	107	65	89	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (22 neighbors)	+0.86	N/A	N/A	N/A	N/A	N/A	N/A	-212	+182	N/A

Nomenclature: See separate page