

KORCA, Albania

WMO: 136290

Lat: 40.600N

Lon: 20.767E

Elev: 2949

StdP: 13.20

Time Zone: 1.00 (EUC)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 18.7	(c) 22.7	(d) 10.8	(e) 10.7	(f) 25.4	(g) 14.9	(h) 13.0	(i) 25.8	(j) 32.0	(k) 43.4	(l) 26.3	(m) 38.5	(n) 2.5	(o) 40	(p) 0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.8	88.6	65.9	85.8	65.3	83.2	64.5	69.4	80.3	68.0	78.4	66.9	77.4	6.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	109.2	73.3	65.0	103.4	71.8	63.6	98.2	70.8	35.4	80.3	34.2	78.5	33.2	77.3	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a) 21.4	(b) 15.4	(c) 12.3	(d) 12.5	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.9	34.6	39.8	45.4	52.8	59.3	66.4	72.1	71.7	64.4	54.7	46.4	38.3
	DBStd	13.92	7.33	6.75	5.84	6.68	5.43	6.27	4.87	4.40	5.57	5.85	5.88	6.36
	HDD50	1511	478	292	168	44	3	0	0	0	0	26	136	364
	HDD65	4664	942	706	607	369	191	58	5	4	75	320	558	829
	CDD50	2933	0	5	26	128	290	493	684	672	433	173	28	1
	CDD65	613	0	0	0	3	13	101	225	211	58	2	0	0
	CDH74	5008	0	0	0	34	80	764	1907	1807	406	10	0	0
	CDH80	1434	0	0	0	4	9	180	618	553	68	2	0	0
Wind	WSAvg	4.6	4.2	5.4	5.3	5.5	5.1	4.6	4.3	4.2	4.7	4.1	4.4	3.9
Precipitation	PrecAvg	32.1	2.6	2.8	2.6	3.1	2.7	1.7	1.3	1.3	3.1	3.3	4.3	3.8
	PrecMax	51.7	6.7	5.9	5.4	7.3	6.7	4.1	3.1	3.0	9.8	8.8	9.2	8.0
	PrecMin	21.5	0.2	0.6	0.6	0.8	0.6	0.4	0.1	0.2	0.2	0.2	1.0	0.4
	PrecStd	8.9	1.8	1.5	1.3	1.5	1.6	1.0	0.8	0.7	2.5	2.1	1.9	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.2	62.0	67.4	77.4	80.1	88.6	93.2	91.4	86.6	75.1	64.6	54.6
		MCWB	46.9	47.7	50.7	56.3	59.8	66.0	66.6	68.4	63.4	58.7	53.5	47.9
	2%	DB	49.3	57.2	64.0	72.9	76.2	84.3	88.9	88.4	81.7	71.0	60.5	51.7
		MCWB	44.8	45.9	49.2	54.8	59.0	64.6	65.4	66.8	63.8	56.8	52.2	47.1
	5%	DB	47.0	53.0	60.3	68.3	73.1	81.6	86.2	85.3	78.8	67.8	57.2	49.6
		MCWB	43.2	45.1	47.7	52.8	57.7	64.3	64.9	65.7	62.7	56.2	51.7	45.8
	10%	DB	44.6	49.5	56.4	65.0	70.2	78.2	83.4	82.7	76.0	65.0	54.9	47.2
		MCWB	41.4	44.2	46.6	52.1	57.2	62.8	64.3	64.6	62.0	55.4	50.5	43.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.8	50.1	52.6	59.0	63.3	70.2	70.8	73.0	68.5	61.8	56.3	50.5
		MCDB	51.4	56.2	63.0	69.3	72.4	79.5	81.7	85.3	76.8	69.4	59.8	51.9
	2%	WB	45.6	48.0	50.3	56.7	61.1	68.0	69.0	69.8	66.2	59.9	54.4	48.4
		MCDB	48.3	53.0	60.7	67.5	70.7	77.9	79.8	81.3	76.5	66.1	57.7	50.6
	5%	WB	43.5	46.4	48.8	55.2	60.1	66.4	67.7	68.1	64.8	58.3	52.4	46.7
		MCDB	46.4	52.0	57.6	65.8	69.0	76.9	77.8	79.3	74.4	64.0	56.0	48.9
	10%	WB	41.7	44.5	47.4	53.3	58.8	64.6	66.6	66.8	63.3	56.8	50.8	44.3
		MCDB	44.3	49.6	54.6	62.3	67.3	75.1	77.2	77.6	72.1	62.5	54.4	46.3
Mean Daily Temperature Range	5% DB	MDBR	10.8	12.1	13.9	16.8	16.1	17.4	18.8	19.7	17.1	16.0	12.2	11.2
		MCDBR	13.1	18.6	21.7	23.0	20.5	21.1	22.3	22.6	22.4	21.4	16.2	14.4
		MCWBR	8.8	9.0	9.3	8.6	7.5	7.2	6.9	7.5	7.1	9.1	8.6	9.1
	5% WB	MCDBR	11.3	13.8	18.7	20.4	17.3	19.2	19.4	20.0	18.8	17.1	12.1	11.0
		MCWBR	8.2	8.0	9.3	8.3	7.4	7.4	6.8	7.7	7.8	8.8	8.0	8.2
Clear-Sky Solar Irradiance	taub	0.304	0.330	0.375	0.426	0.422	0.401	0.408	0.420	0.402	0.366	0.331	0.306	
	taud	2.448	2.353	2.256	2.114	2.184	2.285	2.262	2.226	2.263	2.359	2.428	2.448	
	Ebn at Noon	272	279	277	269	272	277	274	267	264	262	258	261	
	Edh at Noon	25	32	39	48	46	42	42	43	38	31	25	23	
All-Sky Solar Radiation	RadAvg	579	822	1164	1480	1815	2118	2210	1952	1440	1025	669	514	
	RadStd	75	116	144	164	136	154	120	123	115	104	64	92	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (16 neighbors)	+0.72	N/A	N/A	+1.28	N/A	N/A	N/A	-180	+180	N/A

Nomenclature: See separate page