

KREDARICA, Slovenia

WMO: 140080

Lat: 46.3789N

Lon: 13.8489E

Elev: 8251

StdP: 10.81

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.5	0.7	-21.2	2.3	18.3	-16.1	3.1	15.2	50.3	18.2	43.7	15.8	22.3	320	0.924

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	58.3	48.4	55.9	47.5	53.8	46.3	51.3	55.5	49.5	53.8	48.0	52.1	7.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
49.3	71.1	53.4	47.6	66.5	51.5	46.0	62.5	50.0	24.2	55.7	23.0	54.1	22.0	52.2	60.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.8	34.4	29.5	-7.4	62.2	5.4	2.9	-11.3	64.3	-14.5	65.9	-17.5	67.6	-21.5	69.7		
(5)			-7.7	54.1	4.9	2.4	-11.2	55.8	-14.1	57.2	-16.8	58.6	-20.3	60.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	31.1	19.0	18.3	21.9	26.1	34.0	41.5	45.1	45.7	37.9	34.3	26.3	21.9	(6)
(7)		DBStd	12.34	9.19	9.38	8.53	7.20	6.33	6.92	5.77	6.03	6.78	7.72	8.80	9.27	(7)
(8)		HDD50	6961	961	887	870	716	497	266	171	159	363	488	712	871	(8)
(9)		HDD65	12381	1426	1307	1335	1166	962	706	617	599	813	952	1162	1336	(9)
(10)		CDD50	56	0	0	0	0	0	10	18	26	1	1	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	12.5	16.2	15.1	14.5	12.2	11.1	9.4	9.1	9.1	10.9	12.6	14.8	15.1	(14)
(15)	Precipitation	PrecAvg	77.4	4.1	3.7	4.6	5.6	5.7	6.7	6.7	6.3	8.4	9.6	10.1	5.9	(15)
(16)		PrecMax	103.3	17.3	17.1	14.5	10.9	11.4	11.5	11.4	11.5	15.3	23.7	34.4	17.8	(16)
(17)		PrecMin	58.0	0.2	0.1	0.0	0.9	2.3	1.4	2.3	2.1	3.3	0.0	1.8	0.0	(17)
(18)		PrecStd	12.4	3.6	3.8	3.2	2.8	2.3	2.5	2.2	2.4	3.7	5.2	7.0	4.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.6	41.9	40.3	44.0	51.7	59.0	60.7	62.0	54.7	53.1	48.0	42.7	(19)
MCWB			28.7	28.2	29.0	34.8	40.2	47.6	50.8	50.3	43.8	38.4	34.9	29.1	(20)	
2%		DB	37.7	38.1	37.4	40.9	48.1	55.7	57.5	59.0	51.9	49.5	45.2	39.4	(21)	
		MCWB	27.7	27.4	28.5	33.6	40.4	46.7	49.4	47.8	42.9	35.8	34.0	27.6	(22)	
5%		DB	34.6	34.8	35.1	38.2	45.1	53.5	55.2	56.4	49.3	46.6	41.3	36.7	(23)	
		MCWB	25.9	25.8	27.8	32.3	39.2	45.8	48.5	47.2	41.0	35.9	31.7	26.7	(24)	
10%		DB	31.4	31.3	33.1	35.5	42.7	51.2	53.0	53.8	47.2	44.1	36.7	34.1	(25)	
		MCWB	24.1	24.6	27.0	30.9	37.5	44.6	46.8	47.1	40.5	34.9	30.7	25.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.9	31.6	32.2	37.5	44.9	51.9	54.2	53.6	47.9	42.4	39.2	32.0	(27)
MCD B			37.0	37.4	36.1	40.5	47.9	55.9	58.0	58.1	51.2	46.6	45.5	37.2	(28)	
2%		WB	28.9	28.5	30.6	35.9	42.0	49.4	51.6	51.1	45.5	40.9	35.9	30.3	(29)	
		MCD B	34.9	34.7	34.7	39.4	45.5	53.7	55.7	55.6	48.5	42.9	40.6	34.6	(30)	
5%		WB	27.4	27.0	29.2	33.8	40.0	47.3	49.6	49.5	43.9	39.6	33.7	28.8	(31)	
		MCD B	32.4	32.4	33.2	36.6	43.2	51.4	53.5	54.0	47.1	42.1	36.6	33.4	(32)	
10%		WB	25.7	25.4	27.7	31.9	38.5	45.6	47.9	48.1	42.3	38.2	32.3	27.2	(33)	
		MCD B	30.0	30.3	31.5	34.1	41.5	49.8	51.9	52.2	45.5	41.2	35.0	31.8	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.6	8.6	8.1	7.2	6.7	7.4	7.7	7.5	7.2	7.3	7.5	8.5	(35)
MCDBR			11.0	10.6	9.0	7.8	8.5	9.1	9.8	9.5	9.3	8.9	10.4	10.8	(36)	
MCWBR			7.0	6.4	6.1	6.1	7.5	9.4	9.2	8.5	8.4	7.5	6.2	6.5	(37)	
5% WB		MCDBR	10.0	9.9	7.9	6.7	7.4	8.3	8.8	8.3	8.2	7.0	7.2	9.3	(38)	
		MCWBR	7.9	7.8	6.4	5.8	7.0	9.2	9.2	8.3	8.1	6.8	5.9	7.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.225	0.244	0.275	0.305	0.311	0.318	0.315	0.311	0.295	0.281	0.255	0.227	(40)	
taud		2.519	2.503	2.489	2.452	2.458	2.453	2.459	2.486	2.527	2.571	2.597	2.574	(41)		
Ebn at Noon		292	304	306	303	303	300	299	297	295	285	277	280	(42)		
Edh at Noon		19	24	29	33	34	35	34	31	28	23	18	16	(43)		
(44)	All-Sky Solar Radiation	RadAvg	444	710	1077	1360	1625	1828	1855	1619	1188	777	445	376	(44)	
(45)		RadStd	56	103	137	171	181	131	127	160	139	92	77	52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	-2.86	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (78 neighbors)	+0.86	N/A	N/A	+1.35	+0.79	+0.61	N/A	-227	+167	+104	

Nomenclature: See separate page