

SLOVENJ GRADEC, Slovenia

WMO: 140210

Lat: 46.4896N

Lon: 15.1112E

Elev: 1457

StdP: 13.94

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.3	13.6	2.7	6.6	11.8	7.9	8.7	16.1	15.1	34.9	13.3	34.3	1.1	130	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	86.7	69.0	83.3	68.1	80.4	66.5	70.8	82.7	69.1	80.3	67.5	78.2	5.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.7	103.8	76.9	65.0	97.5	74.8	63.5	92.5	73.0	35.6	82.9	34.1	80.7	32.8	78.5	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.6	11.0	9.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB													
			WB	0.4	72.2	6.4	4.3	-4.2	75.3	-7.9	77.8	-11.5	80.2	-16.1	83.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.4	29.6	33.7	40.3	49.8	57.3	65.4	67.8	65.9	58.2	51.7	40.8	31.6		
	DBStd	14.83	7.42	6.69	7.65	6.83	6.29	6.16	5.78	5.66	5.71	5.75	7.47	6.63		
	HDD50	2407	632	458	306	87	12	1	0	0	5	51	286	569		
	HDD65	6004	1096	878	767	457	248	71	39	58	215	414	727	1034		
	CDD50	2191	1	0	4	80	238	462	551	493	251	102	9	0		
	CDD65	313	0	0	0	0	9	82	125	86	11	0	0	0		
	CDH74	2825	0	0	0	13	89	724	1085	832	81	1	0	0		
	CDH80	755	0	0	0	0	5	153	325	265	7	0	0	0		
(14) Wind	WSAvg	3.6	3.3	3.9	4.3	4.5	4.2	4.0	3.6	3.2	3.1	3.4	3.4	2.9		
(15) Precipitation	PrecAvg	47.8	2.0	2.2	2.7	3.3	4.0	5.4	5.3	5.4	5.2	4.9	4.4	3.0		
	PrecMax	60.7	5.6	7.0	5.4	6.2	6.9	8.0	9.8	9.8	11.2	12.0	9.6	7.8		
	PrecMin	35.5	0.2	0.0	0.3	0.3	1.7	2.5	2.1	1.3	1.9	0.0	0.4	0.2		
	PrecStd	5.1	1.3	1.8	1.5	1.4	1.5	1.7	1.9	2.1	2.3	2.6	2.3	1.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.0	55.7	66.5	75.8	80.0	87.2	90.5	90.9	80.3	72.3	61.7	53.6		
		MCWB	47.6	44.9	52.0	57.8	63.2	68.3	69.6	69.0	66.2	61.1	53.7	48.9		
	2%	DB	47.0	50.1	59.9	69.7	76.2	83.8	87.0	86.6	75.8	67.7	58.1	47.9		
		MCWB	42.5	43.7	49.2	54.6	61.2	67.2	69.3	69.2	64.5	58.7	52.9	44.0		
	5%	DB	42.5	47.1	55.8	66.4	72.9	81.3	83.6	81.9	72.0	64.7	55.1	43.1		
		MCWB	39.3	41.6	47.2	54.2	59.6	66.3	68.9	68.2	62.4	57.5	51.5	40.2		
	10%	DB	39.1	43.8	52.5	62.3	69.6	78.2	80.3	78.1	68.4	61.8	51.8	40.0		
		MCWB	36.5	39.2	45.6	52.3	58.2	64.7	67.1	66.2	60.0	56.1	49.2	37.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.1	46.6	52.9	59.3	65.7	71.5	73.6	72.6	67.3	62.2	55.8	49.8		
		MCDB	52.4	51.9	64.1	71.0	75.8	83.1	85.1	85.6	77.7	70.2	58.5	52.5		
	2%	WB	43.1	44.5	50.3	56.9	62.6	68.9	71.4	70.3	65.4	59.9	54.0	45.0		
		MCDB	46.6	49.5	57.9	67.2	73.7	80.9	83.0	82.0	74.6	65.8	57.6	47.8		
	5%	WB	40.0	42.1	48.3	54.8	60.8	67.1	69.6	68.6	63.3	58.4	51.6	40.8		
		MCDB	42.4	46.8	54.8	64.2	70.9	78.7	80.8	79.3	70.5	63.6	54.6	42.7		
	10%	WB	36.8	39.6	46.3	52.9	59.2	65.6	67.9	66.8	61.1	56.8	49.0	38.2		
		MCDB	38.7	43.4	51.9	60.7	67.7	76.9	78.9	76.2	66.4	61.4	51.9	39.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.5	14.5	18.2	18.1	18.4	19.7	19.6	19.5	17.8	17.1	11.9	12.4		
		MCDBR	17.4	22.0	25.4	25.8	24.6	24.7	25.2	27.3	23.0	21.9	19.4	17.7		
	5% WB	MCWBR	12.6	15.0	15.5	13.0	11.4	10.8	10.8	13.1	12.3	13.5	13.5	13.3		
		MCWBR	16.0	20.5	22.5	22.4	21.9	23.8	23.9	24.9	22.1	19.5	16.2	14.9		
(40) Clear-Sky Solar Irradiance	taub		0.305	0.330	0.370	0.417	0.417	0.423	0.424	0.422	0.398	0.373	0.339	0.305		
	taud		2.425	2.358	2.302	2.206	2.253	2.275	2.274	2.292	2.334	2.385	2.435	2.476		
	Ebn at Noon		251	266	269	266	270	268	266	261	257	246	234	238		
	Edh at Noon		22	29	35	43	42	41	41	39	34	28	22	19		
(44) All-Sky Solar Radiation	RadAvg		405	668	1036	1346	1639	1833	1837	1614	1150	756	415	333		
	RadStd		58	101	135	153	157	122	124	174	151	86	66	50		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (82 neighbors)		+0.95	N/A	N/A	+1.71	+0.90	+0.70	-176	-263	+176	+115

Nomenclature: See separate page