

SLOVENJ GRADEC, Slovenia

WMO: 140210

Lat: 46.4896N

Lon: 15.1112E

Elev: 444

StdP: 96.10

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -13.2	(c) -10.2	(d) -16.3	(e) 0.9	(f) -11.2	(g) -13.4	(h) 1.2	(i) -8.8	(j) 6.7	(k) 1.6	(l) 5.9	(m) 1.3	(n) 0.5	(o) 130	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.9	(c) 30.4	(d) 20.6	(e) 28.5	(f) 20.0	(g) 26.9	(h) 19.2	(i) 21.6	(j) 28.2	(k) 20.6	(l) 26.8	(m) 19.7	(n) 25.7	(o) 2.5	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 19.3	(b) 14.8	(c) 24.9	(d) 18.3	(e) 13.9	(f) 23.8	(g) 17.5	(h) 13.2	(i) 22.8	(j) 65.0	(k) 28.3	(l) 61.4	(m) 27.0	(n) 58.3	(o) 25.9	(p) 24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 5.6	(b) 4.9	(c) 4.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 5.6	(b) 4.9	(c) 4.3	(e) -17.5	(f) 22.4	(g) 3.5	(h) 2.4	(i) -20.1	(j) 24.1	(k) -22.2	(l) 25.4	(m) -24.1	(n) 26.8	(o) -26.7	(p) 28.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-1.3	0.9	4.6	9.9	14.1	18.5	19.9	18.8	14.6	10.9	4.9	-0.2
	DBStd	8.24	4.12	3.72	4.25	3.79	3.49	3.42	3.21	3.15	3.17	3.19	4.15	3.68
	HDD10.0	1337	351	254	170	48	7	1	0	0	3	28	159	316
	HDD18.3	3336	609	488	426	254	138	39	22	32	119	230	404	574
	CDD10.0	1217	1	0	2	44	132	257	306	274	139	57	5	0
	CDD18.3	174	0	0	0	0	5	46	69	48	6	0	0	0
	CDH23.3	1569	0	0	0	7	49	402	603	462	45	1	0	0
	CDH26.7	419	0	0	0	0	3	85	181	147	4	0	0	0
Wind	WSAvg	1.6	1.5	1.7	1.9	2.0	1.9	1.8	1.6	1.4	1.4	1.5	1.5	1.3
Precipitation	PrecAvg	1214	51	56	69	83	102	137	134	137	133	125	113	77
	PrecMax	1543	142	177	137	157	175	202	248	250	284	304	245	198
	PrecMin	901	6	0	8	7	44	63	53	34	48	0	10	6
	PrecStd	129	33	45	39	35	39	43	49	54	59	66	59	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	13.2	19.2	24.4	26.7	30.7	32.5	32.7	26.8	22.4	16.5	12.0
		MCWB	8.7	7.1	11.1	14.4	17.3	20.2	20.9	20.6	19.0	16.2	12.0	9.4
	2%	DB	8.3	10.1	15.5	20.9	24.5	28.8	30.5	30.3	24.3	19.8	14.5	8.8
		MCWB	5.9	6.5	9.6	12.6	16.2	19.6	20.7	20.7	18.1	14.8	11.6	6.7
	5%	DB	5.8	8.4	13.2	19.1	22.7	27.4	28.6	27.7	22.2	18.2	12.8	6.2
		MCWB	4.1	5.3	8.4	12.3	15.3	19.1	20.5	20.1	16.9	14.2	10.8	4.6
	10%	DB	3.9	6.5	11.4	16.9	20.9	25.7	26.8	25.6	20.2	16.5	11.0	4.4
		MCWB	2.5	4.0	7.6	11.3	14.6	18.2	19.5	19.0	15.6	13.4	9.5	3.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	8.1	11.6	15.2	18.7	21.9	23.1	22.6	19.6	16.8	13.2	9.9
		MCDB	11.3	11.1	17.8	21.7	24.4	28.4	29.5	29.8	25.4	21.2	14.7	11.4
	2%	WB	6.2	6.9	10.2	13.9	17.0	20.5	21.9	21.3	18.6	15.5	12.2	7.2
		MCDB	8.1	9.7	14.4	19.5	23.2	27.2	28.3	27.8	23.6	18.8	14.2	8.8
	5%	WB	4.5	5.6	9.1	12.7	16.0	19.5	20.9	20.3	17.4	14.7	10.9	4.9
		MCDB	5.8	8.2	12.7	17.9	21.6	26.0	27.1	26.3	21.4	17.6	12.5	5.9
	10%	WB	2.6	4.2	7.9	11.6	15.1	18.7	19.9	19.3	16.2	13.8	9.4	3.5
		MCDB	3.7	6.3	11.1	15.9	19.9	24.9	26.0	24.6	19.1	16.3	11.1	4.3
Mean Daily Temperature Range	5% DB	MDBR	7.5	8.0	10.1	10.1	10.2	11.0	10.9	10.9	9.9	9.5	6.6	6.9
		MCDBR	9.6	12.2	14.1	14.3	13.7	13.7	14.0	15.2	12.8	12.1	10.8	9.8
		MCWBR	7.0	8.3	8.6	7.2	6.4	6.0	6.0	7.3	6.8	7.5	7.5	7.4
	5% WB	MCDBR	8.9	11.4	12.5	12.5	12.2	13.2	13.3	13.9	12.3	10.8	9.0	8.3
		MCWBR	6.7	8.1	8.0	6.4	6.0	6.1	6.1	7.0	6.7	6.9	6.6	6.5
Clear-Sky Solar Irradiance	taub	0.305	0.330	0.370	0.417	0.417	0.423	0.424	0.422	0.398	0.373	0.339	0.305	
	taud	2.425	2.358	2.302	2.206	2.253	2.275	2.274	2.292	2.334	2.385	2.435	2.476	
	Ebn at Noon	791	837	849	838	851	845	839	824	811	775	739	751	
	Edh at Noon	69	91	111	134	132	130	129	122	107	88	70	60	
All-Sky Solar Radiation	RadAvg	1.28	2.10	3.27	4.24	5.17	5.78	5.79	5.09	3.62	2.38	1.31	1.05	
	RadStd	0.18	0.32	0.43	0.48	0.49	0.39	0.39	0.55	0.47	0.27	0.21	0.16	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (82 neighbors)	+0.53	N/A	N/A	N/A	+0.95	+0.50	+0.39	-98	-146	+98	+64

Nomenclature: See separate page