

LISCA, Slovenia

WMO: 140240

Lat: 46.0678N

Lon: 15.2850E

Elev: 941

StdP: 90.52

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.7	-9.6	-17.5	0.9	-7.8	-14.6	1.2	-4.5	13.2	1.9	11.8	2.2	3.0	70	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	26.5	18.7	24.8	18.2	23.3	17.5	20.0	24.8	19.0	23.6	18.1	22.5	2.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.3	14.8	23.0	17.2	13.8	21.8	16.3	13.0	20.8	61.7	24.7	58.1	23.7	55.1	22.6	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.4	9.1	8.0	-13.8	28.7	2.5	2.4	-15.6	30.5	-17.1	31.9	-18.5	33.3	-20.3	35.0		
			-14.2	21.6	2.4	1.6	-15.9	22.7	-17.3	23.7	-18.7	24.6	-20.5	25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	-1.2	-0.2	3.1	7.8	12.2	15.9	18.1	17.6	12.9	8.8	4.0	-0.2
	DBStd	8.04	4.83	4.92	4.92	4.34	3.91	4.04	3.56	3.81	3.47	4.28	4.35	4.63
	HDD10.0	1554	348	287	217	90	22	4	0	1	12	75	183	316
	HDD18.3	3777	606	519	472	316	193	94	49	60	167	297	430	573
	CDD10.0	922	0	1	4	24	89	179	251	237	97	36	3	0
	CDD18.3	105	0	0	0	0	3	21	41	38	2	0	0	0
	CDH23.3	347	0	0	0	0	3	55	138	149	1	0	0	0
	CDH26.7	47	0	0	0	0	0	3	17	27	0	0	0	0
Wind	WSAvg	3.5	4.2	3.8	3.8	3.5	3.3	2.9	2.8	2.8	3.1	3.7	4.2	4.2
Precipitation	PrecAvg	1091	49	54	64	75	99	116	108	115	128	119	101	76
	PrecMax	1426	100	149	137	136	177	210	195	255	283	293	232	140
	PrecMin	735	7	3	6	7	35	40	37	19	46	5	3	14
	PrecStd	146	30	38	39	32	39	37	44	59	63	67	51	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	14.0	16.3	20.3	23.5	26.8	28.6	29.2	22.7	19.0	14.1	10.7
		MCWB	3.8	5.3	8.7	11.9	16.4	19.0	19.3	19.1	17.5	13.9	10.1	4.4
	2%	DB	8.4	10.6	13.4	17.4	21.2	24.9	26.5	26.7	20.8	16.8	11.9	8.5
		MCWB	4.2	4.3	7.0	10.3	14.8	18.5	19.1	18.4	16.3	12.9	9.5	5.5
	5%	DB	6.6	7.7	11.2	15.4	19.6	23.3	24.6	24.7	19.2	15.3	10.6	6.9
		MCWB	4.3	3.3	6.1	9.3	14.0	17.8	18.3	17.9	15.4	12.3	8.9	4.9
	10%	DB	5.1	5.7	9.1	13.6	17.8	21.7	23.1	23.0	17.6	14.0	9.5	5.6
		MCWB	3.4	3.0	5.2	8.4	12.9	16.7	17.5	17.2	14.3	11.7	8.2	3.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	6.4	9.3	12.7	17.7	20.7	21.7	21.2	18.4	15.3	11.5	7.9
		MCDB	7.8	10.6	14.3	17.9	22.1	25.0	25.7	25.8	21.7	17.9	12.6	9.0
	2%	WB	5.7	5.2	7.8	10.8	15.9	19.2	20.1	19.7	17.0	14.0	10.2	6.6
		MCDB	6.7	8.2	11.8	15.7	20.2	23.6	25.0	24.7	19.9	15.7	11.2	7.4
	5%	WB	4.6	4.4	6.9	9.8	14.6	18.2	19.0	18.6	15.8	13.1	9.2	5.4
		MCDB	5.8	6.8	9.7	14.2	18.4	22.6	23.6	23.3	18.6	14.5	10.2	6.3
	10%	WB	3.6	3.5	6.0	9.0	13.4	17.1	18.0	17.7	14.8	12.2	8.4	4.3
		MCDB	5.0	5.5	8.6	12.7	17.1	21.3	22.5	22.0	17.2	13.6	9.4	5.2
Mean Daily Temperature Range	5% DB	MDBR	4.0	4.5	5.8	6.5	6.5	6.8	6.9	6.5	5.5	4.8	4.0	4.0
		MCDBR	5.2	6.6	8.3	8.6	8.1	8.1	8.2	8.2	6.8	6.1	4.7	5.2
		MCWBR	3.2	3.9	5.0	4.9	5.2	5.5	5.2	5.0	4.7	3.9	3.2	3.6
	5% WB	MCDBR	4.1	5.5	7.2	7.8	7.7	7.7	7.8	7.6	6.5	5.4	4.1	4.0
		MCWBR	3.1	3.8	4.6	4.6	5.3	5.6	5.4	5.2	4.7	3.8	3.2	3.4
Clear-Sky Solar Irradiance	taub	0.288	0.309	0.341	0.380	0.376	0.382	0.382	0.380	0.364	0.344	0.316	0.288	
	taud	2.450	2.406	2.370	2.285	2.327	2.340	2.338	2.355	2.381	2.437	2.478	2.501	
	Ebn at Noon	823	870	885	876	890	884	878	867	849	816	778	784	
	Edh at Noon	68	87	104	124	123	122	121	114	102	84	67	59	
All-Sky Solar Radiation	RadAvg	1.25	2.05	3.22	4.25	5.24	5.93	5.98	5.23	3.67	2.37	1.31	1.05	
	RadStd	0.19	0.34	0.45	0.51	0.52	0.40	0.39	0.58	0.48	0.28	0.20	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (62 neighbors)	+0.47	N/A	N/A	+0.88	+0.49	+0.38	N/A	-123	+92	+60

Nomenclature: See separate page