

MARIBOR SLIVNICA, Slovenia

WMO: 140260

Lat: 46.4797N

Lon: 15.6819E

Elev: 876

StdP: 14.24

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.3	16.0	5.4	7.5	14.4	10.8	9.8	19.7	21.5	45.7	19.0	44.3	2.5	0	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.9	89.3	69.8	86.1	68.9	83.1	67.4	71.8	84.3	70.1	82.5	68.7	80.6	7.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	105.3	78.1	66.0	98.9	75.8	64.5	93.7	74.1	36.0	84.3	34.5	82.9	33.3	80.9	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	15.7	13.3	4.2	93.1	6.5	3.7	-0.4	95.7	-4.2	97.9	-7.8	100.0	-12.5	102.6
			3.6	74.8	6.3	2.4	-1.0	76.5	-4.7	77.9	-8.2	79.3	-12.8	81.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	32.2	35.5	43.0	51.8	59.9	66.7	69.6	68.6	60.4	52.0	43.1	33.7	(6)
	DBStd	14.91	8.21	8.52	7.68	6.59	5.94	6.08	5.21	5.47	5.82	7.04	7.85	7.73	(7)
	HDD50	2056	553	408	235	57	3	0	0	0	2	62	230	506	(8)
	HDD65	5389	1017	827	682	397	177	53	19	26	162	403	656	970	(9)
	CDD50	2590	1	1	18	111	311	501	606	578	312	125	24	2	(10)
	CDD65	448	0	0	0	1	20	104	160	139	23	1	0	0	(11)
	CDH74	4569	0	0	0	28	265	1041	1630	1402	193	10	0	0	(12)
	CDH80	1424	0	0	0	1	39	313	550	496	25	0	0	0	(13)
(14) Wind	WSAvg	4.9	4.5	5.3	5.9	5.8	5.6	4.8	4.5	4.0	4.3	4.4	4.7	4.4	(14)
(15) Precipitation	PrecAvg	42.4	1.9	2.0	2.5	3.0	4.1	4.7	4.4	4.6	4.7	4.1	3.8	2.7	(15)
	PrecMax	55.5	4.4	6.1	5.2	6.6	7.0	7.8	8.1	8.3	10.0	10.5	8.8	5.3	(16)
	PrecMin	31.1	0.3	0.1	0.6	0.2	1.7	1.9	1.8	0.7	2.4	0.0	0.5	0.4	(17)
	PrecStd	4.8	1.0	1.5	1.3	1.3	1.6	1.5	1.6	2.1	2.1	2.3	2.0	1.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.7	62.2	69.3	78.4	84.2	91.1	93.1	93.6	82.8	75.4	66.2	57.4	(19)
		MCWB	48.5	49.4	53.0	59.9	64.8	69.8	71.4	70.0	67.3	62.8	56.7	51.5	(20)
	2%	DB	52.0	55.8	64.6	72.9	80.3	87.4	89.1	89.3	79.0	71.3	62.2	53.2	(21)
		MCWB	46.3	46.3	51.2	56.2	63.5	69.0	70.2	69.5	65.9	61.2	54.7	47.9	(22)
	5%	DB	48.4	52.4	60.8	69.2	76.9	83.9	85.9	85.7	75.6	67.8	58.1	48.8	(23)
		MCWB	43.6	45.0	49.8	55.2	61.9	68.0	69.1	68.8	64.2	59.3	52.7	44.6	(24)
	10%	DB	44.6	48.6	56.8	65.5	73.4	80.3	82.7	82.0	72.0	64.3	55.2	44.7	(25)
		MCWB	40.7	42.6	47.9	53.3	60.3	66.1	67.5	67.5	62.1	57.4	50.9	41.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.6	50.1	54.6	60.8	67.3	73.2	74.5	73.6	69.2	64.3	57.5	52.2	(27)
		MCDB	54.6	60.2	65.7	75.3	79.5	85.7	87.5	85.9	79.9	73.7	63.8	56.9	(28)
	2%	WB	46.6	47.5	52.2	57.9	65.0	70.5	71.9	71.3	67.0	61.9	55.4	48.5	(29)
		MCDB	51.3	54.7	62.3	69.5	76.8	82.9	84.2	84.5	77.1	69.2	60.6	52.7	(30)
	5%	WB	43.9	45.5	50.3	56.0	63.0	68.7	70.1	69.8	65.2	59.9	53.2	44.9	(31)
		MCDB	47.7	51.5	59.1	66.1	73.9	81.3	82.4	82.2	74.1	66.3	57.8	48.1	(32)
	10%	WB	41.1	43.1	48.5	54.3	61.1	67.1	68.6	68.2	63.2	58.0	51.0	41.7	(33)
		MCDB	44.4	48.0	56.1	63.6	71.4	78.6	80.4	79.6	70.5	63.4	54.8	44.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	16.4	18.8	19.7	19.8	20.0	20.9	20.8	18.2	17.2	13.2	12.6	(35)
		MCDBR	19.4	23.3	26.4	27.9	26.3	26.0	26.6	27.4	23.0	22.5	18.9	18.6	(36)
		MCWBR	13.4	14.7	15.1	13.8	12.1	10.9	10.8	10.9	11.5	13.2	12.5	13.6	(37)
	5% WB	MCDBR	17.7	21.6	24.1	23.6	23.7	24.0	24.1	24.4	21.6	20.0	16.8	16.9	(38)
		MCWBR	12.7	14.2	14.3	12.3	11.6	10.8	10.7	10.9	11.3	12.2	11.5	13.0	(39)
(40) Clear-Sky Solar Irradiance	taub		0.320	0.346	0.385	0.433	0.428	0.434	0.436	0.436	0.413	0.386	0.352	0.319	(40)
	taud		2.386	2.322	2.257	2.148	2.213	2.241	2.236	2.245	2.279	2.330	2.378	2.429	(41)
	Ebn at Noon		243	259	264	261	266	265	263	257	252	240	227	230	(42)
	Edh at Noon		23	30	37	45	44	43	43	41	36	30	23	20	(43)
(44) All-Sky Solar Radiation	RadAvg		401	661	1031	1361	1660	1850	1850	1628	1156	761	416	325	(44)
	RadStd		57	100	133	152	156	126	125	174	150	86	63	49	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.06	N/A	N/A	N/A	+1.30	+1.17	-194	-310	+214	+112	(46)
(47)	Regional (76 neighbors)	+0.92	N/A	N/A	+1.66	+0.92	+0.76	-164	-245	+171	+110	(47)

Nomenclature: See separate page