

PORTOROZ SECOVLJE, Slovenia

WMO: 141050

Lat: 45.4753N

Lon: 13.6160E

Elev: 7

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.2	28.2	6.7	7.8	32.1	12.5	10.4	34.9	21.2	44.7	19.0	44.6	8.1	120	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	91.0	72.4	88.3	71.6	86.1	70.7	75.1	86.6	73.6	85.0	72.1	83.6	8.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.4	115.9	83.5	69.6	108.8	81.2	68.0	102.9	79.2	38.5	86.5	37.1	85.1	35.8	83.8	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	15.5	13.5	20.5	94.6	4.0	2.6	17.7	96.4	15.3	98.0	13.1	99.4	10.2	101.3
			18.0	78.3	3.7	2.3	15.3	80.0	13.1	81.3	11.0	82.6	8.3	84.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.5	41.6	42.6	48.4	55.3	63.0	70.4	74.2	73.9	66.3	58.9	51.1	43.6	(6)
	DBStd	12.77	5.56	5.52	5.56	5.02	4.71	4.99	4.22	4.62	5.08	5.72	6.57	5.86	(7)
	HDD50	869	267	214	95	13	0	0	0	0	0	6	65	209	(8)
	HDD65	3596	726	628	516	292	95	11	1	2	45	201	417	662	(9)
	CDD50	3611	6	5	44	172	402	611	750	740	489	281	99	12	(10)
	CDD65	863	0	0	0	0	32	172	286	278	84	11	0	0	(11)
	CDH74	8490	0	0	0	16	307	1690	3021	2836	601	19	0	0	(12)
	CDH80	2859	0	0	0	0	42	511	1121	1085	100	0	0	0	(13)
(14) Wind	WSAvg	6.4	5.8	6.4	6.9	6.7	6.4	6.5	6.7	6.6	6.5	6.3	6.2	5.9	(14)
(15) Precipitation	PrecAvg	38.0	2.1	2.4	2.4	2.6	3.1	3.1	2.4	2.9	4.2	4.8	4.9	3.0	(15)
	PrecMax	57.2	5.8	8.0	7.5	5.4	8.0	7.3	8.5	10.1	9.3	11.6	11.3	7.3	(16)
	PrecMin	24.4	0.0	0.1	0.0	0.0	0.4	0.4	0.5	0.4	0.7	0.9	0.4	0.0	(17)
	PrecStd	8.1	1.5	2.0	1.8	1.4	1.9	1.5	2.0	2.0	2.5	2.6	2.8	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.2	60.1	67.4	76.0	84.4	91.5	93.4	94.6	86.1	76.4	68.2	61.1	(19)
		MCWB	54.9	50.8	54.3	59.5	68.7	73.0	72.5	72.5	69.3	65.5	61.1	56.6	(20)
	2%	DB	55.8	57.0	64.0	72.0	80.4	88.2	90.3	91.3	82.7	73.5	65.7	57.4	(21)
		MCWB	51.7	50.1	52.7	58.3	66.4	71.7	71.9	72.7	68.4	64.1	59.5	53.3	(22)
	5%	DB	52.8	54.7	61.0	69.3	77.3	85.7	88.2	88.6	80.3	71.3	63.0	54.7	(23)
		MCWB	48.7	48.7	51.8	57.2	63.9	70.3	71.5	71.8	67.8	63.8	58.1	50.6	(24)
	10%	DB	50.2	52.2	58.7	66.2	74.8	82.7	86.1	86.0	77.3	68.4	60.9	52.2	(25)
		MCWB	46.6	46.8	50.8	55.9	62.7	69.0	70.9	70.6	66.1	61.9	56.6	48.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.4	54.1	56.7	62.6	70.4	76.1	77.0	77.3	72.7	68.2	62.6	57.1	(27)
		MCDB	58.7	57.3	62.4	72.7	81.1	87.4	88.3	88.0	81.5	73.3	65.9	60.5	(28)
	2%	WB	52.7	51.8	54.9	60.2	67.5	73.6	75.0	75.2	70.7	66.5	60.5	54.3	(29)
		MCDB	55.7	55.4	60.8	68.8	78.1	85.4	86.6	86.6	79.5	71.5	64.3	57.2	(30)
	5%	WB	50.0	50.0	53.5	58.4	65.4	71.7	73.4	73.6	69.2	65.0	59.0	51.9	(31)
		MCDB	51.7	53.2	59.2	66.3	74.9	83.2	84.8	85.2	77.7	69.8	62.6	54.2	(32)
	10%	WB	47.8	48.1	52.0	56.8	63.6	69.8	72.0	72.0	67.5	63.3	57.2	49.9	(33)
		MCDB	49.4	51.4	57.1	64.0	72.5	80.8	83.7	83.7	75.3	67.5	60.5	51.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	15.1	17.0	17.8	18.7	19.8	20.8	20.8	18.6	16.4	13.6	13.4	(35)
		MCDBR	14.7	17.6	20.1	23.1	23.1	23.5	23.5	24.1	21.5	17.5	13.3	14.4	(36)
	5% WB	MCWBR	10.8	12.2	12.5	12.6	12.2	11.6	11.4	11.9	11.0	10.4	9.2	10.5	(37)
		MCWBR	10.6	14.1	16.5	19.8	21.1	22.3	22.0	22.0	18.5	14.3	11.1	11.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.348	0.371	0.415	0.455	0.459	0.470	0.459	0.451	0.436	0.417	0.377	0.343	(40)
		taud	2.407	2.325	2.211	2.126	2.170	2.189	2.226	2.263	2.269	2.283	2.338	2.430	(41)
	Ebn at Noon		237	252	256	255	259	256	257	254	246	232	221	226	(42)
		Edh at Noon	24	31	39	46	46	45	43	40	37	32	25	21	(43)
(44) All-Sky Solar Radiation	RadAvg		408	684	1091	1482	1840	2087	2115	1810	1295	797	449	359	(44)
	RadStd		70	124	146	161	175	112	107	147	108	86	60	50	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-185	+155	+113	(46)
(47)	Regional (44 neighbors)	+0.83	N/A	N/A	N/A	+0.81	N/A	N/A	-214	+176	+117	(47)

Nomenclature: See separate page