

PORTOROZ SECOVLJE, Slovenia

WMO: 141050

Lat: 45.4753N

Lon: 13.6160E

Elev: 2

StdP: 101.30

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.8	-2.1	-14.0	1.1	0.0	-10.8	1.5	1.6	9.5	7.1	8.5	7.0	3.6	120	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	32.8	22.5	31.3	22.0	30.1	21.5	24.0	30.4	23.1	29.5	22.3	28.7	3.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	16.6	28.6	20.9	15.5	27.4	20.0	14.7	26.2	71.8	30.3	68.4	29.5	65.3	28.8	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	6.9	6.0	-6.4	34.8	2.2	1.4	-8.0	35.8	-9.3	36.6	-10.5	37.5	-12.1	38.5		
(5)			-7.8	25.7	2.1	1.3	-9.3	26.6	-10.5	27.4	-11.7	28.1	-13.2	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	5.3	5.9	9.1	12.9	17.2	21.3	23.4	23.3	19.1	14.9	10.6	6.5		
	DBStd	7.10	3.09	3.07	3.09	2.79	2.62	2.77	2.35	2.57	2.82	3.18	3.65	3.26		
	HDD10.0	483	148	119	53	7	0	0	0	0	0	3	36	116		
	HDD18.3	1998	403	349	287	162	53	6	1	1	25	112	232	368		
	CDD10.0	2006	3	3	24	96	223	339	417	411	272	156	55	7		
	CDD18.3	479	0	0	0	0	18	96	159	154	47	6	0	0		
	CDH23.3	4717	0	0	0	9	171	939	1678	1576	334	11	0	0		
	CDH26.7	1588	0	0	0	0	23	284	623	603	56	0	0	0		
(14) Wind	WSAvg	2.9	2.6	2.9	3.1	3.0	2.9	2.9	3.0	2.9	2.9	2.8	2.8	2.7		
(15) Precipitation	PrecAvg	964	54	61	61	66	78	80	62	73	107	121	124	75		
	PrecMax	1453	147	204	191	137	204	185	217	257	236	295	287	185		
	PrecMin	620	0	3	0	0	10	10	12	9	18	24	9	0		
	PrecStd	207	39	52	45	35	47	39	50	51	63	67	70	51		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.1	15.6	19.7	24.4	29.1	33.0	34.1	34.8	30.0	24.7	20.1	16.1		
		MCWB	12.7	10.5	12.4	15.3	20.4	22.8	22.5	22.5	20.7	18.6	16.2	13.6		
	2%	DB	13.2	13.9	17.8	22.2	26.9	31.2	32.4	33.0	28.2	23.1	18.7	14.1		
		MCWB	10.9	10.0	11.5	14.6	19.1	22.0	22.2	22.6	20.2	17.8	15.3	11.8		
	5%	DB	11.5	12.6	16.1	20.7	25.2	29.9	31.2	31.4	26.9	21.9	17.2	12.6		
		MCWB	9.3	9.3	11.0	14.0	17.7	21.3	22.0	22.1	19.9	17.6	14.5	10.3		
	10%	DB	10.1	11.2	14.8	19.0	23.8	28.2	30.0	30.0	25.2	20.2	16.1	11.2		
		MCWB	8.1	8.2	10.4	13.3	17.0	20.5	21.6	21.4	18.9	16.6	13.7	9.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	12.3	13.7	17.0	21.3	24.5	25.0	25.1	22.6	20.1	17.0	14.0		
		MCDB	14.8	14.1	16.9	22.6	27.3	30.8	31.3	31.1	27.5	22.9	18.8	15.8		
	2%	WB	11.5	11.0	12.7	15.6	19.7	23.1	23.9	24.0	21.5	19.2	15.8	12.4		
		MCDB	13.2	13.0	16.0	20.4	25.6	29.6	30.4	30.3	26.4	22.0	18.0	14.0		
	5%	WB	10.0	10.0	11.9	14.7	18.5	22.0	23.0	23.1	20.7	18.3	15.0	11.1		
		MCDB	10.9	11.8	15.1	19.1	23.8	28.5	29.4	29.6	25.4	21.0	17.0	12.3		
	10%	WB	8.8	9.0	11.1	13.8	17.6	21.0	22.2	22.2	19.7	17.4	14.0	9.9		
		MCDB	9.7	10.8	14.0	17.8	22.5	27.1	28.7	28.7	24.1	19.7	15.9	10.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	8.4	9.5	9.9	10.4	11.0	11.5	11.6	10.3	9.1	7.6	7.4		
		MCDBR	8.1	9.8	11.2	12.8	12.8	13.0	13.1	13.4	11.9	9.7	7.4	8.0		
	5% WB	MCWBR	6.0	6.8	7.0	7.0	6.8	6.5	6.4	6.6	6.1	5.8	5.1	5.8		
		MCWBR	5.9	7.8	9.2	11.0	11.7	12.4	12.2	12.2	10.3	8.0	6.2	6.2		
(40) Clear-Sky Solar Irradiance	taub	taub	0.348	0.371	0.415	0.455	0.459	0.470	0.459	0.451	0.436	0.417	0.377	0.343		
		taud	2.407	2.325	2.211	2.126	2.170	2.189	2.226	2.263	2.269	2.283	2.338	2.430		
	Ebn at Noon	Ebn at Noon	747	795	806	805	815	806	810	801	777	730	696	711		
		Edh at Noon	75	97	124	146	145	143	136	126	116	100	79	67		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.29	2.15	3.44	4.67	5.80	6.58	6.67	5.71	4.08	2.51	1.42	1.13		
	RadStd	RadStd	0.22	0.39	0.46	0.51	0.55	0.35	0.34	0.46	0.34	0.27	0.19	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	+0.40	N/A	N/A	N/A	N/A	N/A	-103	+86	+63	
(47)	Regional (44 neighbors)	+0.46	N/A	N/A	N/A	+0.45	N/A	-119	+98	+65	

Nomenclature: See separate page