

NOVA GORICA, Slovenia

WMO: 141060

Lat: 45.8954N

Lon: 13.6241E

Elev: 56

StdP: 100.65

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.5	-4.0	-13.8	1.1	0.6	-10.6	1.5	2.0	8.7	3.9	7.5	4.2	1.6	90	0.420

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	33.5	21.7	31.9	21.2	30.4	20.7	23.0	30.6	22.2	29.5	21.5	28.5	2.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.7	15.5	25.6	19.9	14.7	24.8	19.2	14.0	24.1	68.3	30.7	65.1	29.5	62.5	28.6	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.5	6.4	5.5	DB	-7.8	35.9	2.1	1.7	-9.3	37.1	-10.6	38.1	-11.7	39.0	-13.3	40.3	
			WB	-8.5	24.5	2.1	1.0	-10.0	25.2	-11.2	25.8	-12.4	26.3	-14.0	27.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	4.0	5.2	8.6	12.7	17.0	21.3	23.3	22.8	18.1	14.0	9.0	4.7
	DBStd	7.47	3.11	2.92	2.92	2.80	2.76	2.97	2.52	2.81	2.81	3.31	3.89	3.30
	HDD10.0	629	189	137	59	8	0	0	0	0	7	63	166	
	HDD18.3	2233	446	369	301	171	59	8	1	2	38	138	279	422
	CDD10.0	1883	2	1	17	88	217	339	411	398	244	129	34	3
	CDD18.3	444	0	0	0	1	17	97	154	142	32	2	0	0
	CDH23.3	4512	0	0	1	14	205	1009	1591	1432	254	6	0	0
	CDH26.7	1712	0	0	0	0	36	361	659	601	56	0	0	0
Wind	WSAvg	2.1	1.9	2.4	2.4	2.2	2.0	2.0	2.0	2.0	2.0	2.0	2.0	1.9
Precipitation	PrecAvg	1473	96	86	95	109	119	118	108	108	156	169	184	126
	PrecMax	2059	327	274	274	263	278	244	215	268	358	383	540	309
	PrecMin	1054	8	6	4	10	22	24	37	16	50	26	27	4
	PrecStd	267	70	74	71	60	63	44	50	61	83	97	114	83
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	16.7	21.1	25.1	29.7	34.2	35.2	36.0	30.1	24.2	19.7	14.9
		MCWB	11.5	9.6	11.9	14.4	19.3	22.0	22.0	22.2	20.5	16.8	14.8	12.2
	2%	DB	11.8	14.0	18.4	22.7	27.3	31.9	33.3	33.8	28.3	22.5	17.7	12.7
		MCWB	9.3	8.5	10.8	14.0	18.0	21.1	21.9	21.6	19.5	17.1	14.4	10.1
	5%	DB	10.2	12.2	16.4	21.0	25.6	30.4	31.8	31.9	26.2	21.0	16.2	11.1
		MCWB	7.7	7.8	9.9	13.3	17.0	20.6	21.3	21.3	18.5	16.5	13.5	8.4
	10%	DB	8.8	10.6	14.6	19.2	23.8	28.8	30.3	30.0	24.3	19.6	14.8	9.8
		MCWB	7.0	7.3	9.2	12.6	16.2	20.0	20.6	20.6	17.6	15.8	12.5	7.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	11.2	13.5	16.4	20.5	23.6	24.3	24.1	21.6	19.4	16.2	12.9
		MCDB	13.2	13.7	18.4	21.8	27.3	31.2	31.2	31.9	27.4	21.6	17.7	14.3
	2%	WB	10.2	9.9	12.1	15.2	18.9	22.2	23.1	22.9	20.5	18.5	15.1	11.1
		MCDB	11.1	12.2	15.6	19.9	25.6	29.8	30.8	30.5	26.0	20.7	16.9	12.4
	5%	WB	8.6	8.9	11.3	14.1	18.0	21.2	22.2	22.1	19.6	17.7	14.2	9.4
		MCDB	9.4	11.1	14.5	19.0	23.7	28.6	29.5	29.5	24.4	19.9	15.8	10.2
	10%	WB	7.6	8.0	10.4	13.3	17.0	20.5	21.4	21.3	18.7	16.7	13.1	8.3
		MCDB	8.4	10.1	13.4	17.8	22.0	27.3	28.4	28.3	22.6	18.7	14.4	9.3
Mean Daily Temperature Range	5% DB	MDBR	7.8	9.3	10.0	10.2	10.8	12.0	12.3	12.2	11.0	9.2	8.0	8.2
		MCDBR	9.9	12.9	14.4	14.4	14.4	14.5	14.7	15.2	13.6	10.9	9.0	10.0
	5% WB	MCWBR	6.8	7.9	7.8	6.7	6.1	5.3	5.0	5.0	5.7	6.1	5.7	6.8
		MCWBR	6.0	9.6	10.6	11.6	12.2	13.4	13.6	13.4	11.3	7.6	6.7	6.5
Clear-Sky Solar Irradiance	taub		0.342	0.371	0.422	0.470	0.476	0.488	0.477	0.467	0.446	0.423	0.377	0.339
		taud	2.383	2.295	2.160	2.058	2.090	2.108	2.151	2.192	2.210	2.235	2.313	2.416
	Ebn at Noon		746	790	794	789	799	790	793	784	762	716	687	708
		Edh at Noon	75	98	129	156	156	154	146	135	122	104	80	66
All-Sky Solar Radiation	RadAvg		1.36	2.21	3.44	4.50	5.48	6.19	6.29	5.42	3.94	2.49	1.42	1.18
	RadStd		0.20	0.36	0.45	0.53	0.57	0.39	0.37	0.47	0.38	0.28	0.22	0.16

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Regional (58 neighbors)	+0.46	N/A	N/A	+0.75	+0.44	N/A	-80	-126	+95	+62	

Nomenclature: See separate page