

CERKLJE OB KRKI, Slovenia

WMO: 141220

Lat: 45.9009N

Lon: 15.5160E

Elev: 530

StdP: 14.42

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.5	17.7	7.1	8.1	15.7	12.3	10.5	21.1	17.3	49.0	14.5	43.2	3.3	110	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.9	91.8	71.5	89.2	71.1	86.0	69.9	73.9	87.0	72.4	85.2	70.7	83.0	6.3	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.8	111.6	80.6	68.1	105.2	79.0	66.4	99.3	76.3	37.8	87.0	36.3	85.5	34.9	83.3	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.4	12.8	11.0	4.2	97.0	7.6	3.6	-1.2	99.6	-5.7	101.7	-9.9	103.8	-15.4	106.4
			3.7	77.1	7.6	1.6	-1.7	78.2	-6.2	79.2	-10.4	80.1	-15.9	81.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	53.1	33.7	36.4	44.4	54.0	60.6	68.5	72.0	70.8	62.1	53.4	44.6	35.6	(6)
(7)		DBStd	15.07	8.22	8.11	7.51	5.95	6.08	5.85	5.54	5.34	6.07	6.98	7.80	8.07	(7)
(8)		HDD50	1810	507	382	199	29	3	0	0	0	1	46	194	449	(8)
(9)		HDD65	4964	971	800	638	330	161	31	9	13	126	361	613	911	(9)
(10)		CDD50	2945	1	2	25	150	333	556	681	646	364	153	31	3	(10)
(11)		CDD65	624	0	0	0	1	26	137	225	194	39	2	0	0	(11)
(12)		CDH74	6753	0	0	0	66	369	1471	2457	1988	371	31	0	0	(12)
(13)		CDH80	2519	0	0	0	5	68	505	1057	804	80	0	0	0	(13)
(14)	Wind	WSAvg	3.9	3.6	4.1	5.0	4.5	4.3	4.0	3.8	3.4	3.3	3.4	3.6	3.3	(14)
(15)	Precipitation	PrecAvg	40.7	2.2	2.4	2.4	3.0	3.5	3.9	3.7	3.9	4.5	4.2	4.0	2.9	(15)
(16)		PrecMax	59.6	6.3	7.0	5.8	7.0	6.1	6.7	6.6	8.5	8.6	9.3	8.4	4.8	(16)
(17)		PrecMin	26.5	0.4	0.2	0.4	0.2	1.1	1.5	1.7	0.6	1.0	0.4	0.3	0.2	(17)
(18)		PrecStd	6.5	1.4	1.7	1.3	1.5	1.4	1.2	1.3	2.1	2.3	2.2	1.7	1.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	57.6	62.7	71.5	80.4	85.9	92.8	96.4	97.2	86.4	77.7	68.1	60.8	(19)	
(20)		MCWB	49.7	49.8	54.4	61.8	68.5	72.1	72.0	70.3	69.1	64.0	58.3	53.4	(20)	
(21)		DB	53.7	57.3	66.5	75.3	81.7	89.1	93.0	91.5	82.2	73.3	63.0	55.5	(21)	
(22)		MCWB	47.6	47.7	52.5	58.4	65.7	71.1	71.6	71.4	67.9	62.7	55.2	49.5	(22)	
(23)		DB	50.1	53.5	62.7	71.9	78.5	85.9	89.6	88.0	78.5	69.5	59.1	51.6	(23)	
(24)		MCWB	46.0	46.1	51.0	56.8	63.6	69.8	71.2	70.6	66.2	61.1	53.4	47.2	(24)	
(25)		DB	46.3	48.8	58.8	68.2	75.0	82.5	86.1	84.4	74.9	64.8	55.5	46.8	(25)	
(26)		MCWB	43.4	43.8	49.0	55.5	62.4	68.2	69.9	69.3	64.3	58.3	51.5	44.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	50.8	51.4	55.5	62.8	69.6	75.5	75.9	75.6	70.8	65.4	59.1	53.6	(27)	
(28)		MCDWB	56.5	60.5	67.9	77.9	81.8	87.6	90.2	88.4	82.2	75.0	64.7	60.1	(28)	
(29)		WB	48.5	48.9	53.4	59.9	67.1	73.0	73.9	73.6	68.7	63.3	56.6	50.1	(29)	
(30)		MCDWB	52.9	55.9	64.8	72.4	79.7	85.4	87.7	86.2	80.0	71.4	62.1	54.6	(30)	
(31)		WB	46.0	46.4	51.4	57.8	64.8	70.8	72.3	72.0	67.0	61.3	54.3	47.6	(31)	
(32)		MCDWB	49.5	52.1	60.6	69.0	75.5	82.7	85.7	84.4	76.7	68.2	58.6	51.4	(32)	
(33)		WB	43.3	43.9	49.7	56.1	62.8	69.0	70.7	70.2	65.1	59.4	52.0	44.3	(33)	
(34)		MCDWB	45.6	48.4	57.3	66.0	72.5	80.4	83.3	82.2	72.7	64.7	55.6	46.6	(34)	
(35)	Mean Daily Temperature Range	MDBR	13.2	15.9	20.6	22.7	21.5	21.8	22.9	22.8	19.7	18.5	13.5	13.1	(35)	
(36)		5% DB	20.0	25.5	29.5	31.0	27.9	26.9	28.3	29.2	25.6	23.8	20.2	19.9	(36)	
(37)		MCWBR	14.2	16.5	16.7	15.9	13.5	11.8	10.5	11.2	12.3	13.8	13.1	14.0	(37)	
(38)		5% WB	18.2	22.3	25.5	26.6	25.4	25.1	26.0	25.6	23.6	22.4	18.3	18.7	(38)	
(39)		MCWBR	13.1	15.2	15.0	14.1	12.9	11.6	10.8	11.3	11.6	13.3	12.2	13.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.333	0.360	0.400	0.449	0.440	0.446	0.444	0.443	0.427	0.399	0.363	0.332	(40)	
(41)		taud	2.349	2.279	2.216	2.103	2.178	2.212	2.216	2.232	2.243	2.297	2.345	2.396	(41)	
(42)		Ebn at Noon	239	254	260	256	263	262	260	256	248	237	224	226	(42)	
(43)		Edh at Noon	24	32	39	47	45	44	43	41	37	31	24	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	395	645	1014	1353	1673	1902	1920	1679	1168	749	416	333	(44)	
(45)		RadStd	60	111	147	167	167	127	125	187	154	88	62	50	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (53 neighbors)	+0.79	N/A	N/A	+1.48	+0.81	+0.63	N/A	N/A	+151	+103	(47)

Nomenclature: See separate page