

CERKLJE OB KRKI, Slovenia

WMO: 141220

Lat: 45.9009N

Lon: 15.5160E

Elev: 162

StdP: 99.40

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.3	-8.0	-13.8	1.2	-9.0	-10.9	1.5	-6.1	7.7	9.5	6.5	6.2	1.5	110	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	33.2	21.9	31.8	21.7	30.0	21.0	23.3	30.6	22.4	29.5	21.5	28.3	2.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.9	27.0	20.0	15.0	26.1	19.1	14.2	24.6	69.9	30.6	66.5	29.7	63.4	28.5	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.9	5.7	4.9	-15.4	36.1	4.2	2.0	-18.5	37.6	-20.9	38.7	-23.3	39.9	-26.3	41.4		
			-15.7	25.0	4.2	0.9	-18.7	25.7	-21.2	26.2	-23.6	26.7	-26.6	27.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.7	0.9	2.5	6.9	12.2	15.9	20.3	22.2	21.6	16.7	11.9	7.0	2.0
	DBStd	8.37	4.57	4.51	4.17	3.31	3.38	3.25	3.08	2.97	3.37	3.88	4.33	4.48
	HDD10.0	1006	282	212	111	16	2	0	0	0	1	26	108	249
	HDD18.3	2758	539	444	354	183	89	17	5	7	70	201	341	506
	CDD10.0	1636	1	1	14	83	185	309	378	359	202	85	17	2
	CDD18.3	347	0	0	0	1	14	76	125	108	22	1	0	0
	CDH23.3	3752	0	0	0	37	205	817	1365	1104	206	17	0	0
	CDH26.7	1399	0	0	0	3	38	281	587	447	44	0	0	0
Wind	WSAvg	1.7	1.6	1.8	2.2	2.0	1.9	1.8	1.7	1.5	1.5	1.5	1.6	1.5
Precipitation	PrecAvg	1033	55	60	61	77	90	100	93	99	115	107	101	74
	PrecMax	1515	160	179	148	177	155	169	167	216	218	237	214	122
	PrecMin	672	11	6	11	6	27	39	42	16	25	10	7	6
	PrecStd	164	35	43	34	37	36	30	33	54	58	56	43	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.2	17.1	22.0	26.9	29.9	33.8	35.8	36.2	30.2	25.4	20.1	16.0
		MCWB	9.9	9.9	12.5	16.6	20.3	22.3	22.2	21.3	20.6	17.8	14.6	11.9
	2%	DB	12.1	14.1	19.2	24.1	27.6	31.7	33.9	33.1	27.9	22.9	17.2	13.1
		MCWB	8.7	8.7	11.4	14.7	18.7	21.7	22.0	21.9	20.0	17.1	12.9	9.7
	5%	DB	10.0	12.0	17.0	22.2	25.8	29.9	32.0	31.1	25.8	20.8	15.1	10.9
		MCWB	7.8	7.8	10.5	13.8	17.5	21.0	21.8	21.4	19.0	16.1	11.9	8.4
	10%	DB	8.0	9.3	14.9	20.1	23.9	28.1	30.1	29.1	23.8	18.2	13.1	8.2
		MCWB	6.3	6.5	9.4	13.1	16.9	20.1	21.0	20.7	17.9	14.6	10.9	6.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	10.8	13.0	17.1	20.9	24.2	24.4	24.2	21.6	18.6	15.1	12.0
		MCDB	13.6	15.8	20.0	25.5	27.7	30.9	32.3	31.3	27.9	23.9	18.2	15.6
	2%	WB	9.2	9.4	11.9	15.5	19.5	22.8	23.3	23.1	20.4	17.4	13.7	10.1
		MCDB	11.6	13.3	18.2	22.5	26.5	29.7	30.9	30.1	26.7	21.9	16.7	12.6
	5%	WB	7.8	8.0	10.8	14.4	18.2	21.5	22.4	22.2	19.4	16.3	12.4	8.6
		MCDB	9.7	11.2	15.9	20.6	24.2	28.2	29.8	29.1	24.9	20.1	14.8	10.8
	10%	WB	6.3	6.6	9.8	13.4	17.1	20.5	21.5	21.2	18.4	15.2	11.1	6.8
		MCDB	7.6	9.1	14.0	18.9	22.5	26.9	28.5	27.9	22.6	18.1	13.1	8.1
Mean Daily Temperature Range	5% DB	MDBR	7.3	8.8	11.4	12.6	12.0	12.1	12.7	12.7	11.0	10.3	7.5	7.3
		MCDBR	11.1	14.2	16.4	17.2	15.5	14.9	15.7	16.2	14.2	13.2	11.2	11.0
		MCWBR	7.9	9.1	9.3	8.9	7.5	6.6	5.8	6.2	6.8	7.7	7.3	7.8
	5% WB	MCDBR	10.1	12.4	14.2	14.8	14.1	14.0	14.4	14.2	13.1	12.5	10.1	10.4
MCWBR		7.3	8.4	8.3	7.8	7.2	6.5	6.0	6.3	6.5	7.4	6.8	7.4	
Clear-Sky Solar Irradiance	taub	0.333	0.360	0.400	0.449	0.440	0.446	0.444	0.443	0.427	0.399	0.363	0.332	
	taud	2.349	2.279	2.216	2.103	2.178	2.212	2.216	2.232	2.243	2.297	2.345	2.396	
	Ebn at Noon	754	802	819	808	830	826	821	806	782	746	707	714	
	Edh at Noon	77	100	122	149	143	139	137	130	118	97	77	67	
All-Sky Solar Radiation	RadAvg	1.25	2.03	3.20	4.26	5.27	6.00	6.05	5.29	3.68	2.36	1.31	1.05	
	RadStd	0.19	0.35	0.46	0.53	0.53	0.40	0.40	0.59	0.48	0.28	0.19	0.16	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (53 neighbors)	+0.44	N/A	N/A	+0.82	+0.45	+0.35	N/A	N/A	+84	+57	

Nomenclature: See separate page