

PUNTIJARKA, Croatia

WMO: 142350

Lat: 45.9076N

Lon: 15.9684E

Elev: 3241

StdP: 13.05

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.5	12.7	1.5	6.7	13.3	6.3	8.5	18.1	24.2	36.6	22.2	35.6	6.3	90	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	78.9	65.4	76.2	64.6	73.7	63.3	67.9	74.7	66.3	73.8	64.6	71.8	4.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	106.2	72.0	63.6	99.3	70.5	61.8	93.2	68.8	34.2	74.6	32.9	73.9	31.5	72.2	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.1	18.0	15.4	DB	6.5	83.0	4.6	3.4	3.2	85.5	0.5	87.5	-2.1	89.4	-5.5	91.9	(4)
(5)			WB	5.7	71.4	4.4	2.0	2.5	72.9	-0.1	74.0	-2.6	75.1	-5.8	76.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.4	29.0	30.0	36.8	45.9	53.3	60.5	63.9	63.3	54.6	47.1	39.7	31.7		
	DBStd	14.61	8.89	9.22	8.84	7.66	7.25	7.17	6.51	6.70	7.01	7.85	8.09	8.15		
	HDD50	2913	650	562	412	162	50	7	1	33	152	316	567			
	HDD65	6952	1115	981	873	572	365	169	100	114	317	556	758	1032		
	CDD50	1608	0	1	4	41	153	323	433	413	171	61	8	0		
	CDD65	170	0	0	0	0	3	34	67	60	6	0	0	0		
	CDH74	503	0	0	0	0	5	80	206	208	4	0	0	0		
	CDH80	47	0	0	0	0	0	2	18	27	0	0	0	0		
(14) Wind	WSAvg	6.2	6.8	6.8	6.7	6.6	6.2	4.7	4.2	4.9	5.3	6.9	7.9	7.6		
(15) Precipitation	PrecAvg	39.1	1.9	2.2	2.3	2.8	3.5	3.9	3.7	3.9	4.4	4.1	3.8	2.7		
	PrecMax	56.7	5.7	6.6	5.6	6.1	6.5	6.5	7.2	8.1	8.6	9.4	8.4	4.6		
	PrecMin	24.9	0.4	0.1	0.4	0.2	1.1	1.7	1.7	0.7	0.9	0.2	0.2	0.2		
	PrecStd	6.4	1.3	1.6	1.3	1.3	1.5	1.2	1.3	2.2	2.2	2.2	1.7	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	53.2	59.2	68.2	73.7	79.3	82.4	83.3	73.9	65.9	60.5	50.9		
		MCWB	40.6	39.9	47.4	54.3	60.9	66.6	65.9	65.2	62.3	55.8	50.0	41.9		
	2%	DB	46.2	47.8	55.1	63.0	69.7	76.5	79.0	79.0	70.0	61.9	55.3	47.4		
		MCWB	39.6	39.1	44.8	51.2	59.7	65.6	66.2	64.4	60.8	54.4	48.4	41.9		
	5%	DB	43.2	43.8	51.2	59.8	66.6	73.6	76.1	75.8	66.6	59.1	52.1	44.9		
		MCWB	39.8	38.8	43.0	49.8	57.5	64.4	65.0	63.5	59.0	52.8	47.9	41.5		
	10%	DB	40.8	40.9	47.8	56.4	63.7	70.9	73.4	73.1	64.0	56.7	49.7	42.2		
		MCWB	38.6	37.5	41.3	47.6	55.7	62.4	63.5	62.3	57.8	52.4	46.7	39.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.9	43.8	48.3	55.7	63.8	69.8	70.7	68.9	64.1	58.4	52.8	46.5		
		MCDB	46.1	47.8	56.4	65.2	70.8	75.9	76.6	76.9	70.9	62.7	56.8	47.8		
	2%	WB	42.2	41.7	46.0	52.6	61.1	67.4	68.0	67.0	62.0	56.3	50.5	44.0		
		MCDB	43.9	44.6	52.6	61.3	67.2	73.6	75.0	74.6	67.9	59.8	53.2	45.7		
	5%	WB	40.3	39.7	44.2	50.5	58.7	65.5	66.4	65.2	60.2	54.6	48.8	42.1		
		MCDB	42.2	42.3	48.9	57.6	64.3	72.2	74.1	72.8	65.5	57.5	51.2	43.7		
	10%	WB	38.2	38.0	42.5	48.6	56.6	63.4	64.6	63.6	58.4	53.1	47.3	39.9		
		MCDB	40.5	40.6	46.4	54.4	62.4	69.8	72.3	70.6	62.9	55.8	49.2	41.7		
(35) Mean Daily Temperature Range	MDBR		7.7	8.5	10.7	12.1	12.5	12.4	12.7	12.0	10.2	9.2	7.6	7.8		
	5% DB	MCDBR	9.2	11.5	14.3	15.6	14.9	14.3	14.5	14.2	12.5	10.8	9.3	10.6		
		MCWBR	6.1	7.6	9.0	9.4	9.5	9.8	9.3	9.2	8.3	7.7	6.6	7.3		
	5% WB	MCDBR	8.0	9.9	12.4	14.1	14.2	13.7	13.6	13.4	11.8	9.9	8.2	8.9		
		MCWBR	6.1	7.8	8.4	9.0	9.8	10.1	9.7	9.5	8.3	7.4	6.5	7.3		
(40) Clear-Sky Solar Irradiance	taub		0.290	0.311	0.340	0.378	0.370	0.375	0.375	0.375	0.362	0.341	0.315	0.291		
	taud		2.437	2.403	2.371	2.280	2.332	2.346	2.339	2.350	2.371	2.431	2.467	2.480		
	Ebn at Noon		260	275	282	279	284	283	281	276	270	260	247	247		
	Edh at Noon		22	28	33	40	39	38	38	36	33	27	22	19		
(44) All-Sky Solar Radiation	RadAvg		391	635	1012	1382	1707	1918	1926	1695	1176	768	424	318		
	RadStd		59	105	138	157	159	136	127	184	152	89	58	49		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (56 neighbors)		+0.85	N/A	N/A	+1.53	+0.86	+0.76	-144	-234	+166	+106

Nomenclature: See separate page