

PUNTIJARKA, Croatia

WMO: 142350

Lat: 45.9076N

Lon: 15.9684E

Elev: 988

StdP: 90.01

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.1	-10.7	-16.9	1.0	-10.4	-14.3	1.2	-7.7	10.8	2.5	9.9	2.0	2.8	90	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	26.0	18.6	24.6	18.1	23.1	17.4	19.9	23.7	19.1	23.2	18.1	22.1	2.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.6	15.2	22.2	17.6	14.2	21.4	16.6	13.3	20.4	61.7	23.7	58.7	23.3	55.4	22.3	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.0	6.9	DB	-14.2	28.3	2.6	1.9	-16.0	29.7	-17.5	30.8	-18.9	31.9	-20.8	33.3	(4)
(5)			WB	-14.6	21.9	2.5	1.1	-16.4	22.7	-17.8	23.3	-19.2	24.0	-21.0	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.0	-1.7	-1.1	2.7	7.7	11.8	15.8	17.7	17.4	12.6	8.4	4.3	-0.2	(6)	
	DBStd	8.12	4.94	5.12	4.91	4.26	4.03	3.98	3.62	3.72	3.90	4.36	4.49	4.53	(7)	
	HDD10.0	1618	361	312	229	90	28	4	1	1	18	84	176	315	(8)	
	HDD18.3	3862	619	545	485	318	203	94	56	63	176	309	421	573	(9)	
	CDD10.0	893	0	1	2	23	85	179	241	229	95	34	4	0	(10)	
	CDD18.3	94	0	0	0	0	2	19	37	33	3	0	0	0	(11)	
	CDH23.3	279	0	0	0	0	3	44	114	116	2	0	0	0	(12)	
	CDH26.7	26	0	0	0	0	0	1	10	15	0	0	0	0	(13)	
(14) Wind	WSAvg	2.8	3.1	3.0	3.0	3.0	2.8	2.1	1.9	2.2	2.4	3.1	3.5	3.4	(14)	
(15) Precipitation	PrecAvg	993	49	56	59	71	88	99	93	98	111	103	96	69	(15)	
	PrecMax	1441	146	168	142	155	165	165	184	205	218	238	213	116	(16)	
	PrecMin	633	9	3	11	6	29	43	43	17	22	6	5	6	(17)	
	PrecStd	162	32	40	34	34	37	31	32	55	57	55	43	33	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	11.8	15.1	20.1	23.2	26.3	28.0	28.5	23.3	18.8	15.9	10.5	(19)	
		MCWB	4.8	4.4	8.5	12.4	16.0	19.2	18.8	18.4	16.8	13.2	10.0	5.5	(20)	
	2%	DB	7.9	8.8	12.8	17.2	20.9	24.7	26.1	26.1	21.1	16.6	13.0	8.6	(21)	
		MCWB	4.2	3.9	7.1	10.7	15.4	18.7	19.0	18.0	16.0	12.4	9.1	5.5	(22)	
	5%	DB	6.2	6.6	10.7	15.4	19.2	23.1	24.5	24.4	19.2	15.1	11.2	7.1	(23)	
		MCWB	4.4	3.8	6.1	9.9	14.2	18.0	18.3	17.5	15.0	11.5	8.9	5.3	(24)	
	10%	DB	4.9	4.9	8.8	13.5	17.6	21.6	23.0	22.8	17.8	13.7	9.9	5.7	(25)	
		MCWB	3.7	3.1	5.2	8.7	13.2	16.9	17.5	16.8	14.3	11.3	8.1	4.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.6	6.6	9.0	13.2	17.7	21.0	21.5	20.5	17.9	14.7	11.6	8.1	(27)	
		MCDB	7.8	8.8	13.6	18.4	21.6	24.4	24.8	24.9	21.6	17.0	13.8	8.8	(28)	
	2%	WB	5.7	5.4	7.8	11.5	16.2	19.7	20.0	19.4	16.6	13.5	10.3	6.7	(29)	
		MCDB	6.6	7.0	11.4	16.3	19.5	23.1	23.9	23.7	19.9	15.4	11.8	7.6	(30)	
	5%	WB	4.6	4.3	6.8	10.3	14.9	18.6	19.1	18.5	15.7	12.5	9.4	5.6	(31)	
		MCDB	5.7	5.7	9.4	14.2	18.0	22.3	23.4	22.6	18.6	14.2	10.6	6.5	(32)	
	10%	WB	3.5	3.3	5.9	9.2	13.7	17.5	18.1	17.6	14.7	11.7	8.5	4.4	(33)	
		MCDB	4.7	4.8	8.0	12.4	16.9	21.0	22.4	21.4	17.1	13.2	9.6	5.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.3	4.7	5.9	6.7	7.0	6.9	7.0	6.7	5.6	5.1	4.2	4.4	(35)	
		MCDBR	5.1	6.4	8.0	8.7	8.3	8.0	8.1	7.9	7.0	6.0	5.2	5.9	(36)	
	5% WB	MCWBR	3.4	4.2	5.0	5.2	5.3	5.4	5.2	5.1	4.6	4.3	3.7	4.1	(37)	
		MCWBR	4.4	5.5	6.9	7.8	7.9	7.6	7.6	7.5	6.6	5.5	4.5	4.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.290	0.311	0.340	0.378	0.370	0.375	0.375	0.375	0.362	0.341	0.315	0.291	(40)	
		taud	2.437	2.403	2.371	2.280	2.332	2.346	2.339	2.350	2.371	2.431	2.467	2.480	(41)	
	Edn at Noon		820	868	888	879	896	891	885	871	852	819	780	780	(42)	
		Edh at Noon	69	87	104	125	122	121	121	115	103	84	68	60	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.23	2.00	3.19	4.36	5.38	6.04	6.07	5.34	3.71	2.42	1.34	1.00	(44)	
	RadStd		0.18	0.33	0.43	0.50	0.50	0.43	0.40	0.58	0.48	0.28	0.18	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (56 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.47	N/A	N/A	+0.85	+0.48	+0.42	-80	-130	+92	+59

Nomenclature: See separate page