

DARUVAR, CroatiaWMO: **142580**Lat: **45.5914N**Lon: **17.2100E**Elev: **507**StdP: **14.43**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	17.3	8.3	8.6	16.0	13.1	10.9	20.8	14.7	40.3	13.2	41.1	2.0	10	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.5	90.9	71.1	88.2	70.3	85.6	69.5	74.3	85.4	72.4	84.0	70.8	82.3	4.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.8	115.7	79.9	68.8	107.8	77.6	67.1	101.5	75.5	38.1	85.3	36.4	84.2	34.9	82.3	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.6	11.5	9.7	4.5	95.5	7.3	3.4	-0.8	98.0	-5.1	100.0	-9.2	102.0	-14.6	104.5		
(5)			4.2	78.0	7.3	2.5	-1.1	79.8	-5.4	81.3	-9.5	82.7	-14.8	84.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.9	33.6	36.9	44.2	52.9	61.3	68.2	70.9	70.5	61.6	53.5	44.6	35.6
	DBStd	15.21	8.76	9.35	8.04	6.87	6.40	6.56	5.61	5.30	6.44	8.08	8.82	9.27
	HDD50	1871	512	370	213	50	3	0	0	0	1	59	208	455
	HDD65	5017	974	786	646	365	148	43	14	14	139	363	613	912
	CDD50	2921	3	4	31	135	353	545	646	635	349	167	45	8
	CDD65	596	0	0	0	1	33	139	196	184	37	5	1	0
	CDH74	6489	0	0	0	43	437	1497	2115	1927	423	47	0	0
	CDH80	2325	0	0	0	5	83	518	852	764	102	1	0	0
Wind	WSAvg	3.5	3.3	3.9	4.4	4.0	3.7	3.4	3.3	3.1	3.0	2.9	3.3	3.5
Precipitation	PrecAvg	35.0	2.2	1.9	2.2	3.0	3.3	3.8	3.3	3.5	3.0	2.8	3.5	2.7
	PrecMax	46.7	6.1	5.8	5.1	7.1	8.1	7.8	11.2	11.0	9.9	9.4	6.2	6.3
	PrecMin	25.0	0.1	0.3	0.4	0.5	0.3	1.2	0.1	0.6	0.3	0.0	0.5	0.3
	PrecStd	5.4	1.2	1.2	1.0	1.4	1.7	1.5	2.1	2.4	2.0	2.0	1.8	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.1	64.0	71.3	78.8	86.3	91.7	95.1	96.0	88.2	78.7	70.4	63.6
		MCWB	50.9	49.7	54.0	60.2	67.5	72.0	71.4	71.6	67.3	63.8	58.0	53.8
	2%	DB	55.4	59.3	66.7	74.1	82.3	88.8	90.9	91.0	82.6	74.6	66.1	57.5
		MCWB	47.9	48.7	52.8	57.9	66.2	71.3	71.4	70.7	66.8	62.7	56.1	50.0
	5%	DB	51.0	55.5	62.8	70.6	79.1	86.0	88.0	87.7	78.8	70.8	62.4	53.5
		MCWB	45.5	46.6	50.9	56.1	64.2	70.3	70.5	70.0	65.0	60.8	54.1	47.7
	10%	DB	46.8	51.3	58.9	67.0	75.7	82.7	85.0	84.3	75.1	67.0	58.4	49.3
		MCWB	42.7	44.6	49.3	54.4	62.4	68.3	69.6	68.9	63.7	59.3	52.8	45.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.3	51.8	56.0	62.4	70.2	75.5	77.1	76.7	70.7	65.7	59.7	54.2
		MCDB	58.6	60.6	67.0	74.1	81.3	85.9	87.2	86.6	80.0	74.7	66.2	62.1
	2%	WB	48.4	49.4	53.9	59.6	67.6	73.4	74.4	73.5	68.3	63.7	57.2	51.0
		MCDB	54.0	57.5	63.5	70.7	79.1	85.3	85.5	84.9	78.8	72.0	63.3	56.7
	5%	WB	45.9	47.4	52.1	57.4	65.7	71.6	72.3	71.6	66.5	61.9	55.2	48.3
		MCDB	50.6	54.1	60.6	66.9	76.1	83.1	83.7	83.8	75.9	69.1	61.8	52.9
	10%	WB	43.0	45.2	50.1	55.7	63.7	69.6	70.7	70.1	64.7	59.9	52.7	45.6
		MCDB	46.7	50.7	58.1	64.7	73.2	80.3	82.0	81.6	72.8	66.0	58.1	49.2
Mean Daily Temperature Range	5% DB	MDBR	12.6	16.8	19.3	21.1	22.0	21.8	22.5	23.4	21.0	19.6	14.7	11.8
		MCDBR	19.3	24.0	27.0	28.9	28.0	26.5	28.3	29.8	28.0	24.1	20.4	17.6
		MCWBR	12.4	14.0	14.5	13.8	12.9	12.0	12.0	12.0	13.0	13.2	11.8	11.3
	5% WB	MCDBR	18.3	21.8	23.4	24.2	24.9	25.4	25.9	26.0	24.6	22.3	18.7	16.5
		MCWBR	12.1	13.4	13.0	12.3	12.4	12.4	12.5	12.0	12.4	12.6	11.5	11.3
Clear-Sky Solar Irradiance	taub		0.335	0.361	0.395	0.446	0.433	0.434	0.436	0.437	0.423	0.392	0.358	0.335
	taud		2.371	2.298	2.242	2.110	2.200	2.241	2.231	2.237	2.246	2.323	2.373	2.383
	Ebn at Noon		240	255	262	258	266	266	263	258	250	240	229	226
	Edh at Noon		24	31	38	47	44	43	43	41	37	30	24	22
All-Sky Solar Radiation	RadAvg		388	620	1009	1407	1745	1947	1954	1730	1186	792	441	309
	RadStd		62	102	130	150	147	151	128	184	152	91	57	51