

OSIJEK KLISA, Croatia

WMO: 142840

Lat: 45.468N

Lon: 18.806E

Elev: 292

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	17.9	6.9	7.9	14.7	12.6	10.5	20.4	22.9	37.7	20.6	38.0	6.1	340	0.485

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.0	93.8	70.0	91.2	69.5	87.9	68.3	73.6	84.9	72.2	84.4	70.6	82.9	7.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	112.0	78.3	68.3	105.1	76.8	66.6	98.9	74.9	37.3	86.0	36.0	84.8	34.7	83.1	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.5	17.5	15.1	4.5	98.4	10.8	4.1	-3.2	101.3	-9.6	103.6	-15.6	105.9	-23.5	108.9		
			4.1	76.5	10.6	2.3	-3.5	78.2	-9.7	79.6	-15.6	80.9	-23.3	82.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	54.3	33.9	36.5	45.3	55.7	63.1	70.0	73.2	72.7	63.8	55.2	45.0	35.8	(6)
(7)		DBStd	15.77	8.67	9.29	8.39	6.41	6.67	6.44	5.60	5.59	6.45	7.18	7.54	7.85	(7)
(8)		HDD50	1753	499	380	186	23	3	0	0	0	35	183	444	(8)	
(9)		HDD65	4719	963	798	611	283	115	27	5	6	95	310	599	907	(9)
(10)		CDD50	3315	1	2	40	195	408	599	719	704	415	195	34	3	(10)
(11)		CDD65	807	0	0	0	5	56	177	259	245	60	5	0	0	(11)
(12)		CDH74	8954	0	0	2	133	629	1884	2866	2670	674	96	0	0	(12)
(13)		CDH80	3644	0	0	0	24	156	729	1303	1220	204	8	0	0	(13)
(14)	Wind	WSAvg	6.9	7.2	7.7	8.3	7.7	7.5	6.5	6.2	5.8	6.1	6.0	6.8	7.2	(14)
(15)	Precipitation	PrecAvg	26.7	1.7	1.8	1.8	2.0	3.2	2.9	2.7	2.4	2.2	2.4	2.0	1.9	(15)
(16)		PrecMax	37.4	3.0	3.3	3.5	5.2	7.1	5.6	7.3	7.9	5.0	5.4	4.6	4.3	(16)
(17)		PrecMin	15.6	0.5	0.2	0.2	0.2	1.0	1.1	0.8	0.2	0.1	0.1	0.2	0.1	(17)
(18)		PrecStd	6.0	0.7	0.8	0.9	1.3	1.7	1.2	1.7	1.9	1.3	1.4	1.0	1.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.5	64.1	73.1	83.7	88.1	93.6	100.1	98.9	91.2	80.9	69.8	58.9	(19)
(20)		MCWB	50.2	50.4	55.0	62.4	65.8	70.4	70.2	71.4	66.0	62.5	57.7	51.3	(20)	
(21)		2%	DB	52.2	57.2	68.1	77.3	84.2	91.0	94.4	94.6	85.9	76.8	64.1	53.7	(21)
(22)		MCWB	46.5	49.2	53.2	59.1	64.2	70.4	70.2	70.7	64.5	60.8	55.5	49.6	(22)	
(23)		5%	DB	48.2	52.2	64.1	73.6	80.8	87.7	91.1	90.4	80.9	73.1	59.4	50.0	(23)
(24)		MCWB	45.0	46.0	50.8	56.6	63.3	68.8	69.7	69.0	63.2	59.4	54.0	46.8	(24)	
(25)		10%	DB	44.7	48.4	59.1	69.9	77.1	84.3	87.7	87.2	77.3	68.4	56.0	46.3	(25)
(26)		MCWB	42.5	44.7	49.0	55.1	61.8	67.8	68.7	68.0	61.8	58.1	51.7	43.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.6	52.3	56.6	63.6	68.9	75.2	74.9	75.8	69.2	65.0	59.8	52.6	(27)
(28)		MADB	55.7	59.4	67.3	78.1	80.6	85.1	85.2	88.5	78.5	74.4	66.6	57.1	(28)	
(29)		2%	WB	48.0	49.5	54.3	60.9	66.8	73.2	73.3	73.2	67.0	62.4	57.0	50.0	(29)
(30)		MADB	51.7	55.5	64.7	74.2	78.3	83.2	85.2	85.3	78.4	72.4	61.9	53.5	(30)	
(31)		5%	WB	44.8	47.1	52.3	58.6	65.2	71.4	72.0	71.6	65.5	60.9	54.7	47.0	(31)
(32)		MADB	47.2	51.3	61.4	69.0	76.1	82.7	84.9	84.8	76.7	70.1	59.3	49.9	(32)	
(33)		10%	WB	42.3	44.9	50.2	56.6	63.5	69.8	70.4	69.9	64.0	59.1	52.2	43.8	(33)
(34)		MADB	44.2	47.8	57.8	66.6	74.1	81.2	82.9	82.4	74.1	67.1	56.3	45.3	(34)	
(35)	Mean Daily Temperature Range	MDBR	11.7	14.2	18.9	21.8	20.5	21.3	23.0	23.4	21.0	20.2	14.7	10.6	(35)	
(36)		5% DB	MADB	17.8	21.8	27.7	29.4	26.5	26.5	28.9	29.9	28.2	27.3	20.8	16.7	(36)
(37)		MCWBR	12.6	13.9	14.2	13.2	9.8	9.7	8.9	9.5	10.2	13.0	12.9	12.4	(37)	
(38)		5% WB	MADB	16.2	19.1	23.8	25.0	23.5	23.7	25.0	25.9	23.3	24.5	18.9	15.7	(38)
(39)		MCWBR	12.0	12.8	13.1	12.1	9.9	10.2	9.5	10.0	9.8	12.9	12.4	12.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.341	0.366	0.399	0.455	0.441	0.439	0.443	0.447	0.430	0.396	0.361	0.341	(40)	
(41)		taud	2.362	2.284	2.228	2.080	2.178	2.224	2.207	2.203	2.219	2.311	2.362	2.366	(41)	
(42)		Ebn at Noon	238	253	261	255	264	264	261	255	248	239	227	224	(42)	
(43)		Edh at Noon	24	32	38	49	45	44	44	43	38	31	24	22	(43)	
(44)	All-Sky Solar Radiation	RadAvg	386	643	1043	1461	1781	1954	1972	1756	1219	835	484	311	(44)	
(45)		RadStd	60	91	130	136	152	160	146	174	137	86	44	46	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (40 neighbors)	+1.21	N/A	N/A	N/A	+0.76	+0.79	-211	-329	+205	+110	(47)

Nomenclature: See separate page