

PULA, Croatia

WMO: 143070

Lat: 44.894N

Lon: 13.922E

Elev: 274

StdP: 14.55

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.6	29.3	8.6	8.7	33.0	12.9	10.7	35.4	29.7	35.2	26.5	37.6	8.6	60	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	91.4	70.5	89.0	70.2	86.2	69.3	74.4	83.5	72.9	82.8	71.6	81.9	7.9	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.8	118.6	77.8	70.0	111.4	77.1	68.2	104.6	75.9	38.0	83.1	36.7	82.9	35.5	81.9	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.1	20.4	17.1	DB	20.7	94.5	3.9	3.0	17.9	96.7	15.7	98.4	13.5	100.1	10.7	102.3
			WB	18.2	76.9	3.6	1.6	15.5	78.1	13.4	79.1	11.4	80.0	8.7	81.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.6	42.0	42.8	48.1	54.3	62.2	70.0	74.6	74.6	66.4	59.0	51.4	44.3
	DBStd	12.72	5.36	5.54	5.46	5.34	4.81	5.17	4.38	4.88	4.96	5.22	6.18	5.71
	HDD50	833	253	207	100	21	0	0	0	0	0	4	58	190
	HDD65	3595	712	622	525	321	113	14	1	2	42	194	408	641
	CDD50	3593	6	5	40	151	378	601	762	763	491	283	99	14
	CDD65	880	0	0	0	1	26	165	298	299	83	8	0	0
	CDH74	8337	0	0	0	10	246	1549	3060	2952	503	17	0	0
	CDH80	2867	0	0	0	0	30	459	1155	1144	78	1	0	0
Wind	WSAvg	6.9	6.7	7.9	8.0	7.1	6.6	6.5	6.7	6.6	7.1	6.7	6.7	6.9
Precipitation	PrecAvg	35.7	3.1	2.8	2.8	2.7	2.4	2.4	1.7	3.0	3.7	3.9	4.4	3.3
	PrecMax	54.2	7.4	7.0	8.1	5.9	5.6	7.2	4.8	8.8	9.4	16.7	9.8	10.6
	PrecMin	24.6	0.0	0.3	0.3	0.6	0.1	0.5	0.0	0.0	0.0	0.6	0.6	0.6
	PrecStd	6.6	1.9	1.8	1.9	1.3	1.3	1.5	1.3	1.9	2.4	3.4	2.3	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.0	60.4	67.7	75.2	83.4	91.2	94.1	95.1	85.5	75.8	67.6	60.6
		MCWB	54.7	49.8	53.7	60.3	67.0	71.3	71.8	70.4	68.5	64.0	61.8	56.5
	2%	DB	55.7	56.9	64.0	71.6	79.8	87.8	91.2	91.8	82.4	72.9	64.6	57.6
		MCWB	52.3	49.6	51.9	57.5	64.9	70.5	70.8	70.0	67.3	63.8	60.3	53.6
	5%	DB	53.7	54.8	60.9	68.3	76.7	85.3	88.7	89.5	79.6	70.1	62.8	55.6
		MCWB	49.9	48.9	51.6	55.7	62.8	69.0	70.1	70.0	66.4	63.3	59.2	51.8
	10%	DB	51.6	53.0	58.2	65.7	73.6	82.5	86.2	86.3	76.8	68.1	61.0	53.8
		MCWB	48.0	48.0	50.6	54.8	61.5	67.9	69.2	69.5	65.4	62.7	57.5	50.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.4	54.4	56.7	61.4	69.8	75.2	76.1	76.9	73.4	69.0	63.7	58.0
		MCDB	57.7	56.8	61.5	70.8	79.5	85.2	85.2	82.6	78.2	71.3	65.9	59.8
	2%	WB	53.6	52.3	55.0	59.6	67.1	72.7	74.0	74.5	71.3	67.2	61.7	55.2
		MCDB	55.6	54.8	59.4	67.6	75.8	82.9	84.4	83.0	76.9	69.7	63.8	57.2
	5%	WB	51.4	50.9	53.7	57.8	64.9	71.0	72.6	73.0	69.3	65.5	60.0	53.1
		MCDB	53.2	53.3	58.4	64.7	73.0	81.3	83.4	83.0	75.8	68.4	62.3	55.2
	10%	WB	49.2	49.2	52.4	56.3	63.3	69.3	71.2	71.5	67.5	63.6	58.3	51.2
		MCDB	50.7	51.6	56.5	62.7	71.1	79.5	82.2	82.4	73.9	66.7	60.7	53.2
Mean Daily Temperature Range	5% DB	MDBR	13.9	15.5	16.4	17.4	17.9	18.8	19.8	19.2	16.8	15.0	13.2	13.8
		MCDBR	15.6	18.7	21.0	22.1	22.8	22.5	23.1	23.1	19.9	17.2	12.9	15.1
		MCWBR	12.0	13.2	13.2	12.2	11.7	10.5	10.4	10.0	10.0	10.8	9.4	11.7
	5% WB	MCDBR	11.2	13.7	16.4	18.4	19.5	20.7	20.8	19.8	17.1	13.1	10.2	11.7
		MCWBR	9.8	11.1	11.3	11.2	11.3	11.1	11.0	10.8	10.5	9.5	8.4	10.2
Clear-Sky Solar Irradiance	taub	0.342	0.364	0.400	0.437	0.436	0.442	0.434	0.429	0.416	0.400	0.368	0.338	
	taud	2.433	2.364	2.273	2.188	2.250	2.284	2.301	2.327	2.335	2.349	2.378	2.449	
	Ebn at Noon	242	257	262	261	266	264	264	261	254	240	228	231	
	Edh at Noon	23	30	37	44	43	41	40	38	35	30	25	21	
All-Sky Solar Radiation	RadAvg	419	695	1120	1531	1910	2171	2201	1884	1334	835	468	369	
	RadStd	65	115	142	153	172	116	104	149	110	81	52	50	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	+0.74	N/A	N/A	N/A	N/A	N/A	-175	+193	+104
(47)	Regional (30 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	-182	+151	+108

Nomenclature: See separate page