

SLAVONSKI BROD, Croatia

WMO: 143700

Lat: 45.1592N

Lon: 17.9953E

Elev: 89

StdP: 100.26

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.9	-7.9	-14.0	1.1	-9.3	-11.1	1.5	-6.5	7.1	6.5	6.0	4.0	1.1	60	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	34.1	22.1	32.4	21.6	30.8	21.0	23.3	31.1	22.5	30.3	21.7	29.2	2.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.9	15.7	26.7	20.0	14.9	25.9	19.2	14.1	24.9	69.6	31.3	66.5	30.4	63.7	29.4	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	5.0	4.1	DB	-16.1	36.7	5.3	2.1	-20.0	38.2	-23.1	39.4	-26.0	40.5	-29.9	42.0	(4)
(5)			WB	-16.4	24.9	5.2	0.9	-20.2	25.5	-23.2	26.1	-26.2	26.6	-30.0	27.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	0.8	2.8	7.5	12.4	16.7	20.3	22.2	22.0	17.0	12.3	7.2	1.9	(6)	
	DBStd	8.47	4.83	4.69	4.44	3.64	3.44	3.49	3.03	2.95	3.59	3.98	4.31	4.32	(7)	
	HDD10.0	986	286	202	100	18	2	0	0	0	1	23	103	252	(8)	
	HDD18.3	2689	544	434	336	178	73	20	4	5	66	187	334	508	(9)	
	CDD10.0	1711	1	1	22	92	208	308	378	373	211	96	19	2	(10)	
	CDD18.3	373	0	0	0	2	21	78	124	119	27	2	0	0	(11)	
	CDH23.3	4546	0	0	2	58	312	945	1456	1399	331	43	1	0	(12)	
	CDH26.7	1806	0	0	0	8	71	356	644	628	97	2	0	0	(13)	
(14) Wind	WSAvg	1.7	1.6	1.8	2.1	1.9	1.8	1.7	1.6	1.5	1.5	1.4	1.4	1.5	(14)	
(15) Precipitation	PrecAvg	814	52	46	51	66	78	85	82	67	87	68	66	64	(15)	
	PrecMax	1027	92	90	100	171	218	194	200	219	226	173	123	139	(16)	
	PrecMin	452	13	8	6	9	14	28	14	9	13	5	5	1	(17)	
	PrecStd	156	23	23	22	38	45	36	48	50	48	43	31	35	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.5	18.0	23.2	27.6	30.9	34.1	36.4	37.2	32.4	26.8	21.9	16.4	(19)	
		MCWB	10.1	10.4	13.0	16.7	19.6	22.7	22.4	21.9	20.2	17.9	14.9	11.3	(20)	
	2%	DB	12.5	15.0	20.7	24.8	28.7	32.3	34.1	34.3	29.2	24.5	18.8	12.7	(21)	
		MCWB	8.5	8.9	11.9	15.1	18.8	22.0	22.3	21.7	19.2	16.9	13.0	9.2	(22)	
	5%	DB	9.4	12.3	18.4	22.7	26.7	30.6	32.4	32.2	26.9	22.4	16.3	10.1	(23)	
		MCWB	6.9	7.7	11.0	14.0	17.9	21.4	21.9	21.1	18.4	15.9	12.1	7.7	(24)	
	10%	DB	7.1	9.8	15.9	20.5	24.9	28.8	30.4	30.3	24.8	19.9	14.1	7.8	(25)	
		MCWB	5.4	6.7	9.9	13.0	17.0	20.5	21.1	20.7	17.6	14.8	11.1	6.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	11.1	13.6	17.5	20.9	24.2	24.3	24.2	21.4	18.7	15.4	11.5	(27)	
		MCDB	14.8	16.7	21.3	26.2	28.2	31.4	32.0	31.5	29.8	24.9	20.3	15.4	(28)	
	2%	WB	8.8	9.6	12.4	15.9	19.6	22.9	23.3	23.0	20.1	17.5	14.0	9.6	(29)	
		MCDB	11.8	14.0	19.0	23.1	26.7	30.2	31.3	30.8	27.0	23.2	17.3	12.4	(30)	
	5%	WB	7.0	8.3	11.3	14.7	18.6	22.0	22.6	22.2	19.2	16.4	12.6	7.8	(31)	
		MCDB	9.0	11.5	17.1	20.8	25.5	29.3	30.5	30.1	25.1	21.2	16.1	9.7	(32)	
	10%	WB	5.7	7.0	10.3	13.7	17.6	21.1	21.8	21.3	18.2	15.3	11.1	6.3	(33)	
		MCDB	7.1	9.4	15.2	19.1	23.7	27.7	29.2	28.9	23.4	19.2	13.8	7.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	9.0	11.4	12.4	12.6	12.7	13.2	14.0	12.3	11.8	9.1	7.1	(35)	
		MCDBR	12.4	14.9	17.1	17.6	16.5	15.9	17.0	18.1	16.7	15.9	14.2	12.1	(36)	
	5% WB	MCWBR	8.4	9.3	9.1	8.6	7.6	6.8	6.5	7.0	7.6	8.8	8.8	8.7	(37)	
		MCWBR	11.2	13.2	15.1	14.9	14.7	14.7	15.3	15.7	14.5	14.6	12.7	11.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.340	0.368	0.401	0.457	0.444	0.442	0.444	0.446	0.430	0.397	0.360	0.340	(40)	
		taud	2.361	2.279	2.224	2.080	2.173	2.223	2.215	2.215	2.227	2.315	2.370	2.370	(41)	
	Ebn at Noon		756	799	822	803	829	831	823	806	782	756	723	712	(42)	
		Edh at Noon	78	101	122	153	144	138	137	133	121	97	77	70	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.25	1.99	3.21	4.41	5.44	6.05	6.14	5.48	3.77	2.57	1.49	1.02	(44)	
	RadStd		0.19	0.29	0.41	0.48	0.47	0.50	0.45	0.58	0.45	0.29	0.16	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	+0.47	+0.72	N/A	N/A	N/A	N/A
(47)	Regional (35 neighbors)	+0.64	N/A	N/A	N/A	+0.40	N/A	-108	-157	+100	+60

Nomenclature: See separate page