

DUBROVNIK CILIP, Croatia

WMO: 144740

Lat: 42.561N

Lon: 18.268E

Elev: 527

StdP: 14.42

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.9	35.2	3.4	6.7	36.4	8.1	8.5	38.2	42.2	33.7	38.0	37.5	21.0	20	0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.3	89.9	68.9	87.8	68.6	85.9	68.6	74.4	82.9	72.9	82.0	71.5	80.9	8.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.6	119.1	80.1	69.8	111.9	78.7	68.1	105.3	77.8	38.3	82.9	36.9	82.2	35.6	81.2	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
33.1	28.4	24.6	27.8	93.9	3.2	2.8	25.4	95.9	23.5	97.6	21.7	99.2	19.3	101.2
			21.6	77.4	2.6	1.6	19.7	78.5	18.2	79.4	16.7	80.3	14.8	81.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.1	46.6	47.4	51.4	57.4	65.0	72.6	77.2	77.5	69.7	62.6	55.5	48.9	(6)
		DBStd	12.06	5.36	5.57	5.14	5.01	4.99	5.57	4.22	4.45	4.63	4.50	5.41	5.42	(7)
		HDD50	379	127	103	43	6	0	0	0	0	0	16	84		(8)
		HDD65	2683	571	493	421	234	64	7	0	10	98	285	500		(9)
		CDD50	4420	21	30	88	227	464	679	843	854	592	391	182	49	(10)
		CDD65	1248	0	0	0	5	63	236	378	389	152	24	1	0	(11)
		CDH74	10028	0	0	0	15	225	1776	3578	3739	671	22	2	0	(12)
		CDH80	2846	0	0	0	0	15	432	1091	1219	88	1	0	0	(13)
(14)	Wind	WSAvg	10.4	11.9	12.3	12.1	10.2	9.1	8.9	9.1	8.7	9.6	9.7	10.9	12.4	(14)
(15)	Precipitation	PrecAvg	75.9	8.4	7.8	6.9	6.3	3.9	2.7	2.0	2.5	5.3	7.7	10.1	9.6	(15)
(16)		PrecMax	105.7	16.4	15.0	16.6	12.1	7.5	6.7	8.1	6.1	12.7	17.2	20.6	15.6	(16)
(17)		PrecMin	59.4	0.9	3.1	1.7	2.2	0.4	0.2	0.3	0.5	0.0	5.0	2.0		(17)
(18)		PrecStd	13.7	4.3	3.2	3.2	2.6	1.9	1.7	2.0	1.8	2.8	4.1	3.9	3.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	59.4	64.4	67.2	76.4	82.2	89.9	92.1	94.1	86.1	76.7	71.2	62.7		(19)
(20)		MCWB	51.3	51.6	52.6	58.8	64.0	69.8	69.1	70.4	67.4	62.1	58.8	55.7		(20)
(21)		DB	57.4	60.0	63.7	71.5	78.9	87.0	89.7	90.8	82.4	73.7	67.4	60.6		(21)
(22)		MCWB	51.8	50.4	51.7	56.4	63.2	68.8	69.1	68.9	67.3	62.4	59.6	54.6		(22)
(23)		DB	55.7	57.4	61.1	68.2	76.7	84.5	87.6	88.1	80.2	71.9	65.7	58.8		(23)
(24)		MCWB	50.8	50.0	51.3	55.6	62.2	68.1	68.8	68.4	66.2	62.3	59.0	53.4		(24)
(25)		DB	54.0	55.5	59.2	66.1	73.9	82.4	85.7	86.1	77.4	70.1	64.0	57.1		(25)
(26)		MCWB	48.8	49.5	50.9	54.6	61.5	67.1	68.6	68.5	65.2	61.7	57.9	51.7		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	55.7	55.8	57.0	61.6	68.6	74.8	76.1	76.5	72.8	68.5	65.1	59.4		(27)
(28)		MCDB	57.5	58.4	61.5	69.4	76.1	83.3	84.2	83.6	79.3	71.4	66.7	61.5		(28)
(29)		WB	54.1	53.8	55.3	59.5	66.2	72.6	74.3	74.5	70.8	66.7	62.4	56.7		(29)
(30)		MCDB	56.3	57.4	59.6	66.6	74.2	81.4	83.1	82.8	77.2	70.3	65.1	59.1		(30)
(31)		WB	52.2	52.4	54.1	58.0	64.7	70.9	72.7	73.0	69.3	65.1	60.3	54.8		(31)
(32)		MCDB	55.1	56.2	58.5	64.9	72.7	80.2	82.3	82.3	76.3	69.4	64.0	57.6		(32)
(33)		WB	50.4	50.8	52.9	56.7	63.2	69.4	71.1	71.6	67.6	63.5	58.5	52.8		(33)
(34)		MCDB	53.2	54.4	57.5	63.2	71.2	79.3	81.4	81.2	75.0	68.2	62.6	56.1		(34)
(35)	Mean Daily Temperature Range	MDBR	10.6	11.1	11.5	11.9	12.6	12.8	13.3	13.3	12.3	12.1	11.3	10.7		(35)
(36)		5% DB	11.6	12.4	13.1	14.8	15.0	14.1	15.5	14.9	13.5	13.3	12.4	11.8		(36)
(37)		MCWBR	9.0	8.9	9.1	8.8	8.7	9.1	9.5	9.8	10.0	9.5	9.0	9.2		(37)
(38)		5% WB	9.7	10.1	11.4	13.2	13.7	13.5	13.8	13.8	12.6	11.6	10.4	9.0		(38)
(39)		MCWBR	8.6	8.7	9.1	8.9	9.3	9.8	10.5	11.0	10.3	9.5	8.9	8.5		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.335	0.360	0.403	0.453	0.440	0.427	0.425	0.433	0.413	0.389	0.361	0.334		(40)
(41)		taud	2.437	2.353	2.244	2.126	2.229	2.316	2.317	2.286	2.335	2.376	2.402	2.442		(41)
(42)		Ebn at Noon	253	264	265	259	266	269	268	262	259	250	239	242		(42)
(43)		Edh at Noon	24	31	39	47	44	40	40	40	35	30	25	23		(43)
(44)	All-Sky Solar Radiation	RadAvg	522	759	1173	1574	1959	2236	2298	2026	1453	982	600	473		(44)
(45)		RadStd	56	116	157	161	148	136	121	123	93	91	60	82		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (20 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	N/A	-171	+194	N/A	(47)

Nomenclature: See separate page