

MOSTAR, Bosnia and Herzegovina

WMO: 146480

Lat: **43.3481N**Lon: **17.7939E**Elev: **341**StdP: **14.52**Time Zone: **1.00 (EUC)**Period: **01-16**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.6	30.5	4.5	7.0	33.2	8.8	8.7	36.2	25.8	37.4	21.7	38.8	8.7	340	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.9	99.5	72.9	96.5	72.4	93.4	71.6	75.4	93.3	74.1	91.6	72.9	89.6	3.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.2	112.7	82.0	68.8	107.3	81.4	67.4	102.1	80.6	39.0	93.3	37.8	91.1	36.7	90.1	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.9	16.0	13.5	24.0	102.8	3.5	3.5	21.4	105.3	19.4	107.4	17.4	109.3	14.8	111.8		
(5)			20.5	78.4	3.5	1.6	18.0	79.5	16.0	80.4	14.1	81.3	11.6	82.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.1	43.0	44.7	51.3	59.6	67.2	74.9	80.3	81.1	70.7	61.7	52.2	44.6
	DBStd	14.76	5.78	7.12	6.85	5.39	6.28	7.36	5.82	5.27	6.60	6.08	6.70	6.38
	HDD50	709	225	169	68	4	0	0	0	0	0	3	53	187
	HDD65	3079	681	567	425	173	49	12	0	0	21	134	385	632
	CDD50	4742	9	21	109	292	532	748	938	965	622	366	120	20
	CDD65	1636	0	0	0	11	116	310	473	500	193	32	1	0
	CDH74	16285	0	0	4	120	978	3125	5213	5347	1352	145	1	0
	CDH80	7766	0	0	0	18	299	1442	2707	2788	497	15	0	0
(14) Wind	WSAvg	4.5	5.0	5.5	5.3	4.1	4.2	3.9	4.2	4.2	4.3	4.1	4.0	5.7
(15) Precipitation	PrecAvg	64.3	7.0	6.3	5.7	5.4	3.9	3.1	2.0	3.2	4.3	6.3	8.8	8.1
	PrecMax	79.1	15.6	14.6	14.5	10.9	11.0	5.4	9.7	8.8	7.5	18.2	17.1	16.9
	PrecMin	46.9	0.0	0.4	0.9	1.3	0.4	0.4	0.3	0.0	0.2	0.0	2.2	2.7
	PrecStd	8.5	3.9	3.4	3.3	2.2	2.6	1.4	2.0	2.3	2.2	5.1	4.1	3.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.3	65.6	73.4	82.5	91.0	99.1	103.3	103.9	95.6	82.2	71.4	62.0
		MCWB	52.3	52.7	55.1	61.9	69.0	74.7	73.8	72.6	71.0	65.4	61.7	57.1
	2%	DB	56.4	60.7	69.8	77.2	86.9	95.6	99.5	100.0	90.7	77.9	67.5	58.9
		MCWB	51.0	50.4	53.5	58.3	67.4	73.5	73.0	72.3	69.4	63.6	58.6	54.7
	5%	DB	54.0	57.8	66.4	73.6	83.2	92.1	96.5	96.6	85.7	74.5	64.6	56.0
		MCWB	49.2	49.6	51.9	57.2	65.7	71.8	72.7	71.9	67.1	61.9	57.6	51.0
	10%	DB	51.6	54.8	62.3	70.3	79.7	88.5	93.0	93.3	81.6	71.2	61.6	53.6
		MCWB	47.0	48.0	50.4	55.2	63.6	70.4	71.6	71.2	65.2	60.8	55.1	48.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.8	56.6	57.5	63.1	70.4	77.3	76.6	76.5	73.2	68.2	63.3	58.2
		MCDB	57.3	60.7	66.8	78.7	86.6	94.3	95.3	94.9	89.4	74.5	67.2	61.0
	2%	WB	52.8	53.3	55.5	60.3	68.4	75.1	75.1	75.1	70.9	65.8	61.1	55.4
		MCDB	55.2	58.1	64.9	72.5	84.0	91.6	93.7	93.3	85.9	73.8	66.1	58.4
	5%	WB	50.4	51.2	53.8	58.5	66.8	73.2	74.0	73.7	69.2	64.2	58.8	52.8
		MCDB	53.0	55.3	62.6	69.0	81.0	89.0	91.5	91.7	81.3	71.7	63.3	55.2
	10%	WB	48.1	49.3	52.1	57.2	64.9	71.5	72.8	72.5	67.5	62.5	56.6	49.9
		MCDB	50.6	53.2	59.7	66.6	77.3	86.1	89.2	89.5	77.9	68.7	60.2	52.4
(35) Mean Daily Temperature Range	5% DB	MDBR	10.0	12.3	15.0	17.0	19.1	19.8	21.5	21.9	18.0	16.0	12.3	9.3
		MCDBR	12.6	17.9	22.9	24.3	24.5	24.5	26.2	26.5	23.7	20.8	15.2	10.1
		MCWBR	8.6	9.7	10.7	9.9	9.8	9.1	8.9	8.8	8.6	9.4	8.6	6.9
	5% WB	MCDBR	10.6	13.5	18.9	20.8	23.1	23.7	23.8	23.8	21.0	17.7	12.8	8.7
		MCWBR	8.5	9.0	10.0	9.2	9.9	9.6	9.3	9.3	9.4	9.4	8.3	7.1
(40) Clear-Sky Solar Irradiance	taub		0.326	0.352	0.399	0.448	0.443	0.434	0.431	0.436	0.410	0.384	0.352	0.325
	taud		2.406	2.314	2.220	2.118	2.189	2.263	2.268	2.250	2.309	2.367	2.402	2.423
	Ebn at Noon		253	264	264	259	265	267	266	260	258	250	240	242
	Edh at Noon		25	32	40	47	45	42	42	41	36	30	25	22
(44) All-Sky Solar Radiation	RadAvg		486	713	1092	1432	1787	2050	2120	1889	1349	916	551	431
	RadStd		57	91	150	171	147	141	139	153	98	91	69	76

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	-171	+194	N/A

Nomenclature: See separate page