

MOSTAR, Bosnia and Herzegovina

WMO: 146480

Lat: 43.3481N

Lon: 17.7939E

Elev: 104

StdP: 100.08

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.4	-0.8	-15.3	1.0	0.7	-12.9	1.2	2.3	11.5	3.0	9.7	3.8	3.9	340	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.2	37.5	22.7	35.8	22.5	34.1	22.0	24.1	34.1	23.4	33.1	22.7	32.0	1.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.2	16.1	27.8	20.5	15.3	27.4	19.7	14.6	27.0	72.8	34.0	70.1	32.8	67.4	32.3	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.2	6.0	DB	-4.5	39.3	2.0	1.9	-5.9	40.7	-7.0	41.9	-8.1	43.0	-9.5	44.4	(4)
(5)			WB	-6.4	25.8	1.9	0.9	-7.8	26.4	-8.9	26.9	-10.0	27.4	-11.3	28.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	6.1	7.1	10.7	15.3	19.5	23.9	26.8	27.3	21.5	16.5	11.2	7.0	(6)	
	DBStd	8.20	3.21	3.96	3.80	3.00	3.49	4.09	3.23	2.93	3.66	3.38	3.72	3.55	(7)	
	HDD10.0	394	125	94	38	2	0	0	0	0	0	2	29	104	(8)	
	HDD18.3	1711	378	315	236	96	27	7	0	0	12	74	214	351	(9)	
	CDD10.0	2634	5	12	61	162	296	416	521	536	346	203	67	11	(10)	
	CDD18.3	909	0	0	0	6	64	172	263	278	107	18	1	0	(11)	
	CDH23.3	9047	0	0	2	67	543	1736	2896	2971	751	81	1	0	(12)	
	CDH26.7	4314	0	0	0	10	166	801	1504	1549	276	8	0	0	(13)	
(14) Wind	WSAvg	2.0	2.2	2.5	2.4	1.9	1.9	1.7	1.9	1.9	1.9	1.9	1.8	2.5	(14)	
(15) Precipitation	PrecAvg	1632	177	160	145	138	98	80	51	82	110	161	224	206	(15)	
	PrecMax	2010	395	370	369	276	280	138	246	224	191	463	434	429	(16)	
	PrecMin	1191	0	10	24	33	11	10	7	0	4	0	57	68	(17)	
	PrecStd	215	100	87	84	57	67	35	52	59	56	130	104	95	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.2	18.6	23.0	28.0	32.8	37.3	39.6	40.0	35.3	27.9	21.9	16.7	(19)	
		MCWB	11.3	11.5	12.8	16.6	20.5	23.7	23.2	22.5	21.7	18.5	16.5	13.9	(20)	
	2%	DB	13.5	16.0	21.0	25.1	30.5	35.3	37.5	37.8	32.6	25.5	19.7	14.9	(21)	
		MCWB	10.6	10.2	11.9	14.6	19.7	23.0	22.8	22.4	20.8	17.6	14.8	12.6	(22)	
	5%	DB	12.2	14.3	19.1	23.1	28.5	33.4	35.8	35.9	29.8	23.6	18.1	13.3	(23)	
		MCWB	9.6	9.8	11.1	14.0	18.7	22.1	22.6	22.2	19.5	16.6	14.2	10.6	(24)	
	10%	DB	10.9	12.7	16.8	21.3	26.5	31.4	33.9	34.1	27.6	21.8	16.4	12.0	(25)	
		MCWB	8.3	8.9	10.2	12.9	17.6	21.3	22.0	21.8	18.5	16.0	12.8	9.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.6	13.7	14.2	17.3	21.3	25.2	24.8	24.7	22.9	20.1	17.4	14.5	(27)	
		MCDB	14.0	15.9	19.3	25.9	30.4	34.6	35.1	34.9	31.9	23.6	19.5	16.1	(28)	
	2%	WB	11.6	11.8	13.0	15.7	20.2	23.9	24.0	23.9	21.6	18.8	16.2	13.0	(29)	
		MCDB	12.9	14.5	18.3	22.5	28.9	33.1	34.3	34.0	30.0	23.2	19.0	14.7	(30)	
	5%	WB	10.2	10.7	12.1	14.7	19.3	22.9	23.3	23.2	20.7	17.9	14.9	11.6	(31)	
		MCDB	11.7	12.9	17.0	20.6	27.2	31.7	33.0	33.2	27.4	22.1	17.4	12.9	(32)	
	10%	WB	9.0	9.6	11.2	14.0	18.3	21.9	22.7	22.5	19.7	17.0	13.7	9.9	(33)	
		MCDB	10.3	11.8	15.4	19.2	25.2	30.0	31.8	31.9	25.5	20.4	15.7	11.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.6	6.8	8.3	9.5	10.6	11.0	11.9	12.2	10.0	8.9	6.8	5.2	(35)	
		MCDBR	7.0	10.0	12.7	13.5	13.6	13.6	14.5	14.7	13.2	11.5	8.5	5.6	(36)	
	5% WB	MCWBR	4.8	5.4	6.0	5.5	5.4	5.1	4.9	4.9	4.8	5.2	4.8	3.8	(37)	
		MCWBR	5.9	7.5	10.5	11.6	12.8	13.2	13.2	13.2	11.7	9.9	7.1	4.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.326	0.352	0.399	0.448	0.443	0.434	0.431	0.436	0.410	0.384	0.352	0.325	(40)	
		taud	2.406	2.314	2.220	2.118	2.189	2.263	2.268	2.250	2.309	2.367	2.402	2.423	(41)	
	Ebn at Noon	Ebn at Noon	798	833	833	818	834	841	839	821	814	787	757	762	(42)	
		Edh at Noon	78	100	125	149	143	133	131	130	113	95	78	70	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.53	2.25	3.44	4.51	5.63	6.46	6.68	5.95	4.25	2.89	1.74	1.36	(44)	
	RadStd	RadStd	0.18	0.29	0.47	0.54	0.46	0.44	0.44	0.48	0.31	0.29	0.22	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)		+0.47	N/A	N/A	N/A	N/A	N/A	N/A	-95	+108	N/A

Nomenclature: See separate page