

BJELASNICA, Bosnia and HerzegovinaWMO: **146520**Lat: **43.7037N**Lon: **18.2573E**Elev: **2067**StdP: **78.84**Time Zone: **1.00 (EUC)**Period: **99-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.7	-16.3	-23.6	0.6	-14.0	-20.4	0.8	-11.5	37.8	-6.1	35.9	-10.3	18.3	0	1.115

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.7	19.5	12.7	18.1	12.3	16.8	11.8	14.7	17.5	13.7	16.5	12.7	15.4	5.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.5	12.5	16.4	12.5	11.6	15.3	11.5	10.9	14.3	48.7	17.6	45.5	16.5	42.6	15.5	18.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.5	30.1	26.6	DB	-21.2	21.5	2.7	1.4	-23.2	22.5	-24.8	23.4	-26.3	24.2	-28.3	25.2	
(5)			WB	-21.5	15.9	2.6	1.4	-23.4	16.9	-24.9	17.8	-26.4	18.6	-28.3	19.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.0	-6.5	-6.5	-4.1	0.3	4.7	8.7	11.1	11.6	6.6	3.5	-0.7	-4.9
	DBStd	7.73	4.82	4.78	4.25	3.70	4.18	4.33	3.76	3.70	4.06	4.48	4.77	4.94
	HDD10.0	3111	513	463	438	292	171	73	32	26	116	205	322	461
	HDD18.3	5954	771	697	696	542	424	288	224	209	352	461	571	719
	CDD10.0	199	0	0	0	0	6	36	67	76	13	2	1	0
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	10.8	14.2	13.9	13.8	11.2	10.2	8.3	7.7	6.8	8.8	9.4	12.6	13.4
(15) Precipitation	PrecAvg	1267	95	98	96	102	97	99	84	76	115	138	145	117
	PrecMax	1860	203	208	188	200	182	259	152	183	287	270	287	250
	PrecMin	904	19	21	10	24	43	15	16	11	47	31	31	14
	PrecStd	253	52	54	54	45	40	58	41	55	63	64	60	65
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.9	5.0	5.6	11.4	15.9	19.5	21.1	21.7	17.9	13.4	11.4	5.5
		MCWB	0.1	-0.6	2.9	6.6	8.5	12.6	13.0	13.2	12.5	7.7	3.2	0.4
	2%	DB	2.0	2.5	3.4	8.9	13.5	17.6	19.5	19.7	15.4	11.8	8.4	4.0
		MCWB	-0.9	-0.1	0.7	5.1	8.2	12.0	12.7	12.8	11.0	7.1	3.2	-0.1
	5%	DB	0.4	0.2	2.0	7.0	11.9	16.2	18.1	18.1	13.6	10.4	6.3	2.6
		MCWB	-0.9	-1.1	0.0	3.9	7.7	11.5	12.5	12.3	9.9	6.4	2.6	-0.3
	10%	DB	-0.7	-0.8	0.9	5.1	10.4	14.9	16.6	16.8	11.8	8.8	4.8	1.1
		MCWB	-1.6	-1.6	-0.4	2.6	6.9	10.7	11.8	11.7	9.1	5.9	2.5	-0.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.5	2.0	3.1	7.6	11.3	14.7	16.1	16.0	13.6	9.2	6.4	3.3
		MCDB	2.9	3.6	5.1	10.5	14.1	17.1	19.0	19.5	17.0	11.8	7.6	3.4
	2%	WB	0.3	0.2	1.7	5.6	9.7	13.5	14.8	14.6	11.8	8.3	5.1	1.6
		MCDB	0.9	0.9	2.7	8.5	12.3	16.3	17.4	17.9	14.2	10.2	6.0	2.3
	5%	WB	-0.5	-0.6	0.6	4.0	8.5	12.2	13.7	13.6	10.5	7.5	4.1	0.5
		MCDB	0.1	-0.1	1.3	6.4	10.6	15.3	16.3	16.5	12.8	9.1	5.6	1.3
	10%	WB	-1.4	-1.6	-0.2	2.9	7.5	11.2	12.7	12.6	9.4	6.7	3.0	-0.3
		MCDB	-0.8	-1.0	0.5	4.6	9.5	14.2	15.3	15.3	11.3	8.1	4.2	0.7
(35) Mean Daily Temperature Range	5% DB	MDBR	3.7	3.7	3.4	3.6	4.4	4.7	4.9	4.7	4.0	3.7	3.6	3.9
		MCDBR	4.0	4.3	3.6	5.3	5.9	5.7	6.0	5.8	5.3	4.3	4.1	4.5
	5% WB	MCWBR	3.2	3.3	3.0	3.9	4.2	4.6	4.5	4.1	4.1	3.9	3.5	3.3
		MCWBR	3.4	3.7	3.4	4.9	5.4	5.6	5.4	5.3	5.0	3.9	3.6	3.5
(40) Clear-Sky Solar Irradiance	taub		0.248	0.267	0.298	0.334	0.333	0.328	0.328	0.329	0.312	0.291	0.267	0.248
		taud	2.511	2.452	2.434	2.373	2.400	2.435	2.423	2.418	2.469	2.541	2.561	2.532
	Ebn at Noon		912	943	947	931	937	939	935	925	919	902	879	879
		Edh at Noon	67	85	99	115	115	112	112	108	95	77	64	60
(44) All-Sky Solar Radiation	RadAvg		1.46	2.17	3.33	4.26	5.28	6.08	6.31	5.67	3.98	2.75	1.68	1.26
	RadStd		0.20	0.26	0.45	0.56	0.47	0.50	0.47	0.52	0.37	0.30	0.21	0.23

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)		+0.50	N/A	N/A	N/A	N/A	N/A	-95	+108	N/A

Nomenclature: See separate page