

RADAUTI, Romania

WMO: 150070

Lat: 47.8378N

Lon: 25.8906E

Elev: 1281

StdP: 14.03

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.6	6.8	-0.8	5.5	2.9	4.0	7.1	7.5	30.9	28.3	24.2	9.1	1.0	320	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.2	86.6	67.5	83.6	67.0	80.7	66.0	70.7	81.2	69.0	79.8	67.5	78.1	5.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.4	105.5	75.4	65.5	98.6	72.9	64.0	93.4	71.3	35.3	81.4	33.8	79.8	32.6	77.7	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.1	16.5	14.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	25.1	31.3	37.4	47.6	57.9	64.7	66.4	66.7	58.5	48.0	38.4	31.0
	DBStd	16.41	9.48	10.03	8.93	8.66	6.18	5.49	4.90	5.60	7.56	7.79	8.50	10.13
	HDD50	2948	771	524	394	147	14	0	0	18	132	359	589	
	HDD65	6546	1236	943	855	523	229	73	43	50	214	528	798	1054
	CDD50	2160	0	1	4	74	259	440	510	518	273	70	11	0
	CDD65	282	0	0	0	0	8	63	88	103	20	0	0	0
	CDH74	3094	0	0	0	15	149	617	807	1191	298	17	0	0
	CDH80	820	0	0	0	0	19	113	205	415	66	2	0	0
(14) Wind	WSAvg	5.0	4.6	4.8	5.6	5.4	5.1	5.5	5.2	4.8	4.7	4.5	5.0	5.1
(15) Precipitation	PrecAvg	24.1	0.9	0.9	1.1	2.0	3.2	4.2	3.9	2.8	1.8	1.3	1.1	0.9
	PrecMax	34.4	3.1	2.3	3.0	3.8	7.0	10.6	8.1	7.6	5.6	3.9	2.2	2.8
	PrecMin	13.6	0.2	0.1	0.1	0.6	0.5	1.3	0.9	1.1	0.0	0.1	0.3	0.1
	PrecStd	4.5	0.6	0.6	0.7	0.9	1.6	2.1	1.7	1.5	1.5	0.9	0.6	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.0	57.8	67.1	76.0	81.9	85.8	89.2	91.4	86.6	76.1	65.5	58.4
		MCWB	44.3	47.5	51.6	57.7	62.0	69.2	68.0	68.7	65.3	59.0	54.5	48.0
	2%	DB	45.2	53.1	60.2	72.2	77.8	83.1	85.2	87.5	80.7	70.9	59.5	51.2
		MCWB	39.6	45.2	48.1	56.9	61.8	68.1	68.2	67.0	63.3	58.0	51.6	43.6
	5%	DB	40.9	48.3	55.1	67.9	74.6	80.7	81.6	84.7	77.0	66.0	54.6	47.7
		MCWB	36.4	41.7	45.8	54.0	60.6	67.0	67.0	66.8	62.1	55.7	48.8	41.9
	10%	DB	37.3	44.6	50.2	63.2	71.2	77.6	78.3	81.0	72.9	60.6	50.2	43.7
		MCWB	34.2	39.4	42.6	52.4	59.0	65.4	65.5	65.8	61.0	53.9	46.4	39.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.4	48.6	52.1	60.2	66.2	74.0	72.1	73.0	67.9	62.1	55.7	48.1
		MCDB	50.0	56.9	63.4	72.3	77.1	82.5	83.3	85.2	82.9	72.4	65.4	57.8
	2%	WB	40.1	44.9	48.8	57.7	64.0	70.6	69.8	70.4	65.6	59.3	52.4	44.4
		MCDB	44.5	52.2	58.2	70.1	73.6	79.1	81.3	81.9	77.5	68.6	58.9	50.3
	5%	WB	37.2	42.6	46.4	55.4	62.0	68.6	68.4	68.5	63.6	57.1	49.9	42.3
		MCDB	40.3	47.5	54.3	65.8	71.4	78.4	78.4	80.4	74.3	64.3	54.6	47.5
	10%	WB	34.9	40.0	44.0	53.0	60.2	66.6	67.1	66.9	61.8	54.6	47.1	39.9
		MCDB	37.4	43.9	49.4	62.4	68.3	75.7	76.2	78.5	71.1	60.5	50.2	43.6
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	15.0	16.7	18.8	20.0	19.3	20.1	22.2	19.8	18.3	12.8	12.8
		MCDBR	17.2	20.8	25.7	29.2	26.8	25.3	26.6	29.4	28.3	28.5	21.3	20.2
	5% WB	MCWBR	12.4	13.6	15.1	15.3	12.3	11.1	11.6	11.7	12.7	16.1	13.7	13.4
		MCDWR	16.1	19.7	24.2	27.1	22.6	21.9	22.5	25.9	25.4	25.4	20.2	19.2
(40) Clear-Sky Solar Irradiance	taub		0.308	0.339	0.380	0.442	0.417	0.415	0.442	0.450	0.402	0.365	0.334	0.307
		taud	2.303	2.242	2.209	2.085	2.233	2.274	2.205	2.178	2.267	2.351	2.379	2.354
	Ebn at Noon		239	256	262	256	269	270	259	251	252	244	228	225
		Edh at Noon	23	31	38	48	43	41	43	43	36	28	22	20
(44) All-Sky Solar Radiation	RadAvg		362	614	974	1351	1682	1780	1765	1607	1137	743	389	277
	RadStd		53	81	118	131	157	146	149	138	152	100	47	38

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)	+1.26	N/A	N/A	N/A	+1.66	N/A	N/A	-265	-380	+185	+61

Nomenclature: See separate page