

RADAUTI, Romania

WMO: 150070

Lat: 47.8378N

Lon: 25.8906E

Elev: 391

StdP: 96.72

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.9	-14.0	-18.2	0.8	-16.1	-15.5	1.0	-13.6	13.8	-2.0	10.8	-12.7	0.5	320	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.3	30.3	19.7	28.7	19.5	27.1	18.9	21.5	27.3	20.5	26.5	19.7	25.6	2.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.6	15.1	24.1	18.6	14.1	22.7	17.8	13.3	21.8	64.2	27.4	60.7	26.5	58.1	25.4	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.4	6.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	-3.8	-0.4	3.0	8.6	14.4	18.1	19.1	19.3	14.7	8.9	3.6	-0.6		
	DBStd	9.12	5.27	5.57	4.96	4.81	3.43	3.05	2.72	3.11	4.20	4.33	4.72	5.63		
	HDD10.0	1638	428	291	219	82	8	0	0	0	10	73	199	327		
	HDD18.3	3637	687	524	475	291	127	41	24	28	119	293	443	586		
	CDD10.0	1200	0	1	2	41	144	244	283	288	152	39	6	0		
	CDD18.3	157	0	0	0	0	4	35	49	57	11	0	0	0		
	CDH23.3	1719	0	0	0	8	83	343	448	662	166	9	0	0		
	CDH26.7	456	0	0	0	0	11	63	114	231	37	1	0	0		
(14) Wind	WSAvg	2.2	2.1	2.2	2.5	2.4	2.3	2.4	2.3	2.2	2.1	2.0	2.2	2.3		
(15) Precipitation	PrecAvg	612	23	24	28	52	82	106	99	70	45	32	28	24		
	PrecMax	875	78	58	76	97	178	268	206	193	142	100	57	70		
	PrecMin	346	5	2	2	15	13	32	24	27	0	3	7	2		
	PrecStd	115	16	15	18	23	41	54	42	37	37	24	15	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	14.3	19.5	24.5	27.7	29.9	31.8	33.0	30.3	24.5	18.6	14.7		
		MCWB	6.8	8.6	10.9	14.3	16.7	20.7	20.0	20.4	18.5	15.0	12.5	8.9		
	2%	DB	7.3	11.7	15.7	22.3	25.5	28.4	29.6	30.9	27.0	21.6	15.3	10.7		
		MCWB	4.2	7.3	9.0	13.8	16.5	20.1	20.1	19.4	17.4	14.4	10.9	6.4		
	5%	DB	4.9	9.1	12.8	20.0	23.7	27.1	27.6	29.3	25.0	18.9	12.5	8.7		
		MCWB	2.4	5.4	7.7	12.2	15.9	19.4	19.5	19.4	16.7	13.2	9.3	5.5		
	10%	DB	3.0	7.0	10.1	17.3	21.8	25.3	25.7	27.2	22.7	15.9	10.1	6.5		
		MCWB	1.2	4.1	5.9	11.3	15.0	18.5	18.6	18.8	16.1	12.2	8.0	4.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	9.2	11.2	15.7	19.0	23.3	22.3	22.8	19.9	16.7	13.2	8.9		
		MCDB	10.0	13.8	17.4	22.4	25.1	28.1	28.5	29.6	28.3	22.4	18.6	14.3		
	2%	WB	4.5	7.2	9.4	14.3	17.8	21.5	21.0	21.3	18.7	15.2	11.3	6.9		
		MCDB	7.0	11.2	14.6	21.2	23.1	26.2	27.4	27.7	25.3	20.3	14.9	10.1		
	5%	WB	2.9	5.9	8.0	13.0	16.7	20.3	20.2	20.3	17.6	13.9	9.9	5.7		
		MCDB	4.6	8.6	12.4	18.8	21.9	25.8	25.8	26.9	23.5	18.0	12.5	8.6		
	10%	WB	1.6	4.5	6.6	11.6	15.7	19.2	19.5	19.4	16.6	12.6	8.4	4.4		
		MCDB	3.0	6.6	9.7	16.9	20.2	24.3	24.6	25.8	21.7	15.8	10.1	6.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	8.3	9.3	10.5	11.1	10.7	11.2	12.3	11.0	10.2	7.1	7.1		
		MCDBR	9.6	11.5	14.3	16.2	14.9	14.1	14.8	16.3	15.7	15.8	11.8	11.2		
		MCWBR	6.9	7.6	8.4	8.5	6.8	6.1	6.4	6.5	7.1	8.9	7.6	7.5		
		MCDBR	8.9	11.0	13.5	15.1	12.6	12.2	12.5	14.4	14.1	14.1	11.2	10.7		
	5% WB	MCWBR	6.5	7.3	8.2	8.3	6.4	6.1	5.9	6.2	6.6	8.1	7.3	7.2		
(40) Clear-Sky Solar Irradiance	taub		0.308	0.339	0.380	0.442	0.417	0.415	0.442	0.450	0.402	0.365	0.334	0.307		
	taud		2.303	2.242	2.209	2.085	2.233	2.274	2.205	2.178	2.267	2.351	2.379	2.354		
	Ebn at Noon		754	806	827	807	847	850	818	792	796	769	719	710		
	Edh at Noon		74	99	120	150	134	130	137	135	112	88	70	63		
(44) All-Sky Solar Radiation	RadAvg		1.14	1.94	3.07	4.26	5.30	5.61	5.57	5.07	3.58	2.34	1.23	0.87		
	RadStd		0.17	0.26	0.37	0.41	0.50	0.46	0.47	0.44	0.48	0.32	0.15	0.12		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	+0.70	N/A	N/A	+0.92	N/A	N/A	-147	-211	+103	+34

Nomenclature: See separate page