

BAIA MARE TAUTII MAGHERAUS, Romania

WMO: 150140

Lat: 47.6608N

Lon: 23.4733E

Elev: 615

StdP: 14.37

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.6	14.1	3.6	6.8	11.4	9.0	8.9	16.9	15.9	36.1	13.3	34.5	2.9	90	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.3	90.2	70.5	87.6	69.9	84.4	68.0	73.3	86.2	71.5	83.3	69.8	81.3	5.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.5	110.9	79.0	67.6	103.9	77.1	66.0	98.2	75.2	37.3	85.8	35.6	83.5	34.1	81.5	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	12.9	11.2	DB	0.9	94.2	7.1	3.2	-4.2	96.5	-8.4	98.4	-12.4	100.2	-17.6	102.5	(4)
(5)			WB	0.2	76.9	7.1	2.4	-4.9	78.6	-9.1	80.0	-13.1	81.4	-18.3	83.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	30.0	34.3	42.0	52.9	61.2	67.6	70.2	70.5	61.2	51.8	42.7	33.1
	DBStd	16.07	8.73	9.13	8.10	7.47	6.50	6.15	5.71	5.79	7.02	7.71	8.57	8.04
	HDD50	2234	620	441	263	55	4	0	0	0	3	74	249	525
	HDD65	5476	1084	860	712	366	151	44	18	16	154	412	669	990
	CDD50	2797	0	1	16	141	352	529	626	636	338	129	29	0
	CDD65	565	0	0	0	3	34	123	178	186	39	2	0	0
	CDH74	5588	0	0	0	46	380	1156	1709	1848	426	23	0	0
	CDH80	1905	0	0	0	6	67	353	634	733	111	1	0	0
Wind	WSAvg	4.7	3.8	4.5	5.3	5.6	5.1	5.1	5.0	4.9	4.6	4.2	4.2	3.9
Precipitation	PrecAvg	32.1	2.3	2.0	2.0	2.2	3.0	3.8	3.4	2.3	3.0	2.8	2.6	2.9
	PrecMax	45.4	4.2	5.0	7.0	3.7	7.3	7.1	7.2	4.3	6.5	6.7	5.0	5.4
	PrecMin	22.2	0.9	0.8	0.5	0.6	1.1	0.6	0.6	0.4	0.7	0.4	0.1	0.2
	PrecStd	5.6	0.7	1.0	1.6	0.8	1.5	1.6	2.0	1.1	1.5	1.7	1.3	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.5	58.8	67.9	79.2	85.6	89.9	94.7	95.1	88.8	77.0	67.7	54.0
		MCWB	47.1	49.1	53.8	60.5	67.0	71.2	72.2	70.5	66.6	61.2	55.9	47.4
	2%	DB	47.5	53.4	62.8	73.7	82.0	87.4	89.9	91.2	82.6	73.3	62.7	50.0
		MCWB	44.6	45.8	50.6	57.5	64.7	70.3	71.9	69.9	63.8	60.1	53.7	46.2
	5%	DB	44.3	48.9	58.7	70.6	78.6	84.2	86.4	87.7	78.9	68.4	58.9	46.5
		MCWB	42.1	44.1	48.8	55.8	63.5	67.7	70.2	69.4	63.8	58.4	52.1	44.0
	10%	DB	40.9	45.7	54.1	66.7	75.0	80.8	83.7	84.0	74.9	64.3	55.2	43.3
		MCWB	39.3	42.4	46.4	54.2	61.7	67.2	69.0	68.3	62.6	56.8	50.2	41.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	49.7	55.0	61.7	70.1	75.1	75.5	75.3	69.3	63.9	57.9	49.8
		MCDB	50.5	57.0	64.5	75.1	81.7	86.3	87.5	87.5	81.7	72.0	63.2	52.1
	2%	WB	45.2	46.9	52.0	59.6	66.7	72.4	73.3	72.7	66.7	61.4	55.5	46.5
		MCDB	46.7	51.3	60.3	71.3	77.4	83.4	86.9	85.4	77.8	69.2	61.1	48.9
	5%	WB	42.1	44.7	49.8	57.4	64.4	70.1	71.5	70.7	64.9	59.6	53.0	44.2
		MCDB	43.6	48.0	56.5	67.0	74.7	80.7	84.0	82.9	75.4	66.7	58.1	46.1
	10%	WB	39.3	42.5	47.6	55.3	62.6	68.0	69.8	69.0	63.3	57.6	50.7	41.8
		MCDB	40.6	45.3	53.3	64.1	72.7	77.9	81.1	81.0	72.8	63.4	54.5	43.4
Mean Daily Temperature Range	5% DB	MDBR	10.5	12.5	16.8	19.9	20.3	20.5	21.1	22.3	19.9	18.6	13.9	9.2
		MCDBR	12.6	17.0	23.7	25.4	26.3	24.7	25.8	27.2	26.5	24.6	19.3	13.6
		MCWBR	9.6	11.4	13.4	12.3	12.3	10.9	11.1	10.1	11.3	13.2	11.8	10.0
	5% WB	MCDBR	11.1	15.3	20.6	22.1	23.5	22.3	24.3	23.9	23.1	21.1	16.7	12.2
		MCWBR	9.0	10.6	12.4	11.5	11.9	11.2	11.4	10.5	11.2	12.0	10.7	9.5
Clear-Sky Solar Irradiance	taub	0.329	0.358	0.403	0.457	0.439	0.436	0.458	0.458	0.418	0.386	0.358	0.330	
	taud	2.246	2.195	2.149	2.053	2.171	2.218	2.168	2.163	2.232	2.288	2.304	2.296	
	Ebn at Noon	229	248	254	252	262	264	255	249	247	236	217	214	
	Edh at Noon	25	33	41	49	45	43	45	43	37	30	24	22	
All-Sky Solar Radiation	RadAvg	324	584	973	1408	1722	1875	1841	1689	1174	751	410	239	
	RadStd	50	89	144	148	179	123	163	151	146	98	59	38	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.82	N/A	N/A	+2.56	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (47 neighbors)		+1.26	N/A	N/A	+1.94	N/A	N/A	-245	-376	+216	+99

Nomenclature: See separate page