

SUCEAVA, Romania

WMO: 150230

Lat: 47.6323N

Lon: 26.2407E

Elev: 1159

StdP: 14.09

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 3.6	(c) 8.7	(d) -0.4	(e) 5.6	(f) 5.3	(g) 4.9	(h) 7.4	(i) 10.0	(j) 28.8	(k) 16.2	(l) 25.7	(m) 22.1	(n) 6.2	(o) 340	(p) 0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 17.5	(c) 86.3	(d) 68.4	(e) 83.5	(f) 67.8	(g) 80.6	(h) 66.7	(i) 71.9	(j) 80.5	(k) 70.0	(l) 79.7	(m) 68.3	(n) 77.3	(o) 8.2	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.3	112.6	76.9	66.6	102.3	74.0	64.8	95.9	72.1	36.4	80.2	34.8	79.4	33.4	77.0	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 22.8	(b) 20.1	(c) 17.8	(e) -3.0	(f) 90.5	(g) 6.3	(h) 3.8	(i) -7.6	(j) 93.3	(k) -11.3	(l) 95.5	(m) -14.8	(n) 97.6	(o) -19.4	(p) 100.4		
(a) 22.8	(b) 20.1	(c) 17.8	(e) -3.1	(f) 75.0	(g) 6.3	(h) 2.8	(i) -7.6	(j) 77.0	(k) -11.3	(l) 78.6	(m) -14.9	(n) 80.1	(o) -19.5	(p) 82.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.5	26.2	29.9	37.6	48.9	59.0	65.1	68.6	67.7	59.3	48.8	39.4	30.4		
	DBStd	16.82	9.92	10.07	9.16	7.73	6.46	5.74	5.45	5.67	6.75	7.93	8.29	9.46		
	HDD50	2881	738	563	392	110	10	0	0	0	9	119	331	609		
	HDD65	6393	1203	982	850	486	203	70	27	38	190	502	768	1074		
	CDD50	2331	0	0	7	75	288	453	576	547	290	82	13	0		
	CDD65	370	0	0	0	1	17	73	138	120	20	1	0	0		
	CDH74	2897	0	0	0	21	159	534	1011	972	190	10	0	0		
	CDH80	731	0	0	0	2	17	96	279	299	37	1	0	0		
	WSAvg	7.9	8.0	8.1	8.8	8.8	8.3	7.9	7.4	7.1	7.3	7.5	7.9	7.9		
	PrecAvg	24.9	0.8	0.9	1.2	2.0	3.0	3.8	4.1	3.0	2.1	1.8	1.1	1.0		
(15) Precipitation	PrecMax	35.6	1.6	1.7	2.6	5.2	6.6	9.5	10.6	8.9	6.0	6.4	2.6	2.4		
	PrecMin	15.8	0.2	0.3	0.4	0.5	0.9	1.3	0.6	1.1	0.4	0.3	0.1	0.1		
	PrecStd	5.4	0.4	0.4	0.6	1.1	1.6	1.9	2.6	2.0	1.3	1.3	0.7	0.6		
	PrecStd	5.4	0.4	0.4	0.6	1.1	1.6	1.9	2.6	2.0	1.3	1.3	0.7	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	50.9	56.6	65.8	77.1	82.2	86.2	91.1	91.1	84.2	74.7	64.6	54.0			
	0.4% MCWB	44.7	48.6	50.9	59.3	65.9	68.2	70.3	69.5	64.4	60.2	53.7	46.0			
	2% DB	45.2	50.1	59.3	70.3	78.4	82.7	86.3	86.4	78.8	69.5	58.9	48.4			
	2% MCWB	41.0	44.1	48.9	55.9	62.6	68.2	69.1	68.0	63.3	58.3	51.5	43.4			
	5% DB	41.4	45.0	54.5	66.2	75.1	80.2	82.8	82.8	75.3	64.5	54.0	44.7			
	5% MCWB	38.2	41.1	46.1	53.3	61.1	66.7	68.4	67.2	61.6	56.1	49.2	41.0			
	10% DB	38.8	41.8	50.2	62.3	71.4	76.9	80.0	79.6	71.4	60.7	51.0	41.3			
	10% MCWB	36.3	38.8	43.8	51.6	59.4	65.2	67.6	66.5	60.1	54.3	47.4	38.6			
	0.4% WB	45.6	48.7	53.0	60.4	69.7	74.3	74.7	74.4	67.7	63.0	55.2	47.4			
	0.4% MCDB	50.1	55.6	62.6	74.3	78.2	79.7	85.0	83.2	80.0	70.5	62.0	52.5			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	41.4	44.5	49.7	57.4	64.8	70.7	71.8	71.6	65.1	59.5	52.7	44.1			
	2% MCDB	44.2	49.3	57.6	68.3	73.4	78.6	80.8	80.1	74.7	66.2	57.6	47.6			
	5% WB	38.8	41.5	47.1	54.9	62.6	68.3	70.0	69.5	63.3	57.2	50.3	41.3			
	5% MCDB	40.9	44.3	53.5	64.0	71.4	77.0	79.9	79.8	71.8	63.8	53.7	44.1			
	10% WB	36.1	39.0	44.5	52.4	60.7	66.5	68.3	67.5	61.6	54.9	47.9	39.0			
	10% MCDB	38.1	41.3	49.4	60.5	69.0	75.3	77.3	76.3	69.0	59.8	50.8	41.3			
(35) Mean Daily Temperature Range	MDBR	10.2	11.1	14.1	17.1	17.8	17.0	17.5	18.0	16.7	15.4	11.7	10.2			
	5% DB	14.1	16.3	22.1	24.2	23.6	22.1	22.3	24.2	23.8	22.1	17.5	15.0			
	5% MCWBR	10.7	11.8	13.2	12.7	11.7	10.6	10.3	10.1	10.9	12.7	11.7	11.2			
	5% WB	13.0	15.0	20.1	22.0	20.5	19.1	19.4	21.1	20.4	19.6	16.1	13.8			
	5% MCWBR	10.3	11.3	12.8	12.5	11.6	10.6	10.4	10.6	10.8	12.1	11.3	10.7			
	5% WB	13.0	15.0	20.1	22.0	20.5	19.1	19.4	21.1	20.4	19.6	16.1	13.8			
(40) Clear-Sky Solar Irradiance	taub	0.310	0.341	0.379	0.439	0.414	0.412	0.439	0.446	0.401	0.365	0.335	0.308			
	taud	2.311	2.252	2.225	2.093	2.241	2.279	2.210	2.184	2.268	2.352	2.378	2.354			
	Ebn at Noon	239	256	264	257	270	271	261	252	253	245	229	226			
	Edh at Noon	23	31	37	47	42	41	43	43	36	28	22	20			
(44) All-Sky Solar Radiation	RadAvg	368	614	990	1384	1744	1839	1830	1659	1166	753	385	282			
	RadStd	54	86	111	126	150	154	143	131	145	97	40	38			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)		+1.24	N/A	N/A	+1.62	N/A	N/A	-266	-380	+185	+58

Nomenclature: See separate page