

IEZER, Romania

WMO: 150330

Lat: 47.6025N

Lon: 24.6489E

Elev: 5862

StdP: 11.84

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.4	4.1	-21.1	2.1	18.9	-12.9	3.4	14.6	39.2	20.0	31.0	24.1	5.4	70	0.745

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	66.6	57.5	64.1	55.9	61.8	54.6	59.3	65.1	57.6	62.9	55.9	61.1	6.5	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.0	86.4	62.7	55.2	80.8	61.2	53.4	75.7	59.4	28.8	65.5	27.5	63.1	26.2	61.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.6	22.7	18.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.0	19.8	22.9	25.5	33.6	43.7	49.8	50.8	51.9	44.0	37.5	29.8	22.3		
	DBStd	13.94	8.64	8.15	8.40	9.29	6.30	6.42	6.29	8.38	9.19	9.24	8.09			
	HDD50	5439	937	759	759	493	212	82	68	55	217	393	605	859		
	HDD65	10573	1402	1179	1224	942	661	456	440	406	631	853	1055	1324		
	CDD50	343	0	0	0	1	16	77	93	114	37	5	0	0		
	CDD65	1	0	0	0	0	0	0	0	1	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	6.2	7.2	8.1	7.0	7.0	5.9	5.1	4.7	4.5	5.8	5.2	6.8	7.8		
	PrecAvg	43.4	2.2	2.3	3.0	3.3	4.8	5.1	5.4	3.7	4.1	3.9	3.2	2.9		
(15) Precipitation	PrecMax	60.3	4.2	5.0	7.8	5.7	8.6	7.5	10.1	6.0	8.0	9.6	6.9	5.4		
	PrecMin	36.1	0.9	0.9	0.2	1.4	2.2	1.8	1.2	1.3	1.6	0.3	0.0	1.1		
	PrecStd	6.2	0.9	1.0	1.7	1.0	1.6	1.5	2.4	1.3	1.6	2.5	1.7	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.6	46.6	47.6	55.5	61.7	68.7	68.6	71.0	67.8	58.4	51.1	45.0		
		MCWB	29.3	38.3	39.2	44.6	48.8	57.4	58.5	59.8	57.9	43.5	41.3	35.9		
	2%	DB	35.9	38.9	42.8	51.2	58.3	65.4	65.7	66.1	62.2	54.7	47.7	38.2		
		MCWB	30.5	32.4	36.3	42.6	49.1	55.9	57.6	57.2	53.9	42.7	38.4	32.6		
	5%	DB	33.6	35.7	39.9	48.6	55.0	62.5	63.2	63.4	58.7	52.0	44.4	35.2		
		MCWB	29.6	30.6	34.4	41.2	47.8	54.4	56.5	55.9	51.7	42.2	38.1	32.4		
	10%	DB	31.4	33.2	37.2	45.9	52.5	59.4	60.6	60.6	55.5	49.3	41.7	32.5		
		MCWB	28.1	29.4	32.6	39.8	46.7	52.8	55.2	54.3	49.9	41.4	36.5	29.9		
	0.4%	WB	34.4	38.0	40.6	46.6	53.5	61.3	60.9	61.7	58.7	48.2	45.1	37.7		
		MCDB	35.1	43.8	46.3	52.8	58.5	66.0	66.1	68.6	67.0	52.2	49.2	40.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	32.6	34.0	38.0	44.4	50.8	57.7	59.2	59.0	55.0	46.5	41.8	35.0		
		MCDB	34.1	37.8	41.8	50.0	55.6	63.5	64.2	65.2	61.5	51.7	44.8	37.4		
	5%	WB	30.7	32.1	35.7	42.6	49.0	55.6	57.5	57.3	52.7	44.8	39.3	33.1		
		MCDB	32.7	34.1	39.2	47.7	53.9	61.8	62.1	62.5	58.0	50.2	43.2	35.4		
	10%	WB	28.4	30.4	33.4	40.3	47.1	53.6	55.6	55.6	50.8	42.7	37.3	31.0		
		MCDB	31.1	32.6	36.6	45.9	52.0	58.8	60.1	60.5	55.6	47.9	40.7	32.9		
	5% DB	MDBR	9.2	9.3	10.3	10.1	10.4	11.2	10.3	10.8	9.6	10.3	8.9	8.7		
		MCDBR	10.6	10.7	12.2	11.1	13.7	14.5	13.5	14.1	13.7	13.3	9.9	9.5		
		MCWBR	8.1	7.9	8.9	7.8	9.8	10.8	10.5	10.3	9.4	9.4	6.9	7.5		
		MCWBR	9.0	10.0	11.4	10.0	12.8	12.5	11.6	13.0	12.2	11.6	9.2	9.3		
(40) Clear-Sky Solar Irradiance	taub		0.243	0.264	0.297	0.338	0.328	0.327	0.342	0.343	0.314	0.290	0.269	0.246		
		taud	2.404	2.368	2.374	2.369	2.435	2.452	2.403	2.400	2.470	2.532	2.534	2.472		
	Ebn at Noon		274	290	294	290	297	297	290	285	285	278	263	261		
		Edh at Noon	21	27	32	36	35	34	36	34	29	23	19	17		
(44) All-Sky Solar Radiation	RadAvg		375	635	979	1315	1611	1710	1702	1572	1124	758	424	290		
	RadStd		56	75	129	133	166	141	162	147	150	106	61	40		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)		+1.35	N/A	N/A	+1.98	N/A	N/A	-304	-437	+196	+54

Nomenclature: See separate page