

SUPURU DE JOS, Romania

WMO: 150440

Lat: 47.4550N

Lon: 22.7836E

Elev: 526

StdP: 14.42

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 9.5	(c) 14.9	(d) 2.1	(e) 6.2	(f) 12.3	(g) 7.5	(h) 8.2	(i) 17.9	(j) 21.5	(k) 38.6	(l) 18.9	(m) 34.8	(n) 2.8	(o) 200	(p) 0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 24.5	(c) 90.4	(d) 69.2	(e) 87.5	(f) 68.5	(g) 84.6	(h) 67.0	(i) 71.5	(j) 86.9	(k) 70.0	(l) 84.5	(m) 68.6	(n) 82.4	(o) 4.9	(p) 120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.4	99.1	78.1	64.8	93.5	76.8	63.4	89.2	75.4	35.5	87.3	34.2	84.3	33.0	82.0	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.7	(b) 16.0	(c) 13.6	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 18.7	(b) 16.0	(c) 13.6	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	30.3	36.4	42.2	51.5	60.8	67.4	69.0	70.5	61.0	51.7	42.0	33.9		
	DBStd	15.52	8.35	7.71	7.27	8.01	6.06	5.72	5.35	5.88	7.16	7.63	8.47	8.07		
	HDD50	2171	611	382	255	80	4	0	0	0	3	74	262	500		
	HDD65	5459	1076	801	706	408	156	41	23	19	163	412	691	963		
	CDD50	2702	0	1	13	124	338	522	589	634	331	128	21	1		
	CDD65	519	0	0	0	2	25	113	148	189	41	1	0	0		
	CDH74	5659	0	0	0	49	331	1085	1552	2131	478	33	0	0		
	CDH80	1946	0	0	0	3	52	314	520	917	140	0	0	0		
(14) Wind	WSAvg	4.8	4.8	5.7	5.4	5.7	4.8	4.4	4.0	4.0	4.2	4.4	4.4	5.3		
(15) Precipitation	PrecAvg	25.0	1.3	1.2	1.4	1.8	2.6	3.5	3.1	2.0	2.4	2.0	1.8	1.8		
	PrecMax	37.0	2.4	3.4	4.4	3.1	6.3	6.6	6.8	4.0	6.1	4.0	3.1	3.7		
	PrecMin	15.4	0.5	0.4	0.2	0.3	0.7	0.6	0.6	0.2	0.4	0.2	0.0	0.3		
	PrecStd	5.0	0.5	0.7	1.0	0.7	1.5	1.6	1.8	1.1	1.3	1.2	0.8	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.1	57.5	69.6	78.9	84.7	89.8	91.8	95.3	89.6	77.7	64.2	55.9		
		MCWB	44.7	47.6	53.5	59.3	62.0	70.4	70.0	69.8	67.0	60.1	53.8	49.6		
	2%	DB	46.6	53.6	62.2	74.3	81.1	86.7	88.6	91.9	83.5	73.8	60.3	49.7		
		MCWB	41.9	45.7	49.3	56.9	62.3	69.7	69.2	68.9	64.4	58.2	52.0	44.7		
	5%	DB	43.8	50.8	57.6	70.3	77.8	83.7	85.4	88.8	79.4	69.6	57.0	46.7		
		MCWB	40.2	44.4	47.5	55.2	61.2	68.0	68.0	68.6	63.3	56.6	50.2	42.6		
	10%	DB	40.8	47.7	53.7	66.3	74.3	80.2	82.6	85.4	74.8	64.3	53.5	43.3		
		MCWB	37.4	42.2	45.1	52.2	59.4	66.5	66.9	67.8	61.3	54.2	48.0	39.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.2	49.5	55.5	61.4	66.2	74.3	72.4	72.8	68.8	61.4	54.9	49.7		
		MCDB	49.7	55.9	69.1	76.1	79.5	86.9	86.4	89.8	86.7	74.3	62.6	55.7		
	2%	WB	42.4	46.8	51.1	58.9	64.6	71.3	71.0	71.3	65.8	59.6	52.7	45.6		
		MCDB	45.8	52.5	60.8	72.6	77.2	84.4	85.6	88.4	81.0	71.5	59.2	49.7		
	5%	WB	40.5	44.9	48.4	56.5	62.8	69.5	69.5	69.7	64.2	57.7	50.8	42.9		
		MCDB	44.1	50.4	56.3	68.7	75.2	81.3	83.4	85.5	77.7	67.5	56.9	46.8		
	10%	WB	37.6	42.8	46.0	53.9	61.0	67.7	67.9	68.3	62.3	55.3	48.7	40.4		
		MCDB	40.6	47.2	53.0	64.1	71.9	78.7	80.5	83.8	73.8	63.3	53.7	43.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	13.3	17.9	21.4	21.3	20.8	22.5	24.5	21.0	20.1	13.5	8.7		
		MCDBR	11.7	17.2	24.4	28.1	27.1	25.4	27.0	29.8	28.2	28.4	17.4	12.0		
		MCWBR	8.3	11.6	13.9	13.7	12.4	11.4	11.3	11.0	12.0	15.1	11.0	8.7		
	5% WB	MCDBR	10.9	15.1	22.3	25.7	24.2	22.8	24.1	27.1	25.7	26.0	16.6	11.4		
		MCWBR	8.2	10.7	14.0	13.3	12.2	11.0	10.8	11.1	11.2	14.3	10.5	8.6		
(40) Clear-Sky Solar Irradiance	taub		0.327	0.354	0.393	0.443	0.427	0.427	0.446	0.445	0.409	0.379	0.353	0.327		
	taud		2.308	2.268	2.208	2.100	2.210	2.242	2.199	2.197	2.263	2.321	2.341	2.343		
	Ebn at Noon		233	252	259	256	266	266	259	253	251	239	221	218		
	Edh at Noon		24	31	38	47	43	43	44	42	36	29	23	21		
(44) All-Sky Solar Radiation	RadAvg		333	594	987	1417	1734	1891	1859	1703	1185	765	421	247		
	RadStd		49	89	146	148	177	125	162	151	142	96	60	39		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		+1.22	N/A	N/A	+1.89	N/A	N/A	-229	-344	+196	+99

Nomenclature: See separate page