

SUPURU DE JOS, Romania

WMO: 150440

Lat: 47.4550N

Lon: 22.7836E

Elev: 160

StdP: 99.42

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.5	-9.5	-16.6	0.9	-11.0	-13.6	1.2	-7.8	9.6	3.6	8.5	1.5	1.2	200	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.6	32.4	20.7	30.8	20.3	29.2	19.5	21.9	30.5	21.1	29.1	20.3	28.0	2.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	14.2	25.6	18.2	13.4	24.9	17.5	12.7	24.1	64.8	30.7	61.8	29.0	59.0	27.8	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.3	7.1	6.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	-1.0	2.4	5.7	10.8	16.0	19.7	20.6	21.4	16.1	11.0	5.5	1.1
	DBStd	8.62	4.64	4.28	4.04	4.45	3.36	3.18	2.97	3.27	3.98	4.24	4.71	4.48
	HDD10.0	1206	339	212	142	44	2	0	0	0	2	41	146	278
	HDD18.3	3033	598	445	392	227	87	23	13	11	91	229	384	535
	CDD10.0	1501	0	1	7	69	188	290	327	352	184	71	12	1
	CDD18.3	288	0	0	0	1	14	63	82	105	23	1	0	0
	CDH23.3	3144	0	0	0	27	184	603	862	1184	266	18	0	0
	CDH26.7	1081	0	0	0	2	29	174	289	509	78	0	0	0
Wind	WSAvg	2.1	2.2	2.6	2.4	2.6	2.2	2.0	1.8	1.8	1.9	2.0	2.0	2.4
Precipitation	PrecAvg	636	32	31	35	46	67	89	80	52	60	51	45	46
	PrecMax	939	60	86	113	78	160	168	172	101	154	102	78	94
	PrecMin	392	12	10	6	8	18	15	15	5	11	5	0	8
	PrecStd	128	13	19	26	17	38	40	45	27	33	30	20	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	14.2	20.9	26.0	29.3	32.1	33.2	35.2	32.0	25.4	17.9	13.3
		MCWB	7.1	8.7	12.0	15.1	16.7	21.3	21.1	21.0	19.4	15.6	12.1	9.8
	2%	DB	8.1	12.0	16.8	23.5	27.3	30.4	31.4	33.3	28.6	23.2	15.7	9.8
		MCWB	5.5	7.6	9.6	13.8	16.8	20.9	20.7	20.5	18.0	14.5	11.1	7.0
	5%	DB	6.5	10.4	14.2	21.3	25.5	28.7	29.7	31.5	26.3	20.9	13.9	8.2
		MCWB	4.6	6.9	8.6	12.9	16.2	20.0	20.0	20.3	17.4	13.7	10.1	5.9
	10%	DB	4.9	8.7	12.1	19.1	23.5	26.8	28.1	29.7	23.8	17.9	11.9	6.3
		MCWB	3.0	5.7	7.3	11.2	15.2	19.2	19.4	19.9	16.3	12.3	8.9	4.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.3	9.7	13.1	16.3	19.0	23.5	22.5	22.7	20.4	16.3	12.7	9.8
		MCDB	9.8	13.3	20.6	24.5	26.4	30.5	30.2	32.1	30.4	23.5	17.0	13.1
	2%	WB	5.8	8.2	10.6	14.9	18.1	21.8	21.6	21.8	18.8	15.3	11.5	7.5
		MCDB	7.7	11.4	16.0	22.6	25.1	29.1	29.8	31.3	27.2	22.0	15.1	9.8
	5%	WB	4.7	7.2	9.1	13.6	17.1	20.8	20.8	20.9	17.9	14.3	10.5	6.0
		MCDB	6.7	10.2	13.5	20.4	24.0	27.4	28.5	29.7	25.4	19.7	13.8	8.2
	10%	WB	3.1	6.0	7.8	12.2	16.1	19.8	19.9	20.2	16.8	13.0	9.3	4.7
		MCDB	4.8	8.4	11.7	17.8	22.2	25.9	26.9	28.8	23.2	17.4	12.1	6.6
Mean Daily Temperature Range	5% DB	MDBR	5.8	7.4	10.0	11.9	11.8	11.5	12.5	13.6	11.7	11.2	7.5	4.9
		MCDBR	6.5	9.5	13.6	15.6	15.0	14.1	15.0	16.5	15.7	15.8	9.7	6.7
		MCWBR	4.6	6.4	7.7	7.6	6.9	6.3	6.3	6.1	6.7	8.4	6.1	4.8
	5% WB	MCDBR	6.0	8.4	12.4	14.3	13.5	12.7	13.4	15.1	14.3	14.4	9.2	6.4
		MCWBR	4.6	5.9	7.8	7.4	6.8	6.1	6.0	6.2	6.2	7.9	5.8	4.8
Clear-Sky Solar Irradiance	taub	0.327	0.354	0.393	0.443	0.427	0.427	0.446	0.445	0.409	0.379	0.353	0.327	
	taud	2.308	2.268	2.208	2.100	2.210	2.242	2.199	2.197	2.263	2.321	2.341	2.343	
	Ebn at Noon	735	794	816	808	839	839	816	798	791	755	697	687	
	Edh at Noon	76	98	121	148	137	134	138	133	113	92	74	66	
All-Sky Solar Radiation	RadAvg	1.05	1.87	3.11	4.47	5.47	5.96	5.86	5.37	3.74	2.41	1.33	0.78	
	RadStd	0.15	0.28	0.46	0.47	0.56	0.39	0.51	0.48	0.45	0.30	0.19	0.12	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)	+0.68	N/A	N/A	N/A	+1.05	N/A	N/A	-127	-191	+109	+55

Nomenclature: See separate page