

TARGU NEAMT, Romania

WMO: 150730

Lat: 47.2122N

Lon: 26.3792E

Elev: 388

StdP: 96.75

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.5	-11.5	-15.6	1.0	-11.9	-13.7	1.2	-10.2	12.2	-1.3	9.5	-1.7	1.6	330	0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	30.4	19.9	28.9	19.6	27.3	19.0	21.6	27.3	20.7	26.5	20.0	25.6	2.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.8	15.3	24.0	18.8	14.3	23.1	18.0	13.5	22.4	64.5	27.1	61.6	26.7	58.8	25.8	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.2	6.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	-2.2	0.1	3.9	9.1	14.9	19.1	19.9	19.9	15.3	9.3	4.1	0.1		
	DBStd	9.00	5.10	5.27	4.97	4.69	3.54	3.13	2.85	3.11	4.09	4.27	4.73	5.27		
	HDD10.0	1494	379	278	196	72	6	0	0	0	5	64	185	309		
	HDD18.3	3434	638	511	447	277	113	29	17	21	108	280	428	566		
	CDD10.0	1313	0	1	7	46	159	272	306	308	163	42	8	2		
	CDD18.3	211	0	0	0	1	7	51	65	71	16	0	0	0		
	CDH23.3	1862	0	0	0	9	88	417	514	651	176	6	0	0		
	CDH26.7	489	0	0	0	1	14	83	138	208	46	0	0	0		
(14) Wind	WSAvg	2.2	2.3	2.3	2.5	2.8	2.4	2.1	1.9	1.9	2.0	1.9	2.2	2.2		
(15) Precipitation	PrecAvg	620	19	20	31	54	76	103	104	64	51	47	29	28		
	PrecMax	922	43	36	64	115	169	220	268	152	128	186	59	61		
	PrecMin	399	2	6	7	8	18	31	23	19	10	4	1	3		
	PrecStd	140	11	8	13	28	43	54	60	37	30	35	15	18		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	15.1	20.2	24.4	28.3	30.3	32.1	32.7	30.0	23.9	18.8	15.3		
		MCWB	6.8	9.0	12.2	14.8	17.6	20.9	20.2	20.7	17.9	14.8	12.4	9.8		
	2%	DB	8.7	12.1	16.9	22.5	25.6	28.8	29.9	30.6	27.5	21.3	15.5	12.0		
		MCWB	5.0	7.7	10.0	14.0	16.8	20.3	20.2	19.4	18.2	14.4	10.6	7.8		
	5%	DB	6.6	9.1	13.7	20.1	23.9	27.3	28.0	29.0	25.0	18.6	13.0	9.5		
		MCWB	3.9	5.9	8.5	12.5	16.5	19.2	19.7	19.3	16.7	12.9	10.0	6.1		
	10%	DB	4.7	6.9	11.0	17.3	21.9	25.9	26.1	27.2	22.7	16.0	10.8	7.1		
		MCWB	2.3	4.3	7.0	11.4	15.4	18.7	19.1	19.1	16.3	11.8	8.5	4.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	9.8	12.6	15.8	20.6	23.7	22.3	22.8	21.0	16.1	13.0	10.5		
		MCDB	11.0	14.5	18.6	22.7	26.4	28.6	28.7	29.2	25.6	21.7	17.6	14.6		
	2%	WB	5.5	7.8	10.6	14.5	18.4	21.3	21.2	21.4	19.1	14.9	11.4	8.2		
		MCDB	8.1	11.8	16.1	21.4	23.4	27.0	27.1	27.2	25.3	20.2	14.7	11.5		
	5%	WB	4.1	6.2	8.8	13.2	17.2	20.4	20.4	20.5	17.9	13.8	10.2	6.4		
		MCDB	6.0	8.9	12.5	18.8	21.9	26.0	26.1	26.4	23.4	17.8	12.6	9.5		
	10%	WB	2.6	4.8	7.4	12.0	16.1	19.3	19.6	19.6	16.8	12.5	8.8	4.8		
		MCDB	4.3	6.6	10.6	16.8	20.7	24.6	24.8	25.4	21.8	15.9	10.8	7.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.5	7.2	8.4	9.7	10.1	10.0	10.1	10.9	10.1	9.3	7.1	6.3		
		MCDBR	9.8	10.7	13.1	14.9	13.1	12.8	13.2	14.1	14.2	14.0	11.1	10.0		
	5% WB	MCWBR	6.9	7.1	7.6	7.7	5.9	5.5	5.5	5.4	5.8	7.6	6.8	6.5		
		MCWBR	9.9	10.0	12.5	13.8	11.5	12.0	11.4	12.2	12.7	12.8	10.0	9.8		
(40) Clear-Sky Solar Irradiance	taub		0.307	0.336	0.375	0.435	0.410	0.408	0.434	0.441	0.396	0.361	0.332	0.306		
		taud	2.341	2.280	2.246	2.114	2.257	2.295	2.229	2.203	2.291	2.377	2.402	2.375		
	Ebn at Noon		769	817	839	817	855	857	827	802	807	782	734	725		
		Edh at Noon	73	96	116	146	131	127	134	132	111	87	70	64		
(44) All-Sky Solar Radiation	RadAvg		1.21	1.98	3.17	4.39	5.58	5.87	5.88	5.33	3.76	2.42	1.26	0.94		
	RadStd		0.17	0.27	0.34	0.39	0.47	0.51	0.46	0.41	0.43	0.30	0.12	0.12		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (46 neighbors)	+0.67	N/A	N/A	+0.80	N/A	N/A	-142	-202	+98	+31

Nomenclature: See separate page