

DEJ, Romania

WMO: 150830

Lat: 47.1281N

Lon: 23.8989E

Elev: 765

StdP: 14.29

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 5.4	(c) 10.7	(d) 1.0	(e) 6.0	(f) 8.2	(g) 6.0	(h) 7.7	(i) 13.2	(j) 11.7	(k) 34.6	(l) 9.8	(m) 32.2	(n) 1.8	(o) 230	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 24.5	(c) 89.3	(d) 69.6	(e) 86.6	(f) 68.9	(g) 83.5	(h) 67.6	(i) 72.0	(j) 85.2	(k) 70.5	(l) 82.8	(m) 69.1	(n) 80.4	(o) 3.9	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.9	105.3	76.6	66.4	100.2	75.6	65.2	95.8	73.7	36.2	85.7	34.9	83.1	33.6	80.6	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.7	(b) 9.6	(c) 8.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 11.7	(b) 9.6	(c) 8.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.2	27.3	33.8	40.9	50.9	60.6	67.0	68.4	69.6	60.5	50.3	41.0	31.5
	DBStd	16.05	8.42	7.22	6.98	8.26	5.84	5.33	5.11	5.26	7.42	6.98	7.30	7.45
	HDD50	2482	705	454	286	91	4	0	0	0	7	85	278	572
	HDD65	5844	1170	874	746	424	159	40	27	20	172	456	719	1037
	CDD50	2565	0	0	5	117	331	509	571	607	321	94	10	0
	CDD65	451	0	0	0	0	21	98	133	162	37	0	0	0
	CDH74	4798	0	0	0	51	308	998	1243	1736	454	8	0	0
	CDH80	1532	0	0	0	2	47	285	376	703	119	0	0	0
Wind	WSAvg	3.0	2.3	2.7	3.2	3.8	3.4	3.5	3.3	3.2	3.2	2.6	2.5	2.6
Precipitation	PrecAvg	24.5	1.4	1.2	1.4	1.8	2.6	3.5	3.1	1.9	2.3	2.0	1.7	1.9
	PrecMax	32.4	2.7	2.8	4.4	2.9	5.6	6.4	5.9	4.6	4.8	4.2	3.9	3.7
	PrecMin	16.6	0.4	0.3	0.2	0.2	0.8	0.9	0.7	0.2	0.4	0.1	0.0	0.3
	PrecStd	4.6	0.6	0.6	1.1	0.7	1.2	1.3	1.5	1.0	1.2	1.2	0.9	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.1	56.1	68.3	78.8	84.3	90.0	90.6	94.4	88.7	75.2	63.4	48.0
		MCWB	41.9	48.0	52.9	58.4	64.4	71.5	71.2	71.0	66.9	60.5	54.4	44.7
	2%	DB	42.3	50.1	61.6	75.0	80.8	87.0	87.1	90.6	82.9	71.4	58.4	43.9
		MCWB	39.6	44.8	48.7	57.8	63.5	69.8	69.9	69.2	64.2	59.4	52.2	41.3
	5%	DB	39.0	46.4	56.4	70.8	77.4	83.4	84.3	87.5	79.2	66.8	55.1	41.3
		MCWB	36.6	41.7	45.9	55.2	62.0	68.4	69.0	68.8	63.3	57.7	50.4	39.6
	10%	DB	36.5	43.3	52.4	66.4	73.8	79.9	81.1	83.8	74.6	62.0	51.5	39.6
		MCWB	34.8	40.2	43.8	53.2	60.4	66.9	67.3	68.1	62.3	55.2	47.9	38.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	49.4	54.6	61.5	67.2	74.4	73.6	73.6	69.9	64.6	55.8	45.4
		MCDB	45.0	54.8	66.8	73.2	78.3	86.6	85.6	89.2	85.5	69.6	60.4	47.3
	2%	WB	39.9	45.6	50.1	58.9	65.1	71.7	71.8	71.4	66.5	60.7	53.4	41.9
		MCDB	42.4	49.1	59.6	71.8	76.0	83.8	83.7	86.4	76.8	68.6	57.7	43.7
	5%	WB	37.0	43.2	47.4	56.6	63.7	69.7	70.3	70.0	65.0	58.6	51.2	40.0
		MCDB	38.5	45.7	54.5	67.9	74.3	80.3	81.0	83.3	75.4	65.6	54.9	41.0
	10%	WB	35.2	40.4	45.2	54.5	62.1	67.9	68.6	68.7	63.2	56.0	48.6	38.4
		MCDB	36.2	42.9	51.1	63.7	71.3	78.2	78.4	81.3	72.5	61.1	51.4	39.4
Mean Daily Temperature Range	5% DB	MDBR	11.4	13.9	20.0	22.7	21.5	21.8	22.6	24.5	22.3	20.6	13.8	8.9
		MCDBR	12.4	19.3	27.3	30.4	27.9	27.4	27.3	30.7	29.6	29.0	20.2	10.7
		MCWBR	8.8	13.2	15.7	14.2	12.3	11.5	11.0	11.3	12.4	16.9	13.6	8.2
	5% WB	MCDBR	10.3	17.6	25.1	27.2	25.1	24.7	24.9	27.7	26.7	26.3	18.3	10.9
	MCWBR	7.6	12.3	14.9	13.1	11.6	11.0	10.6	10.9	12.1	15.7	12.2	8.5	
Clear-Sky Solar Irradiance	taub	0.316	0.344	0.385	0.432	0.417	0.413	0.434	0.436	0.398	0.369	0.344	0.317	
	taud	2.311	2.268	2.223	2.137	2.243	2.282	2.235	2.227	2.297	2.356	2.370	2.351	
	Ebn at Noon	239	257	262	260	270	271	263	256	256	245	227	225	
	Edh at Noon	24	31	38	45	42	41	43	41	35	28	23	21	
All-Sky Solar Radiation	RadAvg	366	627	996	1378	1685	1829	1804	1660	1172	783	439	279	
	RadStd	53	82	138	141	167	140	161	152	141	100	61	40	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (58 neighbors)		+1.33	N/A	N/A	+1.78	N/A	N/A	-284	-412	+187	+52

Nomenclature: See separate page