

DEJ, Romania

WMO: 150830

Lat: 47.1281N

Lon: 23.8989E

Elev: 233

StdP: 98.55

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.8	-11.9	-17.2	0.9	-13.2	-14.4	1.1	-10.5	5.2	1.4	4.4	0.1	0.8	230	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.6	31.9	20.9	30.3	20.5	28.6	19.8	22.2	29.5	21.4	28.2	20.6	26.9	1.8	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.9	15.0	24.8	19.1	14.3	24.2	18.4	13.7	23.2	66.2	29.8	63.3	28.4	60.3	27.0	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.2	4.3	3.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	-2.6	1.0	5.0	10.5	15.9	19.4	20.2	20.9	15.8	10.2	5.0	-0.3
	DBStd	8.91	4.68	4.01	3.88	4.59	3.25	2.96	2.84	2.92	4.12	3.88	4.06	4.14
	HDD10.0	1379	392	252	159	51	2	0	0	0	4	47	154	318
	HDD18.3	3247	650	486	414	236	88	22	15	11	96	253	399	576
	CDD10.0	1425	0	0	3	65	184	283	317	337	178	52	6	0
	CDD18.3	251	0	0	0	0	12	54	74	90	21	0	0	0
	CDH23.3	2666	0	0	0	28	171	554	691	964	252	4	0	0
	CDH26.7	851	0	0	0	1	26	158	209	391	66	0	0	0
Wind	WSAvg	1.3	1.0	1.2	1.4	1.7	1.5	1.6	1.5	1.4	1.4	1.2	1.1	1.1
Precipitation	PrecAvg	623	36	30	36	46	66	88	78	48	59	51	44	47
	PrecMax	824	69	71	113	74	143	162	150	118	122	107	100	95
	PrecMin	422	11	8	5	6	21	24	18	6	9	3	0	7
	PrecStd	116	16	16	27	19	31	34	37	26	30	31	22	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.4	13.4	20.2	26.0	29.1	32.2	32.6	34.6	31.5	24.0	17.4	8.9
		MCWB	5.5	8.9	11.6	14.7	18.0	22.0	21.8	21.7	19.4	15.8	12.4	7.1
	2%	DB	5.7	10.1	16.4	23.9	27.1	30.5	30.6	32.5	28.3	21.9	14.7	6.6
		MCWB	4.2	7.1	9.3	14.3	17.5	21.0	21.1	20.7	17.9	15.2	11.2	5.2
	5%	DB	3.9	8.0	13.5	21.5	25.2	28.6	29.0	30.8	26.2	19.3	12.8	5.2
		MCWB	2.5	5.4	7.7	12.9	16.7	20.2	20.5	20.4	17.4	14.3	10.2	4.2
	10%	DB	2.5	6.3	11.3	19.1	23.2	26.6	27.3	28.8	23.7	16.7	10.8	4.2
		MCWB	1.6	4.6	6.5	11.8	15.8	19.4	19.6	20.0	16.8	12.9	8.8	3.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	9.7	12.6	16.4	19.6	23.6	23.1	23.1	21.0	18.1	13.2	7.5
		MCDB	7.2	12.7	19.3	22.9	25.7	30.3	29.8	31.8	29.7	20.9	15.8	8.5
	2%	WB	4.4	7.6	10.0	14.9	18.4	22.0	22.1	21.9	19.2	15.9	11.9	5.5
		MCDB	5.8	9.5	15.3	22.1	24.5	28.8	28.7	30.2	24.9	20.3	14.3	6.5
	5%	WB	2.8	6.2	8.5	13.7	17.6	20.9	21.3	21.1	18.3	14.8	10.7	4.4
		MCDB	3.6	7.6	12.5	19.9	23.5	26.8	27.2	28.5	24.1	18.7	12.7	5.0
	10%	WB	1.8	4.7	7.4	12.5	16.7	19.9	20.3	20.4	17.4	13.3	9.2	3.6
		MCDB	2.3	6.0	10.6	17.6	21.8	25.7	25.8	27.4	22.5	16.2	10.8	4.1
Mean Daily Temperature Range	5% DB	MDBR	6.3	7.7	11.1	12.6	11.9	12.1	12.5	13.6	12.4	11.4	7.7	5.0
		MCDBR	6.9	10.7	15.2	16.9	15.5	15.2	15.2	17.1	16.4	16.1	11.2	5.9
		MCWBR	4.9	7.3	8.7	7.9	6.8	6.4	6.1	6.3	6.9	9.4	7.5	4.6
	5% WB	MCDBR	5.7	9.8	13.9	15.1	13.9	13.7	13.8	15.4	14.8	14.6	10.2	6.0
MCWBR		4.2	6.9	8.3	7.3	6.5	6.1	5.9	6.0	6.7	8.7	6.8	4.7	
Clear-Sky Solar Irradiance	taub	0.316	0.344	0.385	0.432	0.417	0.413	0.434	0.436	0.398	0.369	0.344	0.317	
	taud	2.311	2.268	2.223	2.137	2.243	2.282	2.235	2.227	2.297	2.356	2.370	2.351	
	Ebn at Noon	754	809	827	821	850	853	828	808	806	772	717	708	
	Edh at Noon	76	98	119	143	133	129	134	129	110	89	72	66	
All-Sky Solar Radiation	RadAvg	1.15	1.98	3.14	4.34	5.31	5.76	5.69	5.23	3.70	2.47	1.38	0.88	
	RadStd	0.17	0.26	0.43	0.44	0.53	0.44	0.51	0.48	0.44	0.31	0.19	0.12	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (58 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.74	N/A	N/A	+0.99	N/A	N/A	-158	-229	+104	+29

Nomenclature: See separate page