

JOSENI, Romania

WMO: 151270

Lat: 46.7058N

Lon: 25.5125E

Elev: 2465

StdP: 13.43

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.5	(c) 0.4	(d) -6.8	(e) 4.2	(f) -3.6	(g) -2.2	(h) 5.3	(i) 1.4	(j) 22.7	(k) 20.6	(l) 21.1	(m) 23.6	(n) 0.8	(o) 110	(p) 0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 23.4	(c) 83.2	(d) 65.6	(e) 80.2	(f) 64.4	(g) 77.4	(h) 63.3	(i) 68.0	(j) 78.8	(k) 66.4	(l) 76.6	(m) 64.9	(n) 74.9	(o) 6.7	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 64.7	(b) 100.2	(c) 72.0	(d) 62.9	(e) 93.9	(f) 70.5	(g) 61.4	(h) 89.0	(i) 69.2	(j) 33.9	(k) 79.3	(l) 32.5	(m) 76.7	(n) 31.3	(o) 75.1	(p) 73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 17.6	(b) 15.2	(c) 13.2	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 17.6	(b) 15.2	(c) 13.2	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.1	21.0	25.8	35.2	44.4	54.2	61.0	62.5	63.1	54.1	45.0	35.9	26.1		
	DBStd	16.38	10.11	10.45	7.85	7.98	5.74	4.96	4.56	5.06	7.22	7.05	7.75	9.49		
	HDD50	3652	900	677	460	198	26	0	0	0	44	180	427	740		
	HDD65	7701	1365	1097	924	617	335	138	102	92	332	620	874	1205		
	CDD50	1509	0	0	1	31	157	331	387	408	166	25	3	0		
	CDD65	82	0	0	0	0	1	18	24	35	4	0	0	0		
	CDH74	1548	0	0	0	3	56	271	423	667	127	1	0	0		
	CDH80	307	0	0	0	0	2	38	88	160	19	0	0	0		
	WSAvg	3.9	3.4	3.6	4.6	5.1	4.2	3.9	4.2	3.8	4.0	3.6	3.2	3.7		
	PrecAvg	24.4	0.9	1.0	1.3	2.0	2.8	3.8	3.5	2.6	2.1	1.9	1.3	1.5		
	PrecMax	33.5	1.9	2.1	2.9	3.7	4.6	7.0	6.4	4.5	5.2	4.0	3.0	4.3		
(15) Precipitation	PrecMin	17.4	0.4	0.3	0.2	0.8	0.7	1.0	1.4	0.8	0.2	0.1	0.0	0.3		
	PrecStd	3.7	0.4	0.4	0.7	0.9	1.0	1.3	1.4	0.9	1.2	1.0	0.7	1.0		
	DB	44.2	52.4	63.4	73.7	79.0	84.3	86.4	88.8	82.0	71.1	59.1	48.2			
	MCWB	41.3	46.5	48.8	54.7	60.6	67.5	67.3	66.6	62.8	56.9	51.3	44.9			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	39.8	45.7	56.9	69.9	74.9	80.0	82.2	83.7	77.1	67.3	54.8	44.2			
	2% MCWB	37.6	41.7	46.1	54.1	59.5	65.3	66.5	64.5	60.5	55.5	49.7	41.6			
	5% DB	36.6	42.2	51.3	65.3	71.2	77.1	78.6	80.7	73.3	62.5	51.1	40.6			
	5% MCWB	34.9	39.4	43.4	52.0	58.3	64.0	65.4	64.2	59.2	53.7	46.6	38.5			
	10% DB	33.7	38.9	46.6	60.2	67.8	73.6	75.1	77.3	69.1	57.5	47.9	37.6			
	10% MCWB	32.4	36.5	40.5	49.4	57.1	62.8	63.4	63.3	58.1	51.7	44.5	35.7			
	0.4% WB	41.7	46.7	50.8	56.7	64.8	70.2	70.1	70.0	64.9	59.9	52.1	46.0			
	0.4% MCDB	44.1	52.8	62.1	70.4	73.4	80.5	80.9	82.1	78.6	66.8	57.6	46.9			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	38.0	42.2	46.9	54.9	62.0	67.5	68.0	67.2	62.3	56.7	50.0	41.8			
	2% MCDB	39.5	45.3	55.1	67.8	70.9	77.3	79.1	78.6	73.7	64.0	55.4	43.8			
	5% WB	35.5	39.5	44.1	53.0	59.7	65.7	66.4	65.7	60.6	54.4	47.7	38.8			
	5% MCDB	36.8	41.9	51.2	64.4	68.3	75.0	75.7	77.1	71.8	61.5	51.0	40.5			
	10% WB	32.7	36.7	41.5	50.5	57.8	63.9	64.7	64.3	58.6	51.8	44.9	35.8			
	10% MCDB	33.7	38.5	46.0	58.9	66.0	72.2	73.9	75.4	67.7	56.9	47.8	37.5			
	MDBR	13.2	15.5	17.8	21.6	22.1	22.0	23.4	25.8	22.7	21.6	13.8	10.6			
	5% DB	12.3	16.8	27.2	32.6	29.5	28.7	30.8	32.7	32.0	32.6	20.1	13.2			
(36) Mean Daily Temperature Range	MCWBR	10.5	13.6	17.5	17.8	16.1	14.8	15.6	15.3	15.9	20.2	14.7	11.1			
	MCDBR	11.4	17.0	26.2	29.7	26.7	25.8	27.1	28.6	29.7	29.2	18.9	13.8			
	MCWBR	9.8	13.4	17.0	16.4	15.6	14.4	14.5	14.2	14.9	18.8	14.3	11.2			
	MCDBR	9.8	13.4	17.0	16.4	15.6	14.4	14.5	14.2	14.9	18.8	14.3	11.2			
(40) Clear-Sky Solar Irradiance	taub	0.301	0.333	0.380	0.441	0.416	0.411	0.434	0.442	0.397	0.358	0.331	0.303			
	taud	2.303	2.227	2.175	2.061	2.211	2.263	2.203	2.175	2.266	2.366	2.376	2.346			
	Ebn at Noon	247	261	264	257	270	271	263	255	256	250	234	233			
	Edh at Noon	24	32	40	49	44	42	44	43	36	28	23	21			
(44) All-Sky Solar Radiation	RadAvg	404	673	1024	1371	1694	1827	1812	1667	1187	811	456	307			
	RadStd	55	74	122	135	157	153	155	150	137	101	59	39			

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (66 neighbors)		+1.26	N/A	N/A	+1.53	N/A	N/A	-284	-396	+149	+34

Nomenclature: See separate page