

VASLUI, Romania

WMO: 151540

Lat: 46.6461N

Lon: 27.7144E

Elev: 117

StdP: 99.92

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.0	-12.2	-17.0	0.9	-15.0	-14.4	1.1	-11.4	9.5	-5.0	8.5	-5.3	1.8	310	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	32.9	20.7	31.4	20.1	30.1	19.9	22.6	29.6	21.7	28.6	20.9	27.6	2.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.5	15.4	25.0	19.5	14.5	23.8	18.7	13.7	23.1	66.9	29.8	63.7	28.5	60.9	27.7	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	6.9	5.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	-3.1	0.9	4.8	10.6	16.6	20.6	21.7	21.7	16.9	10.5	5.3	-0.5
	DBStd	9.63	4.68	5.51	4.96	4.51	3.44	3.03	2.73	3.14	4.48	4.28	4.69	5.29
	HDD10.0	1408	406	257	168	49	3	0	0	0	2	46	153	325
	HDD18.3	3199	664	488	418	233	73	13	5	9	78	244	390	583
	CDD10.0	1612	0	1	9	67	208	319	363	363	209	61	13	0
	CDD18.3	361	0	0	0	1	19	81	110	113	36	1	0	0
	CDH23.3	4054	0	0	1	29	278	876	1136	1278	439	18	0	0
	CDH26.7	1504	0	0	0	2	63	299	431	563	144	1	0	0
Wind	WSAvg	2.2	2.4	2.5	2.5	2.8	2.2	2.3	2.0	2.0	2.0	2.0	2.4	2.1
Precipitation	PrecAvg	536	25	23	30	43	65	76	68	45	46	47	34	33
	PrecMax	719	55	68	62	100	178	165	167	110	139	194	85	114
	PrecMin	357	5	2	1	6	2	21	6	7	3	5	1	2
	PrecStd	105	16	17	16	21	43	36	38	29	36	39	23	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	16.6	21.2	26.2	31.0	33.1	34.4	35.3	32.2	25.6	19.9	12.7
		MCWB	6.2	11.2	12.0	15.6	17.7	23.0	21.0	21.2	18.9	17.3	13.6	8.9
	2%	DB	6.4	12.7	17.5	23.8	28.5	31.2	32.3	33.1	30.1	22.4	16.9	10.3
		MCWB	4.9	8.8	10.6	14.5	17.8	21.3	20.6	20.4	18.2	15.1	12.3	8.0
	5%	DB	4.6	9.6	14.9	21.5	26.5	30.1	30.8	31.7	28.0	20.1	13.9	8.2
		MCWB	3.2	6.5	8.8	13.4	17.4	20.6	20.4	19.7	17.2	13.9	11.0	6.6
	10%	DB	3.0	7.4	12.5	19.3	24.6	28.5	29.2	30.0	25.8	17.5	11.9	5.5
		MCWB	1.9	5.5	7.7	12.5	16.2	20.0	20.1	19.7	17.0	13.1	9.4	3.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	11.6	12.7	16.7	20.7	24.2	22.9	23.1	20.5	18.0	14.6	10.5
		MCDB	8.0	16.2	19.7	24.3	28.4	30.9	29.4	32.0	28.1	24.4	18.4	11.5
	2%	WB	5.1	8.6	10.9	15.3	19.1	23.0	22.0	22.2	19.3	16.1	12.9	8.3
		MCDB	6.3	12.0	17.1	21.9	26.0	29.3	29.4	29.8	26.4	20.7	16.6	9.9
	5%	WB	3.5	6.8	9.5	14.0	17.9	21.8	21.2	21.2	18.5	14.9	11.4	6.4
		MCDB	4.4	8.8	13.8	20.1	24.1	28.1	28.1	28.5	25.2	18.7	13.9	8.5
	10%	WB	2.1	5.6	8.1	12.9	17.0	20.7	20.6	20.4	17.7	13.6	9.8	4.2
		MCDB	2.8	7.3	11.6	18.5	22.8	26.8	27.1	27.3	24.1	16.9	11.7	5.4
Mean Daily Temperature Range	5% DB	MDBR	6.4	7.5	10.1	11.5	12.8	12.7	12.7	13.7	12.6	10.3	6.8	6.4
		MCDBR	8.5	11.6	14.4	16.2	16.1	14.9	15.6	17.0	16.8	14.8	11.2	9.7
		MCWBR	6.7	7.3	8.5	8.3	7.0	6.0	5.6	5.8	6.8	7.8	6.7	7.1
	5% WB	MCDBR	8.1	9.9	13.7	14.3	13.3	13.9	13.1	14.6	14.7	12.9	9.9	9.6
		MCWBR	6.4	6.6	8.3	7.7	6.3	6.1	5.1	5.4	6.0	7.0	6.3	7.1
Clear-Sky Solar Irradiance	taub	0.329	0.359	0.396	0.454	0.425	0.422	0.447	0.456	0.413	0.380	0.354	0.327	
	taud	2.261	2.225	2.192	2.060	2.222	2.265	2.203	2.168	2.247	2.319	2.327	2.302	
	Ebn at Noon	739	792	817	800	843	846	817	791	792	761	705	696	
	Edh at Noon	81	103	124	155	136	131	138	138	116	93	77	70	
All-Sky Solar Radiation	RadAvg	1.23	2.00	3.21	4.43	5.69	5.98	6.01	5.46	3.87	2.48	1.29	0.98	
	RadStd	0.18	0.27	0.31	0.40	0.49	0.52	0.47	0.39	0.41	0.28	0.13	0.12	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (40 neighbors)	+0.63	N/A	N/A	+0.71	N/A	N/A	-132	-182	+91	+32	

Nomenclature: See separate page