

BAISOARA, Romania

WMO: 151630

Lat: 46.5356N

Lon: 23.3103E

Elev: 4468

StdP: 12.47

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.9	10.6	-10.5	3.7	26.0	-4.2	5.2	21.4	27.6	26.2	22.4	25.6	3.2	320	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.1	73.7	61.3	71.2	59.8	68.7	58.8	63.6	71.4	61.8	69.0	60.4	67.1	4.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.8	94.1	66.7	59.1	88.4	65.1	57.5	83.5	64.5	31.4	72.1	30.0	69.2	28.9	67.1	69.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.1	16.2	13.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.5	26.2	29.1	32.7	40.5	50.1	56.4	58.2	59.2	50.6	44.5	34.7	27.4		
	DBStd	14.30	8.31	8.09	8.74	9.52	6.68	6.86	5.99	6.32	7.66	9.51	9.10	8.41		
	HDD50	3760	739	586	539	308	80	21	7	6	91	224	460	699		
	HDD65	8237	1204	1006	1001	735	462	265	222	199	434	636	909	1164		
	CDD50	1037	0	0	3	23	83	214	261	290	108	53	2	0		
	CDD65	39	0	0	0	0	1	8	11	18	1	0	0	0		
	CDH74	87	0	0	0	0	0	14	28	43	1	1	0	0		
	CDH80	4	0	0	0	0	0	0	2	2	0	0	0	0		
	WSAvg	4.2	4.0	4.8	4.7	4.5	4.1	4.2	4.1	3.7	4.3	3.6	4.5	4.4		
	PrecAvg	28.8	1.3	1.2	1.6	2.3	3.3	4.1	4.1	2.9	2.6	2.0	1.8	1.8		
(15) Precipitation	PrecMax	37.1	2.5	2.8	4.2	4.6	5.8	8.2	6.9	5.9	6.2	3.9	3.6	3.7		
	PrecMin	19.8	0.4	0.3	0.4	0.4	1.7	1.1	1.2	0.3	0.3	0.1	0.0	0.2		
	PrecStd	4.9	0.6	0.6	0.9	0.9	1.2	1.6	1.6	1.1	1.4	1.1	0.8	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.8	50.7	57.4	64.8	69.9	76.1	77.2	78.3	71.4	68.4	56.4	49.5		
		MCWB	34.6	39.7	44.1	50.6	55.1	62.6	63.0	64.6	57.6	52.3	45.9	38.8		
	2%	DB	42.2	46.4	51.8	60.6	65.5	72.4	72.4	73.7	66.8	63.9	52.2	44.8		
		MCWB	33.8	38.5	41.5	48.7	54.2	62.0	60.3	61.1	55.5	51.2	44.3	37.3		
	5%	DB	39.9	42.8	48.2	56.5	62.7	69.6	69.7	71.0	63.4	59.9	48.8	41.4		
		MCWB	33.1	36.0	39.0	46.2	52.9	60.0	60.3	60.1	54.1	48.5	42.5	36.0		
	10%	DB	37.3	39.6	44.7	52.9	59.4	66.6	66.9	68.1	60.5	56.8	46.0	38.8		
		MCWB	32.3	34.7	37.2	44.2	51.3	58.6	58.5	59.3	52.9	47.7	41.0	34.9		
	0.4%	WB	37.8	43.6	45.7	52.8	57.4	65.6	64.7	65.7	58.5	54.9	48.0	41.8		
		MCDB	42.3	47.6	56.0	62.1	66.5	72.7	73.0	74.8	67.8	63.2	52.7	46.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	36.2	39.3	42.7	49.9	55.4	63.1	62.8	63.6	56.7	52.5	45.7	39.9		
		MCDB	40.0	44.5	50.4	59.2	64.1	71.2	69.6	72.1	65.0	60.7	50.6	43.4		
	5%	WB	34.5	37.3	40.3	47.7	53.7	61.1	61.2	61.6	55.3	50.7	43.9	37.4		
		MCDB	38.3	41.4	46.8	55.5	61.5	68.6	67.4	69.0	62.4	59.2	48.3	40.0		
	10%	WB	32.8	35.7	37.9	45.4	52.0	59.4	59.8	60.0	53.8	48.6	42.0	35.5		
		MCDB	36.2	39.5	43.7	52.4	58.7	65.8	65.6	67.1	60.0	55.4	46.0	38.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.0	10.3	11.4	12.3	12.0	12.4	12.3	12.1	11.2	11.6	9.7	9.4		
		MCDBR	11.1	13.4	14.8	16.4	15.4	15.9	15.2	15.1	14.5	15.3	11.3	10.4		
		MCWBR	7.4	8.3	9.3	9.7	9.2	10.1	10.1	9.4	8.7	10.2	7.6	7.0		
		MCDBR	10.4	12.2	14.3	15.1	13.6	15.5	14.2	14.6	13.6	14.2	10.0	8.9		
	5% WB	MCWBR	7.5	8.4	9.4	9.2	9.2	10.4	9.9	9.5	8.4	9.7	7.7	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.273	0.296	0.333	0.374	0.364	0.360	0.374	0.379	0.347	0.321	0.298	0.275		
	taud		2.398	2.362	2.336	2.258	2.332	2.361	2.318	2.306	2.381	2.450	2.468	2.435		
	Ebn at Noon		264	279	283	279	286	287	280	274	274	266	252	250		
	Edh at Noon		22	28	34	40	39	38	39	38	32	26	21	19		
(44) All-Sky Solar Radiation	RadAvg		381	634	1000	1377	1662	1835	1796	1659	1179	808	462	300		
	RadStd		53	82	145	141	159	154	159	159	134	97	63	40		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (67 neighbors)	+1.28	N/A	N/A	+1.78	N/A	N/A	-236	-356	+214	+99

Nomenclature: See separate page