

BAISOARA, Romania

WMO: 151630

Lat: 46.5356N

Lon: 23.3103E

Elev: 1362

StdP: 86.00

Time Zone: 2.00 (EUE)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.0	-11.9	-23.6	0.5	-3.3	-20.1	0.7	-5.9	12.4	-3.2	10.0	-3.6	1.4	320	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	23.2	16.3	21.8	15.5	20.4	14.9	17.5	21.9	16.6	20.6	15.8	19.5	1.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	13.4	19.3	15.1	12.6	18.4	14.2	11.9	18.1	55.1	22.3	51.8	20.6	49.3	19.5	20.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.2	5.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	-3.2	-1.6	0.4	4.7	10.1	13.6	14.5	15.1	10.3	6.9	1.5	-2.5
	DBStd	7.94	4.61	4.49	4.85	5.29	3.71	3.81	3.33	3.51	4.26	5.28	5.05	4.67
	HDD10.0	2089	411	326	299	171	44	12	4	3	51	124	256	388
	HDD18.3	4576	669	559	556	408	257	147	123	111	241	353	505	647
	CDD10.0	576	0	0	2	13	46	119	145	161	60	29	1	0
	CDD18.3	22	0	0	0	0	1	4	6	10	1	0	0	0
	CDH23.3	48	0	0	0	0	0	8	16	24	1	1	0	0
	CDH26.7	2	0	0	0	0	0	0	1	1	0	0	0	0
Wind	WSAvg	1.9	1.8	2.1	2.1	2.0	1.8	1.9	1.8	1.7	1.9	1.6	2.0	2.0
Precipitation	PrecAvg	732	34	30	40	59	83	104	103	74	65	51	45	46
	PrecMax	942	63	71	106	116	148	209	176	150	158	100	92	93
	PrecMin	503	11	7	9	9	43	27	31	7	7	3	1	5
	PrecStd	124	16	15	23	23	30	40	40	29	35	29	20	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.2	10.4	14.1	18.2	21.1	24.5	25.1	25.7	21.9	20.2	13.5	9.7
		MCWB	1.5	4.3	6.7	10.3	12.9	17.0	17.2	18.1	14.2	11.3	7.7	3.8
	2%	DB	5.7	8.0	11.0	15.9	18.6	22.4	22.5	23.2	19.3	17.7	11.2	7.1
		MCWB	1.0	3.6	5.3	9.3	12.3	16.7	15.7	16.1	13.1	10.6	6.9	3.0
	5%	DB	4.4	6.0	9.0	13.6	17.0	20.9	20.9	21.7	17.5	15.5	9.3	5.2
		MCWB	0.6	2.2	3.9	7.9	11.6	15.5	15.7	15.6	12.3	9.2	5.8	2.2
	10%	DB	2.9	4.2	7.1	11.6	15.2	19.2	19.4	20.0	15.8	13.8	7.8	3.8
		MCWB	0.2	1.5	2.9	6.8	10.7	14.8	14.7	15.2	11.6	8.7	5.0	1.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.2	6.4	7.6	11.5	14.1	18.7	18.2	18.7	14.7	12.7	8.9	5.5
		MCDB	5.7	8.7	13.3	16.7	19.2	22.6	22.8	23.8	19.9	17.3	11.5	7.8
	2%	WB	2.3	4.1	6.0	9.9	13.0	17.3	17.1	17.6	13.7	11.4	7.6	4.4
		MCDB	4.5	6.9	10.2	15.1	17.8	21.8	20.9	22.3	18.3	15.9	10.3	6.3
	5%	WB	1.4	3.0	4.6	8.7	12.1	16.2	16.2	16.4	12.9	10.4	6.6	3.0
		MCDB	3.5	5.2	8.2	13.1	16.4	20.4	19.7	20.5	16.9	15.1	9.0	4.5
	10%	WB	0.5	2.0	3.3	7.5	11.1	15.2	15.5	15.6	12.1	9.2	5.5	1.9
		MCDB	2.3	4.2	6.5	11.3	14.9	18.8	18.7	19.5	15.5	13.0	7.8	3.4
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.7	6.3	6.8	6.7	6.9	6.8	6.7	6.2	6.4	5.4	5.2
		MCDBR	6.2	7.4	8.2	9.1	8.5	8.8	8.4	8.4	8.0	8.5	6.3	5.8
		MCWBR	4.1	4.6	5.2	5.4	5.1	5.6	5.6	5.2	4.8	5.7	4.2	3.9
	5% WB	MCDBR	5.8	6.8	7.9	8.4	7.5	8.6	7.9	8.1	7.5	7.9	5.5	5.0
		MCWBR	4.2	4.7	5.2	5.1	5.1	5.8	5.5	5.3	4.7	5.4	4.3	3.9
Clear-Sky Solar Irradiance	taub	0.273	0.296	0.333	0.374	0.364	0.360	0.374	0.379	0.347	0.321	0.298	0.275	
	taud	2.398	2.362	2.336	2.258	2.332	2.361	2.318	2.306	2.381	2.450	2.468	2.435	
	Ebn at Noon	833	879	891	880	901	904	884	865	865	839	795	789	
	Edh at Noon	69	89	107	127	122	119	123	120	101	81	66	60	
All-Sky Solar Radiation	RadAvg	1.20	2.00	3.15	4.34	5.24	5.79	5.66	5.23	3.72	2.55	1.46	0.94	
	RadStd	0.17	0.26	0.46	0.46	0.45	0.50	0.48	0.50	0.42	0.30	0.20	0.12	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (67 neighbors)	+0.71	N/A	N/A	+0.99	N/A	N/A	-131	-198	+119	+55

Nomenclature: See separate page