

TARGU OCNA, Romania

WMO: 151940

Lat: 46.2728N

Lon: 26.6411E

Elev: 798

StdP: 14.28

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.1	13.1	4.0	6.9	11.5	7.7	8.4	15.5	20.3	42.8	17.0	35.1	3.3	290	0.482

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.1	89.5	69.8	86.4	69.0	83.9	68.2	73.0	84.7	71.2	82.5	69.7	80.8	5.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.5	111.6	78.4	67.5	104.0	76.3	65.9	98.5	74.6	37.1	85.6	35.5	82.6	34.2	81.1	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	14.3	12.4	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	28.6	34.7	41.4	50.9	61.4	68.6	70.6	71.0	62.1	51.1	41.8	34.0		
	DBStd	16.39	8.26	9.14	8.64	8.18	6.10	5.37	4.91	5.31	7.54	7.20	7.78	9.07		
	HDD50	2315	663	432	284	91	5	0	0	0	3	74	265	498		
	HDD65	5552	1128	850	731	424	140	27	11	12	140	432	695	962		
	CDD50	2839	0	2	18	117	359	557	638	652	367	107	20	2		
	CDD65	603	0	0	0	1	29	135	184	199	54	1	0	0		
	CDH74	5323	0	0	3	58	339	1166	1466	1765	500	24	2	0		
	CDH80	1685	0	0	0	5	60	335	480	673	132	0	0	0		
(14) Wind	WSAvg	5.0	4.4	4.5	5.2	5.8	5.5	5.6	5.0	5.5	5.3	4.7	3.8	5.0		
(15) Precipitation	PrecAvg	23.2	0.9	0.8	1.1	2.1	3.0	3.4	3.6	2.2	2.0	1.9	1.1	1.2		
	PrecMax	33.7	2.0	2.2	2.6	3.9	6.6	7.3	7.6	7.0	5.9	6.5	2.2	3.1		
	PrecMin	14.3	0.2	0.2	0.0	0.7	0.6	1.1	0.4	0.6	0.4	0.0	0.1	0.2		
	PrecStd	5.2	0.6	0.5	0.6	0.9	1.7	1.7	2.0	1.4	1.3	1.3	0.6	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.8	62.2	71.6	78.8	85.7	89.7	93.3	93.6	88.9	77.3	68.2	60.2		
		MCWB	46.3	51.2	54.0	60.6	64.8	73.0	69.2	71.3	67.9	61.7	55.9	49.0		
	2%	DB	48.4	57.2	64.8	75.2	81.2	86.5	88.6	89.8	83.2	71.9	62.4	53.6		
		MCWB	41.6	47.5	51.0	58.3	64.1	71.4	69.8	68.6	64.9	58.8	52.5	45.0		
	5%	DB	43.9	52.0	59.2	70.3	78.0	84.0	85.1	86.7	79.4	67.9	57.2	49.6		
		MCWB	38.6	44.5	47.8	55.8	62.6	69.4	68.7	68.5	63.8	57.4	50.1	43.5		
	10%	DB	40.3	47.3	55.2	65.8	74.4	81.4	81.8	83.6	75.4	62.8	52.8	46.0		
		MCWB	36.7	41.5	45.7	54.0	60.8	67.9	67.8	68.0	62.0	54.8	48.2	40.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.1	51.3	55.1	61.8	69.3	75.7	75.4	75.3	69.9	63.8	57.9	50.2		
		MCDB	54.3	61.4	68.8	75.7	84.4	87.7	86.2	86.1	84.6	73.1	67.8	56.9		
	2%	WB	42.9	47.8	51.7	59.5	66.3	72.8	72.0	72.6	67.1	60.6	53.9	46.3		
		MCDB	48.1	55.7	64.2	73.0	77.5	84.6	82.8	84.8	79.6	69.0	60.5	53.5		
	5%	WB	39.7	45.1	49.1	57.2	64.1	71.0	70.3	70.6	65.2	58.0	51.2	43.8		
		MCDB	43.1	51.5	58.4	69.1	73.8	82.0	80.9	82.4	76.3	65.7	55.9	49.5		
	10%	WB	36.8	42.1	46.5	54.8	62.2	69.2	69.1	69.1	63.6	55.5	48.8	41.4		
		MCDB	40.1	46.2	53.6	64.0	71.3	79.8	79.1	80.4	73.6	62.1	52.7	45.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	15.6	17.2	19.1	20.2	19.8	19.9	21.1	19.6	18.4	14.4	12.8		
		MCDBR	19.7	23.0	26.6	28.9	25.5	24.2	24.7	25.9	26.6	26.4	22.4	19.9		
		MCWBR	14.0	14.8	15.1	14.4	11.5	10.8	10.1	9.9	11.2	14.8	13.3	12.6		
	5% WB	MCDBR	19.3	21.6	25.1	27.0	22.8	22.5	21.6	23.4	24.4	24.1	19.6	19.0		
		MCWBR	13.9	14.4	14.7	13.7	11.6	11.2	10.1	10.9	10.7	14.1	12.4	12.3		
(40) Clear-Sky Solar Irradiance	taub		0.316	0.347	0.387	0.449	0.423	0.422	0.443	0.455	0.409	0.372	0.343	0.316		
	taud		2.336	2.258	2.215	2.080	2.231	2.271	2.220	2.181	2.271	2.360	2.387	2.359		
	Ebn at Noon		244	258	263	256	268	269	261	252	253	246	232	230		
	Edh at Noon		24	32	38	48	43	42	43	43	36	29	23	21		
(44) All-Sky Solar Radiation	RadAvg		408	656	1028	1393	1780	1872	1899	1724	1234	796	430	330		
	RadStd		52	80	104	131	154	163	155	128	122	92	40	36		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (60 neighbors)	+1.13	N/A	N/A	+1.21	N/A	N/A	-241	-324	+135	+36

Nomenclature: See separate page