

BLAJ, Romania

WMO: 152090

Lat: 46.1783N

Lon: 23.9353E

Elev: 1110

StdP: 14.12

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.2	12.4	2.1	6.4	9.4	7.7	8.5	14.3	36.3	31.8	34.9	37.3	5.5	0	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.6	88.6	69.2	85.9	68.1	83.1	67.0	71.3	84.1	69.8	82.3	68.4	79.9	6.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.4	104.9	76.1	65.8	99.0	73.7	64.6	94.9	72.3	35.8	84.4	34.4	82.6	33.3	80.0	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.4	23.4	21.0	-0.7	93.2	6.0	3.7	-5.0	95.9	-8.5	98.1	-11.9	100.1	-16.3	102.8		
(5)			-1.0	74.3	6.0	1.5	-5.3	75.3	-8.8	76.2	-12.2	77.0	-16.5	78.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.8	28.5	34.9	41.8	51.9	60.4	67.2	69.2	69.8	61.4	51.2	40.7	31.5	(6)
(7)		DBStd	16.06	8.27	8.70	7.71	7.62	5.86	5.35	4.75	5.06	7.38	7.18	8.33	8.32	(7)
(8)		HDD50	2373	666	423	268	68	3	0	0	3	74	295	573		(8)
(9)		HDD65	5671	1131	842	719	393	164	38	19	16	153	429	729	1038	(9)
(10)		CDD50	2658	0	1	13	125	324	515	594	613	346	111	16	0	(10)
(11)		CDD65	484	0	0	0	1	20	104	148	164	46	1	0	0	(11)
(12)		CDH74	4551	0	0	2	54	254	896	1276	1554	495	20	0	0	(12)
(13)		CDH80	1355	0	0	0	2	31	228	384	566	143	1	0	0	(13)
(14)	Wind	WSAvg	6.2	5.7	7.2	7.9	8.0	6.7	5.6	5.3	4.8	6.2	5.3	5.7	6.0	(14)
(15)	Precipitation	PrecAvg	22.1	0.9	0.7	1.0	2.0	2.6	3.5	3.2	2.0	2.2	1.7	1.2	1.3	(15)
(16)		PrecMax	30.6	1.8	2.0	2.2	4.4	4.6	7.2	6.1	4.3	6.3	3.7	2.7	2.9	(16)
(17)		PrecMin	14.2	0.2	0.2	0.2	0.2	1.1	1.4	0.7	0.2	0.1	0.1	0.0	0.1	(17)
(18)		PrecStd	4.8	0.5	0.4	0.5	0.9	1.1	1.5	1.3	1.0	1.3	1.0	0.6	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.3	61.3	70.1	79.2	83.4	89.5	90.4	93.8	89.9	76.8	66.0	52.6	(19)
(20)		0.4%	MCWB	42.5	48.1	52.2	59.4	63.7	70.6	70.7	70.8	68.3	61.3	54.7	45.6	(20)
(21)		2%	DB	44.2	55.2	63.5	74.9	79.8	85.8	87.3	89.1	83.9	71.9	61.0	47.7	(21)
(22)		2%	MCWB	40.8	46.4	49.6	57.0	62.5	69.2	69.6	68.7	66.0	58.8	52.2	43.8	(22)
(23)		5%	DB	41.0	51.3	58.6	70.3	76.7	82.4	84.4	86.1	79.5	68.1	57.0	44.3	(23)
(24)		5%	MCWB	38.1	44.5	47.2	54.9	61.3	67.4	68.4	67.6	63.1	56.7	50.3	41.4	(24)
(25)		10%	DB	38.0	47.4	54.4	66.0	73.4	79.4	81.5	82.8	75.5	64.0	53.3	41.4	(25)
(26)		10%	MCWB	36.0	42.0	44.7	53.3	59.8	66.2	67.0	66.9	62.1	55.2	48.1	39.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.8	50.5	53.6	61.0	65.7	73.5	73.4	73.0	69.4	62.9	55.6	47.8	(27)
(28)		0.4%	MCDWB	46.9	59.0	67.9	75.3	78.7	85.7	84.9	88.8	86.2	72.5	63.4	50.2	(28)
(29)		2%	WB	41.0	47.0	50.3	58.3	63.8	70.6	71.3	70.8	66.8	60.2	53.3	43.7	(29)
(30)		2%	MCDWB	44.1	53.7	61.5	72.6	76.1	81.9	83.2	85.2	80.6	68.6	59.1	46.9	(30)
(31)		5%	WB	38.6	44.8	47.8	56.0	62.5	68.8	69.8	69.2	64.9	58.1	51.1	41.8	(31)
(32)		5%	MCDWB	40.7	50.6	57.1	67.6	74.0	79.6	81.4	82.6	76.2	66.1	56.5	44.3	(32)
(33)		10%	WB	36.2	42.3	45.6	54.0	60.9	67.2	68.3	67.8	62.9	55.9	48.5	39.7	(33)
(34)		10%	MCDWB	37.8	47.1	52.9	63.6	71.3	77.1	78.4	79.7	72.4	63.0	52.8	41.6	(34)
(35)	Mean Daily Temperature Range		MDBR	10.4	15.4	18.5	20.6	19.9	20.3	21.3	22.6	20.8	19.4	13.8	9.2	(35)
(36)		5% DB	MCDBR	13.4	22.3	26.6	29.1	26.4	25.6	26.6	28.5	28.3	28.4	21.2	13.5	(36)
(37)		5% DB	MCWBR	9.9	13.9	14.7	13.4	11.1	10.4	10.2	9.8	11.2	15.0	12.8	10.0	(37)
(38)		5% WB	MCDBR	12.8	20.8	24.1	25.7	24.5	23.5	24.1	26.0	25.9	24.8	19.3	12.5	(38)
(39)		5% WB	MCWBR	9.8	13.3	13.5	12.0	10.7	10.1	10.0	9.7	11.0	13.1	11.7	9.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.312	0.340	0.381	0.435	0.419	0.415	0.434	0.442	0.400	0.365	0.339	0.313	(40)	
(41)		taud	2.351	2.299	2.241	2.118	2.226	2.270	2.224	2.197	2.285	2.371	2.390	2.372	(41)	
(42)		Ebn at Noon	246	261	266	260	269	271	263	255	257	249	234	232	(42)	
(43)		Edh at Noon	24	30	37	46	43	42	43	43	36	28	23	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	406	665	1019	1374	1667	1833	1812	1663	1188	820	472	321	(44)	
(45)		RadStd	52	81	132	143	157	161	156	155	130	99	60	41	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (79 neighbors)	+1.33	N/A	N/A	+1.78	N/A	N/A	-268	-387	+166	+41	(47)

Nomenclature: See separate page