

ADJUD, Romania

WMO: 152190

Lat: 46.1047N

Lon: 27.1703E

Elev: 102

StdP: 100.10

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.2	-10.6	-14.6	1.1	-12.0	-12.4	1.3	-8.8	15.7	-6.4	12.5	-4.5	2.9	320	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.4	32.8	21.2	31.1	20.8	29.7	20.6	23.7	29.0	22.7	27.8	21.9	27.0	2.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	17.3	25.3	21.3	16.2	24.4	20.4	15.2	23.8	71.4	28.6	67.7	28.0	64.5	27.1	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 11.9	9.2	7.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	-3.0	1.1	5.3	10.6	17.0	21.2	22.1	22.4	17.8	10.8	5.2	0.5
	DBStd	9.60	4.44	5.01	4.65	4.42	3.37	2.78	2.60	2.99	4.22	4.00	4.36	4.51
	HDD10.0	1344	403	249	154	47	2	0	0	0	1	39	153	296
	HDD18.3	3101	662	481	405	232	64	7	3	4	60	236	393	553
	CDD10.0	1698	0	1	8	66	218	335	376	386	236	62	11	0
	CDD18.3	413	0	0	0	1	22	92	121	132	45	1	0	0
	CDH23.3	3887	0	0	2	26	266	850	1057	1253	422	12	1	0
	CDH26.7	1361	0	0	0	2	56	269	379	529	125	1	0	0
(14) Wind	WSAvg	3.0	3.3	3.2	3.6	3.7	3.1	3.0	2.7	2.9	2.7	2.5	2.7	3.0
(15) Precipitation	PrecAvg	557	22	21	27	47	68	83	72	53	47	50	31	33
	PrecMax	836	53	70	60	90	162	189	189	164	147	206	83	102
	PrecMin	335	3	3	2	18	14	17	9	14	8	2	2	2
	PrecStd	131	14	16	14	23	38	51	46	35	34	41	20	26
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.3	16.4	21.5	25.9	30.6	33.1	34.2	34.9	31.7	25.1	19.9	12.9
		MCWB	6.6	11.3	13.1	17.4	19.4	23.6	22.1	22.7	19.4	17.5	13.9	8.5
	2%	DB	6.5	12.5	17.4	23.6	28.2	31.0	32.3	33.1	29.6	22.2	16.2	10.6
		MCWB	4.9	9.5	10.9	15.4	18.5	22.1	21.5	20.4	18.7	15.8	12.1	8.2
	5%	DB	4.4	9.5	15.0	21.3	26.4	29.6	30.4	31.4	27.9	19.9	13.4	8.5
		MCWB	3.3	7.1	10.0	14.5	18.0	21.3	21.2	20.5	17.6	14.7	10.9	6.5
	10%	DB	2.7	7.3	12.6	18.9	24.5	28.1	28.7	29.7	25.8	17.3	11.2	5.9
		MCWB	1.8	6.0	8.2	13.3	17.0	20.5	20.7	20.3	17.5	13.4	9.6	4.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	12.2	14.1	18.8	23.1	25.2	24.6	24.6	22.5	20.0	14.4	10.3
		MCDB	8.9	15.3	20.1	23.5	25.2	29.6	30.6	30.2	26.5	23.6	18.9	11.4
	2%	WB	5.4	10.0	12.1	16.7	20.5	23.7	23.2	23.2	20.7	17.2	12.8	8.3
		MCDB	6.4	11.9	16.4	21.8	24.6	29.2	28.3	28.8	25.1	20.1	15.9	10.7
	5%	WB	3.6	7.7	10.4	15.2	19.4	22.6	22.4	22.2	19.3	15.6	11.7	6.7
		MCDB	4.5	9.2	14.2	20.5	24.0	27.9	27.3	27.7	24.8	18.3	13.4	8.5
	10%	WB	2.1	6.0	9.1	13.7	18.1	21.5	21.6	21.4	18.3	14.2	9.9	4.9
		MCDB	2.8	7.0	12.0	18.3	22.5	26.8	26.4	26.7	23.8	16.9	11.4	5.6
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	7.1	9.6	10.9	11.9	11.7	11.5	12.4	11.8	9.9	7.0	5.7
		MCDBR	8.1	11.4	14.9	15.6	15.0	13.7	14.2	15.3	15.7	14.1	11.7	9.1
		MCWBR	6.2	7.8	8.8	8.2	6.7	5.9	5.3	5.1	6.0	8.3	7.3	6.8
	5% WB	MCDBR	8.0	10.4	13.4	14.4	12.4	12.9	11.8	12.8	13.4	12.4	10.4	8.8
		MCWBR	6.3	8.0	8.4	8.2	7.4	6.6	5.5	5.5	5.7	8.0	6.9	6.8
(40) Clear-Sky Solar Irradiance	taub		0.328	0.359	0.397	0.458	0.430	0.429	0.449	0.462	0.418	0.382	0.354	0.327
	taud		2.308	2.240	2.194	2.054	2.215	2.256	2.207	2.162	2.246	2.325	2.350	2.326
	Ebn at Noon		753	798	820	799	840	841	817	788	790	764	716	708
	Edh at Noon		79	103	124	156	138	133	138	139	117	94	76	70
(44) All-Sky Solar Radiation	RadAvg		1.29	2.08	3.25	4.41	5.61	5.91	6.00	5.44	3.91	2.53	1.37	1.05
	RadStd		0.16	0.25	0.33	0.42	0.48	0.50	0.48	0.40	0.38	0.29	0.13	0.12

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	-128	-170	+71	+23

Nomenclature: See separate page