

TIMISOARA, Romania

WMO: 152470

Lat: 45.7711N

Lon: 21.2581E

Elev: 286

StdP: 14.54

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.8	16.2	7.8	8.3	14.1	12.3	10.4	18.8	21.9	32.9	18.5	34.3	3.8	100	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	93.6	69.3	91.1	69.5	87.7	68.3	73.2	85.5	71.6	83.8	70.2	82.5	6.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.9	111.3	76.7	68.1	104.4	75.2	66.4	98.3	73.6	37.0	85.5	35.5	83.3	34.3	82.2	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	15.1	12.7		3.9	97.8	6.6	3.4	-0.8	100.3	-4.7	102.2	-8.3	104.1	-13.1	106.6
				3.5	76.4	6.5	2.2	-1.2	77.9	-5.0	79.2	-8.7	80.4	-13.4	82.0
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.4	32.3	35.9	44.0	54.1	62.6	69.0	72.5	72.4	63.5	53.8	44.4	34.6 (6)
	DBStd	16.04	8.33	9.37	7.99	7.00	6.50	6.28	5.56	5.74	6.74	7.73	8.19	8.38 (7)
	HDD50	1936	548	397	216	40	1	0	0	0	0	51	206	477 (8)
	HDD65	4997	1013	814	652	330	124	31	7	8	106	352	619	941 (9)
	CDD50	3165	0	3	29	163	392	571	697	695	406	170	37	2 (10)
	CDD65	748	0	0	0	3	50	152	238	238	62	5	0	0 (11)
	CDH74	8436	0	0	1	83	611	1695	2656	2636	676	78	0	0 (12)
	CDH80	3421	0	0	0	9	134	649	1206	1206	211	6	0	0 (13)
(14) Wind	WSAvg	5.1	4.9	5.2	6.0	5.7	5.3	4.9	4.9	4.6	4.7	4.6	5.1	4.8 (14)
(15) Precipitation	PrecAvg	24.2	1.5	1.4	1.4	1.9	2.4	3.1	2.4	2.1	1.8	1.7	1.9	1.9 (15)
	PrecMax	33.2	3.5	3.8	4.2	6.1	6.5	7.1	7.4	5.6	5.8	7.7	5.0	5.5 (16)
	PrecMin	16.0	0.1	0.0	0.2	0.2	0.2	0.9	0.2	0.0	0.0	0.0	0.1	0.0 (17)
	PrecStd	3.9	0.9	1.0	0.9	1.0	1.3	1.4	1.5	1.5	1.2	1.4	1.0	1.2 (18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.6	62.9	71.3	80.9	87.4	93.6	98.3	98.6	91.5	80.2	69.9	58.4 (19)
		MCWB	49.3	50.7	54.1	61.5	66.0	70.2	69.5	69.3	67.2	62.8	58.4	51.2 (20)
	2%	DB	50.2	57.4	66.3	75.8	83.8	90.4	93.6	94.7	85.6	75.7	64.7	53.5 (21)
		MCWB	46.5	49.1	52.3	58.7	65.2	70.2	69.5	68.7	65.3	61.4	55.2	48.7 (22)
	5%	DB	46.6	53.0	62.4	71.9	80.7	87.3	91.0	91.0	81.3	71.8	60.9	49.7 (23)
		MCWB	44.2	46.9	50.8	56.7	64.4	69.1	69.9	69.0	64.2	59.7	53.6	46.7 (24)
	10%	DB	43.1	48.6	57.6	68.2	77.2	83.9	86.7	87.4	77.2	67.4	57.0	46.1 (25)
		MCWB	41.6	44.7	48.5	55.2	62.6	67.7	68.7	68.1	63.2	57.8	51.7	44.3 (26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.6	52.2	56.9	63.5	69.6	75.2	75.0	76.0	69.8	65.7	59.3	52.8 (27)
		MCDB	53.9	59.7	66.3	76.4	81.8	88.1	86.3	87.2	82.6	75.5	66.0	55.5 (28)
	2%	WB	47.3	50.0	54.3	60.7	67.4	72.5	72.9	72.9	67.6	63.0	56.8	49.4 (29)
		MCDB	49.8	56.3	63.0	71.7	79.2	84.3	85.3	85.0	79.6	72.1	63.0	52.9 (30)
	5%	WB	44.3	47.7	51.8	58.8	65.6	70.7	71.4	71.0	66.0	60.9	54.6	46.7 (31)
		MCDB	46.1	52.2	60.2	68.6	77.2	82.3	83.9	83.4	76.9	69.1	60.0	49.1 (32)
	10%	WB	41.4	45.0	49.8	56.7	63.9	69.1	70.1	69.5	64.4	59.0	52.0	44.1 (33)
		MCDB	42.9	48.0	56.9	65.9	74.5	80.3	82.8	81.9	74.2	66.4	56.5	45.7 (34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	15.0	19.2	21.4	22.0	22.3	23.6	24.0	21.3	20.5	15.9	11.0 (35)
		MCDBR	16.6	22.5	26.6	28.1	27.2	27.5	29.6	29.8	27.8	26.3	21.7	16.3 (36)
	5% WB	MCWBR	12.6	14.9	14.7	13.3	11.7	10.5	9.5	9.4	11.0	13.1	13.3	11.9 (37)
		MCWBR	15.6	20.0	23.4	23.8	24.8	24.6	25.1	24.9	23.1	23.5	20.0	14.7 (38)
(40) Clear-Sky Solar Irradiance	taub		0.342	0.369	0.405	0.460	0.444	0.438	0.450	0.458	0.434	0.393	0.361	0.341 (40)
		taud	2.325	2.256	2.194	2.052	2.166	2.219	2.188	2.166	2.199	2.302	2.344	2.343 (41)
	Ebn at Noon		235	251	258	253	262	264	259	251	246	239	226	221 (42)
		Edh at Noon	25	32	40	50	46	44	45	44	39	31	25	23 (43)
(44) All-Sky Solar Radiation	RadAvg		369	638	1040	1468	1782	1963	1955	1746	1217	828	489	294 (44)
	RadStd		40	89	134	140	161	161	149	162	134	86	40	43 (45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.37	N/A	N/A	N/A	N/A	N/A	N/A	-326	+230	+121 (46)
(47) Regional (60 neighbors)		+1.24	N/A	N/A	N/A	+0.72	N/A	-209	-315	+205	+108 (47)

Nomenclature: See separate page