

TIMISOARA, Romania

WMO: 152470

Lat: 45.7711N

Lon: 21.2581E

Elev: 87

StdP: 100.28

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.2	-8.8	-13.4	1.2	-10.0	-10.9	1.5	-7.3	9.8	0.5	8.3	1.3	1.7	100	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	34.2	20.7	32.8	20.9	31.0	20.2	22.9	29.7	22.0	28.8	21.2	28.1	2.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.1	15.9	24.9	20.1	14.9	24.0	19.1	14.0	23.1	68.2	29.7	64.7	28.5	62.0	27.9	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	6.7	5.7	-15.6	36.6	3.6	1.9	-18.2	37.9	-20.4	39.0	-22.4	40.1	-25.1	41.4		
(5)			-15.8	24.6	3.6	1.2	-18.4	25.5	-20.6	26.2	-22.6	26.9	-25.2	27.8	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	0.2	2.2	6.6	12.3	17.0	20.6	22.5	22.4	17.5	12.1	6.9	1.5	(6)	(7)
	DBStd	8.91	4.63	5.21	4.44	3.89	3.61	3.49	3.09	3.19	3.74	4.30	4.55	4.66	(7)	(8)
	HDD10.0	1076	304	221	120	22	1	0	0	0	0	28	114	265	(8)	(9)
	HDD18.3	2776	563	452	362	183	69	17	4	4	59	196	344	523	(9)	(10)
	CDD10.0	1758	0	2	16	91	218	317	387	386	226	94	21	1	(10)	(11)
	CDD18.3	416	0	0	0	2	28	84	132	132	34	3	0	0	(11)	(12)
	CDH23.3	4687	0	0	1	46	339	942	1476	1464	376	43	0	0	(12)	(13)
	CDH26.7	1901	0	0	0	5	74	361	670	670	117	3	0	0	(13)	(14)
(14) Wind	WSAvg	2.3	2.2	2.3	2.7	2.5	2.3	2.2	2.2	2.1	2.1	2.1	2.3	2.2	(14)	(15)
(15) Precipitation	PrecAvg	614	39	36	36	49	62	78	61	53	46	44	48	49	(15)	(16)
	PrecMax	844	90	96	106	154	166	180	187	142	147	195	127	140	(16)	(17)
	PrecMin	407	3	0	4	4	6	24	5	1	1	0	2	1	(17)	(18)
	PrecStd	100	22	25	22	25	34	36	37	37	30	36	26	30	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	17.2	21.8	27.2	30.8	34.2	36.9	37.0	33.1	26.8	21.1	14.7	(19)	(20)
		MCWB	9.6	10.4	12.3	16.4	18.9	21.2	20.9	20.7	19.6	17.1	14.7	10.6	(20)	(21)
	2%	DB	10.1	14.1	19.1	24.3	28.8	32.4	34.2	34.8	29.8	24.3	18.1	12.0	(21)	(22)
		MCWB	8.0	9.5	11.3	14.8	18.4	21.2	20.9	20.4	18.5	16.3	12.9	9.3	(22)	(23)
	5%	DB	8.1	11.7	16.9	22.1	27.0	30.7	32.8	32.8	27.4	22.1	16.0	9.8	(23)	(24)
		MCWB	6.8	8.3	10.5	13.7	18.0	20.6	21.0	20.6	17.9	15.4	12.0	8.1	(24)	(25)
	10%	DB	6.2	9.2	14.2	20.1	25.1	28.8	30.4	30.8	25.1	19.7	13.9	7.8	(25)	(26)
		MCWB	5.3	7.1	9.2	12.9	17.0	19.8	20.4	20.0	17.3	14.3	11.0	6.8	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.3	11.2	13.8	17.5	20.9	24.0	23.9	24.4	21.0	18.7	15.1	11.6	(27)	(28)
		MCDB	12.2	15.4	19.0	24.6	27.7	31.2	30.2	30.7	28.1	24.2	18.9	13.1	(28)	(29)
	2%	WB	8.5	10.0	12.4	15.9	19.6	22.5	22.7	22.7	19.8	17.2	13.8	9.7	(29)	(30)
		MCDB	9.9	13.5	17.2	22.0	26.2	29.1	29.6	29.4	26.5	22.3	17.2	11.6	(30)	(31)
	5%	WB	6.8	8.7	11.0	14.9	18.7	21.5	21.9	21.7	18.9	16.1	12.5	8.2	(31)	(32)
		MCDB	7.8	11.2	15.7	20.4	25.1	28.0	28.8	28.6	25.0	20.6	15.6	9.5	(32)	(33)
	10%	WB	5.2	7.2	9.9	13.7	17.7	20.6	21.2	20.8	18.0	15.0	11.1	6.7	(33)	(34)
		MCDB	6.1	8.9	13.8	18.8	23.6	26.9	28.2	27.7	23.5	19.1	13.6	7.6	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.5	8.4	10.7	11.9	12.2	12.4	13.1	13.3	11.8	11.4	8.9	6.1	(35)	(36)
		MCDBR	9.2	12.5	14.8	15.6	15.1	15.3	16.4	16.6	15.4	14.6	12.0	9.1	(36)	(37)
	5% WB	MCWBR	7.0	8.3	8.2	7.4	6.5	5.8	5.3	5.2	6.1	7.3	7.4	6.6	(37)	(38)
		MCWBR	8.7	11.1	13.0	13.2	13.8	13.7	13.9	13.8	12.8	13.0	11.1	8.2	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub	taub	0.342	0.369	0.405	0.460	0.444	0.438	0.450	0.458	0.434	0.393	0.361	0.341	(39)	(40)
		taud	2.325	2.256	2.194	2.052	2.166	2.219	2.188	2.166	2.199	2.302	2.344	2.343	(40)	(41)
	Ebn at Noon	Ebn at Noon	741	791	814	798	827	833	817	792	775	753	711	697	(41)	(42)
		Edh at Noon	79	102	125	157	145	138	141	139	123	97	78	71	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg	RadAvg	1.16	2.01	3.28	4.63	5.62	6.19	6.16	5.50	3.84	2.61	1.54	0.93	(43)	(44)
	RadStd	RadStd	0.13	0.28	0.42	0.44	0.51	0.51	0.47	0.51	0.42	0.27	0.13	0.14	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	-181	+128	+67	(46)
(47)	Regional (60 neighbors)	+0.69	N/A	N/A	N/A	+0.40	N/A	-116	-175	+114	+60	(47)

Nomenclature: See separate page